

O.G.E.R.O. VAT NO: 601-122958

QUOTATION REQUEST

طلب عرض اسعار

اوجيرو

QR 37 / 2023TD008

Page 1 of 1

QR Date 27/02/2023

#	A- ITEM CODE B-ITEM DESCRIPTION	MATERIALS المواد	أ- رمز الصنف ب- التوصيف	UNIT	NB/U	Quantity	Unit Price	Total Price
1	ELBE0060 Circuit Breaker 4 poles, 10amp, Rail Mounting, LCU 6KA C characteristic. Rated Voltage Un:400/415V. Trade mark: USA, Europe, Japan or equivalent.			EA	1	12.00		
2	ELCB0038 Auxiliary Switch 400 /415V Rated 3A Rated Current In with 1 Contact 1NC+1NO			EA	1	12.00		
3	ELJU0011 Copper bus bars used for earth, length=40cm, width=5cm, thickness=5 to 6mm.			EA	1	30.00		
4	ELSP0000 Surge Arrestor 255V Rated, 1 Phase, Response Time <= 25ns, In(10/350) >=60KA Test Certificate Veritas. (Brand: Phoenix, Dehn, ABB, OBO, Saltel, Citel or equivalent)			EA	1	40.00		
5	ELSP0004 Surge Arrestor 275V Rated, 1 Phase, Response Time <= 25ns, In(8/20), 15/20KA. Test Certificate Veritas. (Brand: Phoenix, Dehn, ABB, OBO, Saltel, Citel or equivalent)			EA	1	300.00		

٢١