

## مُلخَص عن التلزيْم

مصرف لبنان – مديرية الخدمات	إسم الجهة الشارعية
مصرف لبنان – الحمرا – المركز الرئيسي	عنوان الجهة الشارعية
SD00354-23 في ٢٠٢٣-١٠-٥	رقم وتاريخ التسجيل
تلزيم صيانة أنظمة مكافحة الحريق في المركز الرئيسي والفروع	عنوان التلزيْم
يرغب مصرف لبنان بتلزيْم صيانة أنظمة مكافحة الحريق في المركز الرئيسي وفروعه كافة يتضمن التلزيْم كلفة اليد العاملة والنقل وقطع الغيار للأعطال المستجدة في حال طلب ذلك مصرف لبنان من الملتزم.	موضوع التلزيْم
مناقصة عمومية عن فترة زمنية تبدأ اعتباراً من ٢٠٢٤/٠١/٠١ ولغاية نهاية ٢٠٢٥/١٢/٣١ من ضمنها أيام الأحاد والأعياد الرسمية.	طريقة التلزيْم
خدمات- أعمال صيانة	نوع التلزيْم
٩٠ يوم من التاريخ النهائي لتقديم العروض	مدة صلاحية العرض <sup>١</sup>
كتاب ضمان مصرفي صادر عن مصرف مقبول من مصرف لبنان ولصالحه بقيمة //٤,٠٠٠// دولار أميركي بموجب الملحق رقم (٤)	ضمان العرض <sup>٢</sup>
١١٨ يوم من تاريخ جلسة التلزيْم	مدة صلاحية ضمان العرض <sup>٣</sup>
كتاب ضمان مصرفي صادر عن مصرف مقبول من مصرف لبنان ولصالحه بنسبة ١٠ بالمائة من قيمة العقد النهائية (بموجب الملحق ٤)	ضمان حسن التنفيذ <sup>٤</sup>
<p>1- في المرحلة الأولى يتم تقييم الشروط التقنية والفنية بحسب ما نصّ عليه الملحق رقم (١) وفقاً للجدول <b>Technical Evaluation Grading</b>، إن الإستحصال على علامة دون ١٠٠/٧٠ ستؤدي إلى إعتبار العارض مرفوض تقنياً وغير مؤهل للمرحلة الثانية، بحيث يتم فض عرضه المالي.</p> <p>2- في المرحلة الثانية، يتم وضع العلامات وفقاً لجدول الـ <b>Commercial Evaluation</b>.</p> <p>3- يسند التلزيْم بعد تحليل الأسعار إلى العرض الأفضل نتيجة الإستحصال على أعلى علامة بموجب معادلة نسبية بين العرض التقني والأكلاف المالية المتمثلة بكلفة اليد العاملة وقطع الغيار للأعطال المستجدة على الشكل التالي:</p> <ul style="list-style-type: none"> <li>• <b>العرض التقني ٤٠%:</b> أي يستحصل على نسبة كاملة ٤٠% العارض المستحصل على أعلى علامة في التقييم التقني بحيث باقي العروض المقبولة تستحصل على النسبة المحتسبة من الـ ٤٠% مقارنة مع العلامة التقنية الأعلى،</li> <li>• <b>الأكلاف المالية ٦٠%:</b> أي يستحصل على نسبة كاملة ٦٠% العارض المستحصل على أعلى علامة في التقييم المالي بحيث باقي العروض المقبولة تستحصل على النسبة المحتسبة من الـ ٦٠% مقارنة مع العلامة المالية الأدنى،</li> </ul> <p>4- يمكن للمصرف تجزئة التلزيْم بحسب الأنواع المفصلة في الملحق رقم (٥).</p> <p>5- في حال تجزئة التلزيْم: يتم إرساء التلزيْم لمورد واحد أو أكثر وذلك لمجموعة واحدة أو أكثر بحسب تقسيم جدول الكميات وفقاً لما هو مفصّل في الملحق رقم (٥). يكون الملتزم مسؤول عن تنفيذ أعمال الصيانة والتصلّيات كافة بناءً للأكلاف المقدمة من قبله خلال فترة التلزيْم.</p>	معايير التقييم
منشور على منصة هيئة الشراء العام مع الإشارة أن الراغبين جدياً بالإشتراك بالمناقصة إرسال بريد إلكتروني على العنوان التالي: <a href="mailto:purchasingunit@bdl.gov.lb">purchasingunit@bdl.gov.lb</a> مرفق به إذاعة تجارية للشركة لا يعود تاريخها لأكثر من سنة وذلك قبل ٤ أيام من الموعد النهائي لتقديم العروض	مكان استلام دفتر الشروط الخاص
مصرف لبنان- الحمرا- بلوك ب- الطابق الأول- وحدة المشتريات – الطابق الأول	مكان تقديم العروض

زيارة الموقع	ضرورة مع العلم أن مواعيد الزيارات محددة في جدول المواعيد المرفق
موعد فض العروض	الاثنين ٣٠-١٠-٢٠٢٣ الساعة الحادية عشرة صباحاً* فوراً عند انتهاء موعد تقديم العروض.
مكان فض العروض	مصرف لبنان- المركز الرئيسي- مديرية الشؤون القانونية – مبنى "أ" – الطابق الخامس
مدة التنفيذ	إن مدة العقد تبدأ اعتباراً من ٢٠٢٤/٠١/٠١ ولغاية نهاية ٢٠٢٥/١٢/٣١ من ضمنها أيام الأعياد والأعياد الرسمية. على أن يتم الحضور إلى مصرف لبنان خلال ٤ ساعات من طلبنا مباشرة للقيام بالزيارة الميدانية لزوم الكشف والصيانة إضافة إلى المضي بالتصليح خلال مهلة أقصاها ٢٤ ساعة بما فيها فترات الأعياد الرسمية وأيام الأعياد من تاريخ تبليغ الملتزم بالعطل. يجب تأمين القطع المطلوبة على مدى سبعة أيام في الأسبوع وذلك ٢٤/٢٤ ساعة حتى خلال فترات الأعياد الرسمية وأيام الأعياد.
عملة العقد	بالدولار الأميركي
دفع قيمة العقد	يسدد مصرف لبنان المستحقات المسعرة بالدولار الأميركي نقداً بالليرة اللبنانية على أساس سعر منصة صيرفة مضافاً إليها، إن وجب ذلك، هامشاً (هامش نسبي %) تراعى فيه، في حينه، الفروقات المتعددة لتسعير الليرة اللبنانية مقابل الدولار الأميركي في حال توفرها. يتم تحديد الهامش من قبل مصرف لبنان بتاريخ تسديد كل دفعة لإحتساب قيمتها النهائية.

## مصرف لبنان

# دفتر شروط خاص بتلزم صيانة أنظمة مكافحة الحريق في المركز الرئيسي وفروعه متضمنة كلفة اليد العاملة والنقل وقطع الغيار للأعطال المستجدة

تمت المصادقة على أحكام دفتر الشروط الخاص الحاضر كافة بتاريخ .....

يرجى ، تحت طائلة رفض العرض ، التقيد حرفياً بالشروط الشكلية والموضوعية المطلوبة بموجب دفتر الشروط الخاص الحاضر.

## Checklist

Please check the fields below with

✓ Submitted Document (مستند مقدم)

X Document Not Submitted (مستند غير مقدم)

المستندات المقدمة من قبل العارض	المستندات المطلوبة من قبل مصرف لبنان
	1. إذاعة تجارية
	2. شهادة تسجيل في السجل التجاري
	3. التفويض القانوني بالتوقيع عن العارض
	4. عقد الشراكة (Joint Venture) إن وجدت
	5. شهادة تسجيل العارض في الـ TVA
	6. شهادة تسجيل العارض لدى وزارة المالية
	7. براءة ذمة صادرة عن الصندوق الوطني للضمان الإجتماعي
	8. محضر اجتماع جمعية عمومية للمساهمين مع لائحة الحضور
	9. إفادة شاملة صادرة عن السجل التجاري
	10. كتاب تعهد بالامتثال
	11. بطاقة إنتساب العارض في أي من النقابات
	12. في حال كان العارض شركة أجنبية: • التفويض القانوني بالتوقيع • شهادة تسجيل شركته أو مؤسسته لدى المراجع المعنية في بلده • إفادة من وزارة الاقتصاد والتجارة اللبنانية تثبت مقاطعة العدو الإسرائيلي
	13. افادة صادرة عن المحكمة المختصة تثبت ان العارض ليس في حالة افلاس
	14. افادة صادرة عن المحكمة المختصة تثبت ان العارض ليس في حالة تصفية
	15. مستند يحدد فيه العارض مكاناً لإقامته
	16. كتاب تعهد
	17. كتاب ضمان مصرفي
	18. دفتر الشروط الخاص الحاضر مختوماً وموقعاً وفقاً للأصول
	19. الظرف المختوم المتضمن لوائح الأسعار مختومة وموقعة وفقاً للأصول
	20. لائحة الشروط التقنية والفنية (ملحق رقم 1) مختومة وموقعة وفقاً للأصول مع جدول الكميات و المستندات كافة المفصلة في الملحق المذكور.
	21. لائحة ببعض زبائن العارض ولمشاريع مماثلة
	22. سجل عدلي للمفوض بالتوقيع
	23. شهادة إنتساب صادرة عن غرفة التجارة والصناعة والزراعة
	24. شهادة الجودة الخاصة بالعارض (ISO).
	25. Catalogue- Brochure-....
	26. أي مستند اضافي، ان وجد (Any Other Document, if available)

## القسم الأول أحكام خاصة بتقديم العروض وارساء التلزم

### المادة 1: المصطلحات

1. يقصد بكلمة "المصرف" الجهة الشارية - مصرف لبنان.
2. يقصد بكلمة "العارض" المؤسسة أو الشركة مقدمة العرض أو أي شخص طبيعي.
3. يقصد بكلمة "الملتزم" المؤسسة أو الشركة التي تم اعتماد عرضها أو أي شخص طبيعي.
4. يقصد بكلمة "قانون الشراء العام" القانون رقم 21/244 تاريخ 2021/07/19.
5. يقصد بكلمة "المناقصة"/"عروض أسعار" إجراءات الشراء بواسطة مناقصة عمومية أو عروض أسعار.
6. يقصد بكلمة "لجنة التلزم" لجنة التلزم لدى المصرف المنصوص عليها في المادة 100 من قانون الشراء العام.
7. يقصد بكلمة "لجنة الاستلام" لجنة الاستلام لدى المصرف المنصوص عليها في المادة 101 من قانون الشراء العام.
8. يقصد بكلمة "العقد" العقد الذي سيوقع بين المصرف والملتزم.
9. يقصد بكلمة "الإلتزام / التلزم" مشروع تلزم صيانة أنظمة مكافحة الحريق في المركز الرئيسي وفروعه كافة.

### المادة 2: الدعوة إلى التلزم

- 1- تتم الدعوة الى هذا التلزم عبر الإعلان والنشر على المنصة الالكترونية المركزية لدى هيئة الشراء العام.
  - 2- مرفقات دفتر الشروط الخاص:
    - الملحق رقم 1: لائحة الشروط التقنية والفنية
    - الملحق رقم 2: كتاب التعهد
    - الملحق رقم 3: مستند تصريح النزاهة
    - الملحق رقم 4: نموذج كتاب ضمان
    - الملحق رقم 5: لوائح الأسعار والكشف بالكميات
    - إن لائحة قطع الغيار هي على سبيل المثال لا الحصر، كونه قد يطرأ أعطال لقطع غير مذكورة فيها.
    - الملحق رقم 6: تحليل الأسعار
    - الملحق رقم 7: كتب الإمتثال (خمسة - 5- وثائق)
- إن دفتر الشروط الخاص منشور على المنصة الالكترونية المركزية لدى هيئة الشراء العام ويمكن الحصول على نسخة منه عبر البريد الإلكتروني بعد مراجعة وحدة المشتريات لدى مصرف لبنان.
- يُطبق على دفتر الشروط الخاص الحاضر أحكام قانون الشراء العام رقم 244 تاريخ 2021/7/29 والأنظمة الأخرى المرعية الإجراء.

### المادة 3: طريقة التلزم والمعايير المعتمدة

يجري التلزم عبر الإعلان على المنصة الإلكترونية المركزية لدى هيئة الشراء العام. يسند التلزم مؤقتاً الى العارض المقبول شكلاً من الناحية الإدارية والفنية والتقنية والمالية وفقاً للمعايير المحددة في تحليل الأسعار (الملحق رقم 6).

## المادة 4: شروط مشاركة العارضين

I- يحق الاشتراك في هذا التلزم لكل شخص معنوي/طبيعي تتوافر فيه الشروط التالية:

- 1- يقدم العرض بصورة واضحة وجليّة جداً من دون أي شطب أو حك.
- 2- يصرح العارض في عرضه أنه اطلع على دفتر الشروط الخاص هذا والمستندات المتممة له وأخذ نسخة عنه؛ وأنه يقبل الشروط المبينة فيه ويتعهد التقيد بها وتنفيذها جميعها من دون أي نوع من أنواع التحفظ أو الاستدراك وأنه يقدم عرضه على هذا الأساس ويلصق على كتاب التعهد والتصريح المرفقين ربطاً بالطابع المالية المتوجبة.
- 3- يلتزم بكتمان السر المنشأ بقانون ٣ أيلول ١٩٥٦ ويشمل هذا الموجب جميع المعلومات التي قد يستحصل عليها من مصرف لبنان أو قد يطلع عليها وعليه أن يحافظ على هذه المعلومات بالعناية التي يحافظ بها على المعلومات السرية الخاصة به.
- 4- يرفض كل عرض يتضمن أي تحفظ أو استدراك.

II- يتوجب على العارض تقديم مغلفين يتضمنان المستندات المعددة أدناه ( أصل أو صورة طبق الأصل) وفقاً لما يلي:

### أولاً: الغلاف رقم (١) الوثائق والمستندات الإدارية والتقنية

#### الوثائق والمستندات الإلزامية:

- 1- إذاعة تجارية محدّد فيها صاحب الحق المفوض بالتوقيع عن العارض، تُبين توقيع المفوض قانوناً بالتوقيع على العرض، مصادق عليها لدى السجل التجاري بتاريخ لا يقل عن سنة (صورة طبق الاصل) – ان يكون موضوع الشركة واضح يتماشى مع نوع الخدمات التي تقدمها لمصرف لبنان.
- 2- شهادة تسجيل في السجل التجاري.
- 3- التفويض القانوني بالتوقيع عن العارض مصدقاً عليه وفقاً للأصول في حال توجبه (وكالة لدى كاتب العدل) او محضر مجلس ادارة لا يتعدى سنة من تاريخ انعقاد الاجتماع مصادق عليه لدى السجل التجاري المتضمن التفويض بالتوقيع.
- 4- عقد الشراكة مصدقاً عليه وفقاً للأصول في حال توجبه (Joint Venture).
- 5- شهادة تسجيل العارض في وزارة المالية يتضمن رقم تسجيل العارض كمكلف بالضريبة على القيمة المضافة إذا كان خاضعاً لها. وفي حال عدم خضوع العارض لأحكام الضريبة على القيمة المضافة، عليه ان يذكر ذلك خطأً وعلى كامل مسؤوليته.
- 6- شهادة تسجيل العارض لدى وزارة المالية.
- 7- براءة ذمة صادرة عن الصندوق الوطني للضمان الإجتماعي مصدقاً عليها وفقاً للأصول لا يعود تاريخها لأكثر من سنة.
- 8- محضراجماع جمعية عمومية للمساهمين مع لائحة الحضور (تحدد هوية ونسبة ملكية مع توقيع كل شخص او شركة يملك اكثر من ٢٠% في رأسمال الشخص المعنوي) لا يتعدى ثلاث سنوات من تاريخ انعقاد الاجتماع، مصادق عليه لدى السجل التجاري.
- 9- إفادة شاملة صادرة عن السجل التجاري تبين: المؤسسين، الأعضاء، المساهمين، المفوضين بالتوقيع، المدير، رأس المال، ...
- 10- كتاب تعهد بالامتنال معد من قبل وحدة الإمتثال لدى المصرف مختوماً وموقعاً وفقاً للأصول (الملحق رقم ٧).



- 11- بطاقة إنتساب العارض في أي من النقابات في حال كان مشروع الإلتزام متعلق بمهنة منظمة من قبل نقابة.
- 12- في حال كان العارض شركة أجنبية، يتوجب الحضور للممثل القانوني عن الشركة أو أن يكون لها وكيل أو ممثل في لبنان مكلف بتوقيع عنها المستندات والوثائق والعقد الناتج عن الإلتزام. في هذه الحالة، يتوجب أيضاً على العارض الأجنبي أن يتقدم بما يلي:
  - شهادة تسجيل شركته أو مؤسسته لدى المراجع المعنية في بلده مصدقة من السفارة اللبنانية ووزارة الخارجية في لبنان.
  - إفادة من وزارة الاقتصاد والتجارة اللبنانية تثبت انطباق أحكام قانون مقاطعة العدو الاسرائيلي على العارض على أن لا يعود تاريخ تصديقها لأكثر من ثلاثة أشهر من تاريخ جلسة التلزم.
  - المستندات المطلوبة أعلاه.
- 13- إفادة صادرة عن المحكمة المختصة (السجل التجاري) تثبت ان العارض ليس في حالة إفلاس.
- 14- إفادة صادرة عن المحكمة المختصة (السجل التجاري) تثبت ان العارض ليس في حالة تصفية.
- 15- مستند يحدد فيه العارض مكاناً لإقامته (عنوان واضح- بريد إلكتروني- رقم هاتف-...) للتواصل معه وذلك بغية إستلام التبليغات كافة.
- 16- كتاب تعهد، مطابقاً للنموذج المرفق بدفتر الشروط الخاص الحاضر (ملحق رقم ٢) موقعاً وفقاً للأصول وملصقاً عليه رسم الطابع المالي المتوجب.
- 17- كتاب ضمان مصرفي، مطابقاً للنموذج المرفق بدفتر الشروط الخاص الحاضر (ملحق رقم ٤) مختوماً وموقعاً وفقاً للأصول.
- 18- دفتر الشروط الخاص الحاضر مختوماً وموقعاً وفقاً للأصول.
- 19- الطرف المختوم المتضمن لوائح الأسعار مختومة وموقعة وفقاً للأصول (اللوائح الأصلية المسلمة إلى العارض) (ملحق رقم ٥).
- 20- لائحة الشروط التقنية والفنية (ملحق رقم ١) مختومة وموقعة وفقاً للأصول مع جدول الكميات و المستندات كافة المفصلة في الملحق المذكور.
- 21- لائحة بـ ١٠ زبائن للعارض على الأقل لمشاريع مماثلة من حيث الحجم والنوع أنجزها ما بين العام ٢٠١٥ لغاية تاريخه مع العنوان الكامل والأرقام الهاتفية والبريد الإلكتروني لهؤلاء الزبائن.
- 22- سجل عدلي للمفوض بالتوقيع لا يعود تاريخه لأكثر من ثلاثة أشهر من تاريخ انعقاد الاجتماع.

### الوثائق والمستندات الاختيارية:

- 1- شهادة إنتساب صادرة عن غرفة التجارة والصناعة والزراعة تثبت أن العارض يتعاطى تجارة أو صناعة المواد موضوع التلزم، صالحة بتاريخ جلسة التلزم وصالحة للإشتراك في المناقصات العمومية/عروض أسعار.
- 2- شهادة الجودة الخاصة بالعارض (ISO).
- 3- أي مستند فني إضافي (....- Brochure- Catalogue).

إن جميع المستندات والوثائق المقدمة في العرض يجب ان تكون مصدقة وفقاً للأصول ومرقمة وفقاً للترتيب الوارد في الـ Check list المرفقة ربطاً ويكون كل عارض مسؤولاً عن صحة المعلومات المقدمة من قبله. إن عدم التقيد حرفياً بمضمون وشروط المستندات المذكورة أعلاه و/أو عدم ملاءمة العرض المقدم للمواصفات الفنية المطلوبة لا سيما عدم التقيد باللوائح المعدة من قبل المصرف، يؤدي إلى عدم فتح الطرف المختوم المتضمن لوائح الأسعار، وبالتالي استبعاد العرض كلياً.

### ثانياً: الغلاف رقم (٢) بيان الأسعار

يُقدم العارض بياناً بالأسعار موقع ومختوم من قبله ضمن ظرف مقفل يُدَوّن عليه موضوع التلزم وإسم العارض وفقاً للملحق رقم (5) ويتضمن الأكلاف لكل من اليد العاملة السنوية وقطع الغيار للأعطال المستجدة على حدة، تدون الأسعار بالأرقام والحروف الكاملة دون حك أو شطب أو زيادة لكلمات غير مصدق عليها، علماً أنه في حال اختلاف قيمة الأرقام عما هو مدون بالأحرف، يعتمد السعر الأدنى.

تشمل الأسعار جميع المصاريف والرسوم والضرائب، بما فيها الضريبة على القيمة المضافة في حال توجبها، والأجور والأتعاب ومصاريف النقل والأعباء مهما كانت التي تستحق قبل وخلال مدة تنفيذ الإلتزام.

على العارض أن يقدم سعره مفصلاً مع السعر الإجمالي للتلزم بما فيه الضريبة على القيمة المضافة.

على العارض أن يلتزم بالأسعار التي قدمها في عرضه دون أن يكون له حق التغيير أو المراجعة طيلة مدة التعاقد معه في حال تم إختياره لتنفيذ الإلتزام.

III- يقتضي على العارض أن يدون على كل غلاف محتوياته وموضوع التلزم وتاريخ جلسة التلزم وإسم العارض على أن يوضع الغلافين المذكورين أعلاه ضمن غلاف واحد يدون عليه موضوع التلزم وتاريخ جلسة التلزم فقط دون أية عبارة فارقة أو إشارة مميزة كإسم العارض أو صفته أو عنوانه، وذلك تحت طائلة رفض العرض.

### المادة 5: العروض المشتركة (المادة ٢٣ من قانون الشراء العام)

لا يجوز أن يشترك في تنفيذ المشروع هذا عدة موردين أو مقدّمي خدمات أو مقاولين بموجب عقد شراكة أو اتفاقية مشتركة (joint venture).

### المادة 6: طلبات الاستيضاح (المادة ٢١ من قانون الشراء العام)

يحقّ للعارض تقديم طلب استيضاح خطّي حول دفتر الشروط خلال مهلةٍ تنتهي قبل عشرة أيام من تاريخ تقديم العروض وذلك عبر البريد الإلكتروني على العناوين التالية: [purchasingunit@bdl.gov.lb](mailto:purchasingunit@bdl.gov.lb)، على مصرف لبنان الإجابة خلال مهلةٍ تنتهي قبل ستة أيام من الموعد النهائي لتقديم العروض. ويُرسَل الإيضاح خطياً، في الوقت عينه، من دون تحديد هويّة مُصدِر الطلب، إلى جميع العارضين الذين زوّدهم مصرف لبنان بملفات التلزم، وتطبق أحكام المادة ٢١ من قانون الشراء العام في حال ارتأى مصرف لبنان إجراء تعديلات على دفتر الشروط لأي سبب كان أو بمبادرة منه أم نتيجة لطلب استيضاح مقدم من احد العارضين، وفي كل ما يتعلق بعقد الاجتماعات مع العارضين، كما يُمكن لمصرف لبنان، عند الاقتضاء، تحديد موعد معين للعارضين المحتملين لمعاينة الموقع، مع العلم أنه يتوجب على العارض القيام بزيارة ميدانية على كافة مواقع الأعمال في المركز الرئيسي وفروعه كافة للتأكد من تغطية كافة الشروط المطلوبة بهدف دقة التسعير.

### المادة 7: مدة صلاحية العرض (المادة ٢٢ من قانون الشراء العام)

1. يُحدد دفتر الشروط الحاضر مدة صلاحية العرض بـ ٩٠ يوم من التاريخ النهائي لتقديم العروض.
2. يمكن لمصرف لبنان أن يطلب من العارضين، قبل انقضاء فترة صلاحية عروضهم، أن يمددوا تلك الفترة لمدة إضافية محدّدة. ويُمكن للعارض رفض ذلك الطلب من دون مصادرة ضمان عرضه.
3. على العارضين الذين يوافقون على تمديد فترة صلاحية عروضهم أن يمددوا فترة صلاحية ضمانات العروض، أو أن يُقدّموا ضمانات عروض جديدة تُغطّي فترة تمديد صلاحية العروض. ويُعتبَر العارض الذي لم يُمدّد ضمان عرضه، أو الذي لم يُقدّم ضمان عرض جديد، أنه قد رَفُض طلب تمديد فترة صلاحية عرضه.
4. يمكن للعارض أن يعدّل عرضه أو أن يسحبه قبل الموعد النهائي لتقديم العروض دون مصادرة ضمان عرضه. ويكون التعديل أو طلب سحب العرض ساري المفعول عندما تتسلّمه الجهة الشارعية قبل الموعد النهائي لتقديم العروض.



5. تمدد صلاحية العرض حكماً في حال تجميد الإجراءات لفترة محددة من قبل هيئة الاعتراضات وفق أحكام الفصل السابع من قانون الشراء العام، وذلك لفترة زمنية تعادل فترة تجميد الإجراءات. وعلى العارض تمديد فترة ضمان عرضه تبعاً لذلك.

#### المادة 8: ضمان العرض (المادة ٣٤ من قانون الشراء العام)

1. يُحدد ضمان العرض لهذا التلزم بمبلغ //٤,٠٠٠// دولار أميركي (أربعة الاف دولار أميركي) بحسب النموذج المرفق في الملحق رقم ٤.
2. تُحدّد مدة صلاحية ضمان العرض بـ ١١٨ يوم من تاريخ جلسة التلزم.
3. يجدد مفعول ضمان العرض تلقائياً إلى أن يقرر إعادته إلى العارض.
4. يُعاد ضمان العرض إلى الملتزم عند تقديمه ضمان حسن التنفيذ، وإلى العارضين الذين لم يرس عليهم التلزم في مهلة أقصاها بدء نفاذ العقد.

#### المادة 9: ضمان حسن التنفيذ (المادة ٣٥ من قانون الشراء العام)

1. تحدد قيمة ضمان حسن التنفيذ بنسبة لا تزيد عن ١٠% من قيمة العقد.
2. يجب تقديم ضمان حسن التنفيذ خلال فترة لا تتجاوز //١٥// خمسة عشر يوماً من تاريخ توقيع العقد. وفي حال التخلف عن تقديم ضمان حسن التنفيذ، يُصادر ضمان العرض.
3. يبقى ضمان حسن التنفيذ مجمداً طوال مدة التلزم، ويُحسم منه مباشرةً وبدون سابق إنذار وعند أول طلب ما قد يترتب من غرامات أو مخالفات أو عطل أو ضرر يحدثه الملتزم إلى حين إيفائه بكامل الموجبات.
4. يعاد ضمان حسن التنفيذ إلى الملتزم بعد انتهاء مدة التلزم وتمام الإستلام النهائي الذي يجري بعد تأكد لجنة الإستلام من أن التلزم جرى وفقاً للأصول.

#### المادة 10: طريقة دفع الضمانات (المادة ٣٦ من قانون الشراء العام)

يقدم ضمان العرض كما ضمان حسن التنفيذ بموجب كتاب ضمان مصرفي غير قابل للرجوع عنه، صادر عن مصرف مقبول من مصرف لبنان يُبين أنه قابل للدفع عند أول طلب، ويقدم ضمان العرض بإسم الإلتزام لصالح مصرف لبنان.

#### المادة 11: تقديم العروض

1. ترسل العروض بواسطة البريد أو باليد مباشرة إلى مصرف لبنان- وحدة المشتريات.
2. يُحدد الموعد النهائي لتقديم العروض وفق ما ينص عليه الإعلان المتعلق بهذا التلزم، والمنشور على المنصة الالكترونية المركزية لهيئة الشراء العام. (يكون موعد جلسة التلزم فوراً عند انتهاء مهلة استقبال العروض).
3. يزود مصرف لبنان العارض بإيصال يُبين فيه رقم تسلسليّ بالإضافة إلى تاريخ تسلّم العرض بالساعة واليوم والشهر والسنة.
4. يحافظ مصرف لبنان على أمن العرض وسلامته وسريته، وتكفل عدم الاطلاع على محتوياته إلا بعد فتحه وفقاً للأصول.
5. لا يُفتح أيّ عرض يتسلّمه مصرف لبنان بعد الموعد النهائي لتقديم العروض، بل يُعاد مختوماً إلى العارض الذي قدّمه.
6. لا يحقّ للعارض أن يقدم أكثر من عرض واحد تحت طائلة رفض كل عروضه.



## المادة 12: فتح وتقييم العروض

1. تفتح العروض لجنة التلزم المنصوص عنها في المادة ١٠٠ من قانون الشراء العام في مديرية الشؤون القانونية في الطابق الخامس من البلوك "أ" من مصرف لبنان الرئيسي. تتولى هذه اللجنة حصراً دراسة ملف التلزم وفتح وتقييم العروض وبالتالي تحديد العرض الأنسب، وذلك في جلسة علنية تعقد فور انتهاء مهلة تقديم العروض.
2. على رئيس اللجنة وعلى كل من أعضائها أن يتتخى عن مهامه في اللجنة المذكورة في حال تبين وجود تضارب مصالح مع المشاركين في إجراءات الشراء، وذلك فور معرفته بذلك.
3. يمكن للجنة التلزم الاستعانة بخبراء من خارج أو داخل مصرف لبنان للمساعدة على التقييم الفني والمالي عند الإقتضاء، وذلك بقرار من المرجع الصالح لدى مصرف لبنان. يخضع اختيار الخبراء من خارج مصرف لبنان إلى أحكام قانون الشراء العام.
4. يلتزم الخبراء بالسرية والحياد في عملهم ولا يحق لهم أن يقرروا بإسم اللجنة أو أن يشاركوا في مداولاتها أو أن يفصحوا عنها، ويمكن دعوتهم للاستماع والشرح من قبل الجهات المعنية. كما يتوجب على الخبراء تقديم تقرير خطي للجنة يُضمّ إلزامياً إلى محضر التلزم.
5. في حال التباين في الآراء بين أعضاء اللجنة، تؤخذ القرارات بأغلبية أعضائها ويُدون أي عضو مخالف أسباب مخالفته.
6. يحق لجميع العارضين المشاركين في عملية التلزم أو لممثليهم المفوضين وفقاً للأصول حضور جلسة فض العروض.
7. تُفتح العروض في جلسة علنية بحضور العارضين الراغبين في التاريخ المحدد لفض العروض بحسب الآلية التالية:  
ب- يتم فض الغلاف الخارجي الموحد لكل عارض على حدة وإعلان اسمه ضمن المشاركين في التلزم،  
ت- يتم فض العروض على مرحلتين:  
المرحلة الأولى:  
يتم فض الغلاف رقم (١) (الوثائق والمستندات الإدارية والتقنية المنصوص عنها في المادة ٤-٢ اعلاه) وفرز المستندات المطلوبة والتدقيق فيها تمهيداً لتحديد وإعلان أسماء العارضين المقبولين شكلاً والمؤهلين للاشتراك في بيان مقارنة الأسعار.  
تحفظ الظروف المختومة المتضمنة لوائح الأسعار والكشف بالكميات بانتظار أن تفتح في المرحلة الثانية.  
يقوم المصرف بدراسة باقي المستندات وتُسبغ العروض غير المستوفية للشروط المطلوبة كافة.  
المرحلة الثانية:  
عند الانتهاء من دراسة المستندات، يجري فض الغلاف رقم (٢) (بيان الأسعار) للعارضين المقبولين شكلاً كل على حدة وإجراء العمليات الحسابية اللازمة، وتدوين السعر الإجمالي لكل عارض بما فيه الضريبة على القيمة المضافة في حال كان العارض خاضعاً لها، تمهيداً لإجراء مقارنة وإعلان اسم الملتزم المؤقت.  
تُصحح لجنة التلزم أي أخطاء حسابية محضة تكتشفها أثناء فحصها العروض المقدّمة وفقاً لأحكام دفتر الشروط، وتبلغ التصحيحات إلى العارض المعني بشكل فوري إذا كان حاضراً.  
يحق للمصرف إجراء المرحلتين المذكورتين أعلاه في يوم واحد كلما دعت الحاجة.
8. يمكن للجنة التلزم، في أي مرحلة من مراحل إجراءات التلزم، أن تطلب خطياً من العارض إيضاحات بشأن المعلومات المتعلقة بمؤهلاته أو بشأن عروضه، لمساعدتها في التأكد من المؤهلات أو فحص العروض المقدّمة وتقييمها.
9. تُسجل وقائع فتح العروض خطياً في محضر يوقع عليه رئيس وأعضاء لجنة التلزم، كما توضع لائحة بالحضور يوقع عليها المشاركون من ممثلي مصرف لبنان وهيئة الشراء العام والعارضين وممثليهم على أن يشكّل ذلك إثباتاً على حضورهم. تُدرج كل المعلومات والوثائق المتعلقة بوقائع الجلسة في سجل إجراءات الشراء المنصوص عليه في المادة ٩ من قانون الشراء العام.

10. لا يمكن طلب إجراء أو السماح بإجراء أيّ تغيير جوهري في المعلومات المتعلقة بالمؤهلات أو بالعرض المقدّم، بما في ذلك التغييرات الرامية إلى جعل من ليس مؤهلاً من العارضين مؤهلاً أو جعل عرض غير مستوفٍ للمتطلبات مستوفياً لها.
11. لا يمكن إجراء أيّ مفاوضات بين مصرف لبنان أو لجنة التلزم والعارض بخصوص المعلومات المتعلقة بالمؤهلات أو بخصوص العروض المقدّمة، ولا يجوز إجراء أيّ تغيير في السعر إثر طلب استيضاح من أي عارض.
12. تُدرج جميع المراسلات التي تجري بموجب هذه المادة في سجل إجراءات الشراء بحسب المادة ٩ من قانون الشراء العام.
13. في حال كانت المعلومات أو المستندات المقدّمة في العرض ناقصة أو خاطئة أو في حال غياب أي مستندات معيّنة، يجوز للجنة التلزم الطلب خطياً من العارض المعني توضيحات حول عرضه، أو طلب تقديم أو استكمال المعلومات أو الوثائق ذات الصلة خلال فترة زمنية محدّدة، شرط أن تكون كافة المراسلات خطية واحترام مبادئ الشفافية والمساواة في المعاملة بين العارضين في طلبات التوضيح أو الاستكمال الخطية، وذلك مع مراعاة أحكام الفقرة ٣ من البند الثاني من المادة ٢١ من قانون الشراء العام.
14. تطبق احكام المادة ٥٥ من قانون الشراء العام على كيفية تقييم العروض.

#### المادة 13: استبعاد العارض

تستبعد الجهة الشارعية العارض من إجراءات التلزم بسبب عرضه منافع أو من جرّاء ميزة تنافسية غير منصفة أو بسبب تضارب المصالح وذلك في احدي الحالتين المنصوص عنهما في المادة الثامنة من قانون الشراء العام.

#### المادة 14: حظر المفاوضات مع العارضين (المادة ٥٦ من قانون الشراء العام)

تُحظر المفاوضات بين مصرف لبنان أو لجنة التلزم وأي من العارضين بشأن العرض الذي قدّمه ذلك العارض.

#### المادة 15: الأنظمة التفضيلية (المادة ١٦ من قانون الشراء العام)

خلافاً لأي نص آخر، يمكن إعطاء العروض المتضمنة سلعاً أو خدمات ذات منشأ وطني أفضلية بنسبة //١٠// عشرة بالمئة عن العروض المقدّمة لسلع أو خدمات أجنبية. تُعطى الأفضلية لمكوّنات العرض ذات المنشأ الوطني.

#### المادة 16: إلغاء الشراء و/أو أي من إجراءاته:

يمكن لمصرف لبنان أن يلغي الشراء و/ أو أي من إجراءاته في أي وقت قبل إبلاغ الملتزم المؤقت إبرام العقد، في الحالات التي نصّت عليها المادة ٢٥ من قانون الشراء العام.

## القسم الثاني أحكام خاصة بالعقد وتنفيذ الإلتزام

### المادة 17: قواعد قبول العرض الفائق (أو التلزم المؤقت) وبدء تنفيذ العقد:

1. يقوم مصرف لبنان بقبول العرض المقدم الفائز ما لم:
  - أ- تُسقط أهلية العارض الذي قدم العرض الفائز وذلك بمقتضى المادة ٧ من قانون الشراء العام؛ أو
  - ب- يُلغ الشراء بمقتضى الفقرة ١ من المادة ٢٥ من قانون الشراء العام؛ أو
  - ج- يُرفض العرض الفائز عند اعتبار سعره منخفضاً انخفاضاً غير عادي بمقتضى المادة ٢٧ من قانون الشراء العام؛ أو
  - د- يُستبعد العارض الذي قدم العرض الفائز من إجراءات التلزم للأسباب المبينة في المادة ٨ من قانون الشراء العام.
2. بعد التأكد من العرض الفائز يبلغ مصرف لبنان العارض الذي قدم ذلك العرض، كما ينشر بالتزام قراره بشأن قبول العرض الفائز (التلزم المؤقت) والذي يدخل حيّز التنفيذ عند انتهاء فترة التجميد البالغة عشرة أيام عمل تبدأ من تاريخ النشر، الذي يجب أن يتضمّن على الأقل، المعلومات التالية:
  - أ- إسم وعنوان العارض الذي قدم العرض الفائز (الملتزم المؤقت)؛
  - ب- قيمة العرض، ويمكن إضافة ملخص لسائر خصائص العرض الفائز ومزاياه النسبية إذا كان العرض الفائز قد تمّ تأكيده على أساس السعر ومعايير أخرى؛
  - ج- مدة فترة التجميد بحسب هذه الفقرة.
3. فور انقضاء فترة التجميد، يقوم مصرف لبنان بإبلاغ الملتزم المؤقت بوجوب توقيع العقد خلال مهلة لا تتعدّى //١٥// خمسة عشر يوماً.
4. يوقع المرجع الصالح لدى مصرف لبنان العقد خلال مهلة //١٥// خمسة عشر يوماً من تاريخ توقيع العقد من قبل الملتزم المؤقت. يمكن أن تُمدد هذه المهلة إلى //٣٠// ثلاثين يوماً في حالات معينة تحدّد من قبل مصرف لبنان.
5. يبدأ نفاذ العقد عندما يوقع الملتزم المؤقت والمرجع الصالح لدى مصرف لبنان عليه.
6. لا يتخذ مصرف لبنان ولا الملتزم المؤقت أيّ إجراء يتعارض مع بدء نفاذ العقد أو مع تنفيذ الشراء خلال الفترة الزمنية الواقعة ما بين تبليغ العارض المعني بالتلزم المؤقت وتاريخ بدء نفاذ العقد.
7. في حال تمنّع الملتزم المؤقت عن توقيع العقد، يصادر مصرف لبنان ضمان عرضه. في هذه الحالة يمكن لمصرف لبنان أن يلغي الشراء أو أن يختار العرض الأفضل من بين العروض الأخرى الفائزة وفقاً للمعايير والاجراءات المحددة في قانون الشراء العام وفي ملفات التلزم، والتي لا تزال صلاحيتها سارية المفعول. تُطبّق أحكام هذه المادة على هذا العرض بعد إجراء التعديلات اللازمة.

### المادة 18: قواعد بشأن العروض المنخفضة الأسعار انخفاضاً غير عادياً (المادة ٢٧ من قانون الشراء العام)

يجوز لمصرف لبنان أن يرفض أيّ عرض إذا اعتبر أنّ السعر، مُقترناً بسائر العناصر المكوّنة لذلك العرض المقدم، مُنخفض انخفاضاً غير عاديّ قياساً إلى موضوع الشراء وقيّمته التقديرية وتُطبّق أحكام المادة ٢٧ من قانون الشراء العام في هذا الشأن.

### المادة 19: مدة التنفيذ

إن مدة العقد تبدأ اعتباراً من ٢٠٢٤/٠١/٠١ ولغاية نهاية ٢٠٢٥/١٢/٣١ من ضمنها أيام الأحاد والأعياد الرسمية.

## المادة 20: قيمة العقد وشروط تعديلها (المادة ٢٩ من قانون الشراء العام)

1. تكون البدلات المتفق عليها في العقد ثابتة ولا تقبل التعديل والمراجعة إلا عند إجازة ذلك أثناء تنفيذه ضمن ضوابط محدّدة وفقاً لشروط التعديل والمراجعة في الحالات الاستثنائية التالية:
  - أ- تطبيقاً لتعديلات ضريبية تؤدي إلى زيادة تكلفة تنفيذ العقد؛
  - ب- في الحالة المنصوص عليها في الفقرة ٣ من المادة ٤٦ من قانون الشراء العام؛
  - ج- عندما تصدر قوانين أو مراسيم من شأنها التأثير على قيمة العقد، وعلى أن يُعلّل ذلك بموجب تقرير من الجهة الشارية.
2. تُراعى شروط الإعلان المنصوص عليها في المادة ٢٦ من قانون الشراء العام عند تعديل قيمة العقد.

## المادة 21: تنفيذ العقد والاستلام (المادة ٣٢ من قانون الشراء العام)

- يحدد المصرف بموجب كتاب موجه إلى الملتزم لتقديم خدمة الصيانة / قطع الغيار بواسطة البريد الإلكتروني أو الفاكس أو باليد مع إشعار بالاستلام، على أن يتم الحضور إلى مصرف لبنان خلال ٤ ساعات من طلبنا مباشرة للقيام بالزيارة الميدانية لزوم الكشف والصيانة إضافة إلى المضي بالتصليح خلال مهلة أقصاها ٢٤ ساعة بما فيها فترات الأعياد الرسمية وأيام الأحاد من تاريخ تبليغ الملتزم بالعتل.
1. يجب تأمين القطع المطلوبة على مدى سبعة أيام في الأسبوع وذلك ٢٤/٢٤ ساعة حتى خلال فترات الأعياد الرسمية وأيام الأحاد.
  2. يسلم الملتزم خدمة الصيانة / قطع الغيار في مركز المصرف الرئيسي أو في أي من فروع، حسب الحالة، وفقاً للشروط والمواصفات كافة المتفق عليها.
  3. يتم الاستلام المؤقت بعد:
    - استلام المصرف لخدمة الصيانة / قطع الغيار البديلة حسب الكتاب المشار إليه في الفقرة أعلاه وبعد التأكد من مطابقتها لما جاء في لائحة الشروط التقنية والفنية.
    - استلام الفواتير المعدة وفقاً للأصول مختومة بشكل أوتوماتيكي من خلال العداد وملصق عليها الطابع المالي أو أية مستندات أخرى يقضي التعامل بتسليمها إلى المصرف وموافقة المصرف الخطية على هذه الفواتير.

## المادة 22: استلام الأشغال/اللوازم/الخدمات (المادة ١٠١ من قانون الشراء العام)

1. يجري الاستلام على مراحل لكل من، خدمة الصيانة / قطع الغيار، وفقاً لما هو مفصل في المواصفات الفنية والتقنية.
2. إنّ مدة العقد تبدأ اعتباراً من تاريخ إعطاء الأمر من قبل المصرف للملتزم بمباشرة الالتزام من ٢٠٢٤/٠١/٠١ ولغاية ٢٠٢٥/١٢/٣١ من ضمنها أيام الأحاد والأعياد الرسمية.
3. يجري الاستلام وفقاً لأحكام المادة ١٠١ من قانون الشراء العام.
4. يتعهد الملتزم، في معرض تنفيذه الالتزام تسليم خدمة الصيانة / قطع الغيار وفقاً لما يلي:
  - تسليم خدمة الصيانة / قطع الغيار، نخب أول خالي من الشوائب وذات مواصفات عالية الجودة وفقاً للمواصفات المطلوبة.
  - عدم تسليم خدمة الصيانة / قطع الغيار غير مطابقة للمواصفات المتفق عليها حتى في حال عدم توفر المطلوب أو لأي سبب آخر.
  - تقديم، فور توقيع العقد، تقريراً مفصلاً عن ما يلي:
    1. آلية تطبيق خدمة أعمال الصيانة (Method of Statement including check lists)
    2. ضمان عدم وجود أي عيب أو خلل في خدمة الصيانة / قطع الغيار ومعالجتها وفقاً للأصول عند مطالبة المصرف خطياً بذلك فوراً وعلى كامل مسؤولية ونفقة الملتزم.

3. يحتفظ المصرف بحقه في مطالبة الملتزم بالتعويض عن العطل والضرر الناتجين عن أي إخلال بأحد الموجبات المذكورة أعلاه بالإضافة إلى مصادرة كتاب ضمان حسن التنفيذ المشار إليه في دفتر الشروط الحاضر.

#### المادة 23: التعاقد الثانوي (المادة ٣٠ من قانون الشراء العام)

يجب على الملتزم الأساسي أن يتولى بنفسه تنفيذ العقد ويبقى مسؤولاً تجاه مصرف لبنان عن تنفيذ جميع بنوده وشروطه، ويُمنع عليه تلزيم كامل موجباته التعاقدية لغيره.

#### المادة 24: الإشراف على التنفيذ والكشوفات (تطبق أحكام المادة ٣١ من قانون الشراء العام) أولاً: الإشراف:

1. في عقود الأشغال، وفي العقود الأخرى التي تستدعي ذلك كعقود الخدمات والتصنيع لمصلحة مصرف لبنان، يُطبَّق الإشراف المُتلازم مع تنفيذ الأعمال المطلوبة بالشكل الذي يضمن استمرارية العمل وتحقيقه المواصفات المطلوبة والنتائج المرجوة قبل حلول موعد الاستلام المؤقت.
2. يتولى الإشراف مَنْ يكلفه مصرف لبنان بذلك من ذوي الاختصاص والخبرة والقدرة على متابعة العمل، من داخل مصرف لبنان، أو خارجه عند الاقتضاء، وعندها يجري التعاقد مع المُشرف وفق أحكام قانون الشراء العام.
3. تُوضع بنتيجة الإشراف تقارير دورية عن سير العمل ووصف التنفيذ، وعلى المُشرف إبلاغ مصرف لبنان بكل مخالفة أو تصرف غير مُنطبق على الأصول ينفَّذ في مواقع العمل.
4. يحضر المُشرف إلى مواقع العمل بصورة تؤمّن صحة واستمرارية العمل، كما يدقّق في الكشوفات ويحضر عملية تسليم مواقع العمل والاستلام المؤقت والنهائي، ويؤدي رأيه باقتراحات الملتزم وبالتعديلات المطلوبة على الأعمال الملزمة، ويقترح الملائم لتنفيذ العمل بطريقة أنسب، ويرفع تقريراً بذلك إلى مصرف لبنان ليتخذ القرار المناسب.
5. يتحمّل من يتولى الإشراف على الأعمال مسؤولية شخصية عن أيّ تقصير في الموجبات الملقة على عاتقه بموجب هذه المادة ويَعرض للعقوبات المنصوص عليها في الفصل الثامن من قانون الشراء العام.

#### ثانياً: الكشوفات

يقدم الملتزم كشوفات السلع أو الخدمات أو الأعمال المنفّذة على اختلافها إلى مصرف لبنان للإطلاع والموافقة عليها.

#### المادة 25: الحوادث والمسؤوليات

- يتحمل الملتزم المسؤولية الكاملة عن كافة المخاطر والحوادث التي قد تصيب الغير والعاملين تحت إمرته طيلة فترة تنفيذ الأعمال، كما يعتبر مسؤولاً عن كافة الأضرار التي تلحق بتجهيزات المصرف من جراء وأثناء تنفيذ الأعمال وعليه إتخاذ كافة التدابير لمنع حدوثها.
- على الملتزم تصليح كل عطل وضرر يلحق بتجهيزات المصرف ينتج عن الأعمال التي يقوم بها.
- وفي حال المخالفة يقوم مصرف لبنان بإتخاذ الإجراءات اللازمة على نفقة ومسؤولية الملتزم.

#### المادة 26: دفع قيمة العقد (المادة ٣٧ من قانون الشراء العام)

أ- تحدد كلفة خدمة الصيانة / قطع الغيار بالدولار الأميركي.  
يشمل "البذل" المصاريف والرسوم والضرائب كافة المرتبطة بتنفيذ العقد بما فيها قيمة الضريبة على القيمة المضافة ونفقات النقل والأجور والأتعاب والأعباء مهما كانت التي تستحق قبل وخلال مدة العقد،

ولا يحق للملتزم أن يطالب بأي زيادة على "البديل" لأي سبب كان مهما كان نوعه أو مصدره ولأية جهة كانت.  
ب- يسدد مصرف لبنان المستحقات المستعرة بالدولار الأميركي نقداً بالليرة اللبنانية على أساس سعر منصة صيرفة مضافاً إليها، إن وجب ذلك، هامشاً (هامش نسبي %) تراعى فيه، في حينه، الفروقات المتعددة لتسعير الليرة اللبنانية مقابل الدولار الأميركي في حال توفرها. يتم تحديد الهامش من قبل مصرف لبنان بتاريخ تسديد كل دفعة لإحتساب قيمتها النهائية، وفقاً لما يلي:

- تسدد خدمة الصيانة (أكلاف اليد العاملة) كل ستة أشهر

- تسدد كلفة قطع الغيار بعد إستلامها وتركيبها وتشغيلها وفقاً للأصول وبعد تسليم الكشوفات التابعة لها.

ج- يلتزم الملتزم في مهلة أقصاها خمسة أيام عمل تبدأ اعتباراً من تاريخ توقيع العقد، بتقديم لمصرف لبنان، كتاب ضمان مصرفي وفقاً للنموذج المرفق ربطاً (ملحق رقم ٤-) يضمن حسن قيامه بتنفيذ موجباته موضوع العقد بمبلغ قدره ١٠% من قيمة البديل (كتاب ضمان حسن التنفيذ). يعاد كتاب ضمان حسن التنفيذ الى الملتزم بعد مرور ثلاثة أشهر على انتهاء مدة العقد وبعد موافقة مصرف لبنان النهائية والخطية على حسن التنفيذ (الإستلام النهائي).

د- يمكن لمصرف لبنان اجراء المقاصة حكماً بين أي مبلغ يترتب للملتزم وبين أي مبلغ يترتب على مصرف لبنان لاسيما قيمة الغرامة الاكراهية التي قد تتوجب على الملتزم وفقاً لأحكام المادة ٢٨ أدناه.

#### المادة 27: دفع الطابع والرسوم

ان كافة الطابع والرسوم التي تتوجب وفقاً للأنظمة والقوانين المرعية الإجراء الناتجة عن هذا الإلتزام هي على عاتق الملتزم بما فيها قيمة الضريبة على القيمة المضافة.

ويُسَدَّد رسم الطابع المالي البالغ ٤/ بالآلاف خلال خمسة أيام عمل من تاريخ ابلاغ الملتزم تصديق العقد.

#### المادة 28: الغرامات (المادة ٣٨ من قانون الشراء العام)

يتوجب على الملتزم التقيد بالمهل المحددة في العقد تحت طائلة دفع الغرامات المحددة فيه.

تُفرض الغرامات بشكلٍ حكمي على الملتزم بمجرّد مخالفته أحكام العقد دون حاجة لإثبات الضرر.

وتحتسب غرامة تأخير نقدية قدرها (١%) من قيمة العقد عن كل يوم تأخير في انجاز الأعمال المطلوبة، ويُعتبر كسر اليوم يوماً كاملاً، على أن لا تزيد هذه الغرامات عن (١٠%) من قيمة العقد. وإذا تجاوزت غرامات التأخير نسبة الـ (١٠%) من قيمة العقد، يحق للجهة الشارعية فسخ العقد واعتبار الملتزم ناكلاً، وتطبق بحقه أحكام المادة ٣٣ من قانون الشراء العام. وفي جميع الأحوال يُصادر كتاب ضمان حسن التنفيذ مؤقتاً الى حين تصفية التلزم.

#### المادة 29: أسباب انتهاء العقد ونتائجه (المادة ٣٣ من قانون الشراء العام)

##### أولاً: النكول

إذا خالف الملتزم شروط تنفيذ العقد أو أحكام دفتر الشروط الحاضر، يعود لمصرف لبنان إنذاره رسمياً بوجوب التقيد بكافة موجباته ضمن مهلة تتراوح بين خمسة أيام كحدٍ أدنى وخمسة عشر يوماً كحدٍ أقصى. في حال لم يَقم الملتزم بموجباته ضمن هذه المهلة، يُعتبر ناكلاً ويُفسخ العقد حكماً دون الحاجة إلى أيّ إنذار وتطبق الإجراءات المنصوص عليها في الفقرة (١) من البند رابعاً من المادة ٣٣ من قانون الشراء العام.

##### ثانياً: الإنهاء

1- ينتهي العقد حكماً دون الحاجة إلى أيّ إنذار في الحالتين التاليتين:

أ- عند وفاة الملتزم إذا كان شخصاً طبيعياً، إلا إذا وافق مصرف لبنان على طلب مواصلة التنفيذ من قبل الورثة.

- ب- إذا أصبح المُلتزم مُفلساً أو مُعسراً أو حُلَّت الشركة، وتُطبَّق عندئذ الإجراءات المنصوص عليها في الفقرة (٢) من البند رابعاً من المادة ٣٣ من قانون الشراء العام.
- 2- يجوز لمصرف لبنان إنهاء العقد إذا تعذّر على المُلتزم القيام بأيّ من التزاماته التعاقدية بنتيجة القوة القاهرة.

### ثالثاً: الفسخ

- 1- يُفسخ العقد حكماً دون الحاجة إلى أيّ إنذار في أيّ من الحالات التالية:
- أ- إذا صدرَ بحقّ المُلتزم حكمٌ نهائيّ بارتكاب أيّ جرم من جرائم الفساد أو التواطؤ أو الإحتيال أو الغش أو تبييض الأموال أو تمويل الإرهاب أو تضارب المصالح أو التزوير أو الإفلاس الإحتيالي، وفقاً للقوانين المرعية الاجراء؛
- ب- إذا تحقّقت أيّ حالة من الحالات المذكورة في المادة ٨ من قانون الشراء العام.
- ج- في حال فقدان أهلية المُلتزم.
- 2- إذا فُسخ العقد لأحد الأسباب المذكورة في الفقرة (١) من هذا البند تُطبَّق الإجراءات المنصوص عليها في الفقرة (١) من البند رابعاً من هذه المادة.

### رابعاً: نتائج انتهاء العقد:

- 1- في حال حصول إحدى حالات النكول أو الفسخ المحدّدة أعلاه أو سواها من الحالات المحددة في المادة ٣٣ من قانون الشراء العام، تُتبع فوراً، خلافاً لأيّ نص آخر أحكام البند رابعاً من المادة ٣٣ من قانون الشراء العام.
- 2- لا يترتّب أيّ تعويض عن الخدمات المُقدّمة أو الأشغال المنفّذة من قبل من يثبت قيامه بأيّ من الجرائم المنصوص عليها في الفقرة (١- أ) من البند ثالثاً من المادة ٣٣ من قانون الشراء العام.
- 3- يُنشر قرار انتهاء العقد وأسبابه على المنصة الإلكترونية المركزيّة لدى هيئة الشراء العام.

### **المادة 30: الإقتطاع من الضمان (المادة ٣٩ من قانون الشراء العام)**

إذا ترتّب على المُلتزم في سياق التنفيذ مبلغ ما، تطبيقاً لأحكام وشروط العقد، حقّ لمصرف لبنان اقتطاع هذا المبلغ من ضمان حسن التنفيذ ودعوة المُلتزم إلى إكمال المبلغ ضمن مدّة معيّنة، فإذا لم يفعل اعتُبر ناكلاً وفقاً لأحكام البند أولاً من المادة ٣٣ من قانون الشراء العام.

### **المادة 31: الإقصاء (المادة ٤٠ من قانون الشراء العام)**

تطبق أحكام الإقصاء على المُلتزم الذي يعتبر ناكلاً أو الذي يصدر بحقه حكم قضائي وفقاً لما نصت عليه المادة ٤٠ من قانون الشراء العام.

### **المادة 32: القوّة القاهرة**

إذا حالت ظروف استثنائية وخارجة عن ارادة المُلتزم دون التسليم في المدة المُحددة، يتوجب على المُلتزم ابلاغ مصرف لبنان فوراً وخطياً عند حصول أي تخلف أو تأخير في التنفيذ وعن أسبابه وعن مدته المتوقعة. في حال تجاوز التخلف أو التأخير في التنفيذ مهلة عشرة أيام، ولم يتم التوصل الى حل بين الفريقين، يجوز لمصرف لبنان إستتسائياً (i) فسخ العقد أو (ii) تمديد المهلة المذكورة وذلك فقط في حالات إستثنائية ومعللة. في حال فسخ العقد بسبب القوة القاهرة، يتوجب على مصرف لبنان إعادة "كتاب ضمان حسن التنفيذ" المشار إليه في الفقرة (ج) من المادة ٢٦ أعلاه الى المُلتزم.



**المادة 33: النزاهة**

تُطبّق أحكام المادة ١١٠ من قانون الشراء العام.

**المادة 34: القضاء الصالح**

تطبق القوانين والأنظمة اللبنانية المرعية في تفسير وتنفيذ العقد. تكون محاكم بيروت هي المحاكم الصالحة للبت بأي نزاع قد ينشأ عن تفسير العقد وتنفيذ الإلتزام.

**المادة 35: أحكام مختلفة**

- يخضع الملتمزم في كل ما لم ينص عليه دفتر الشروط الخاص الحاضر، لأحكام قانون الشراء العام رقم ٢٤٤ تاريخ ٢٩/٧/٢٠٢١.
- يوقع العارض على النسخ المسلمة له من دفتر الشروط الخاص الحاضر وملحقاته كافة تأكيداً "منه انه قام بقراءتها واعتبارها صالحة كأساس ملزم لتنفيذ ما ورد في عرضه.

## المُلحق رقم (١)

### لائحة الشروط التقنية والفنية

إن المواصفات التقنية والفنية هي عينها مفصلة في جدول الكميات الملحق رقم (٥)، لذا على العارضين الاطلاع وتأكيدها الموافقة عليها من خلال ختمها، توقيعها وضمها إلى المغلف رقم (١) دون تدوين الأسعار، منوهين بضرورة إضافة المستندات التالية المذكورة في الجدول أدناه بشكل يسمح لمصرف لبنان إجراء التقييم التقني قبل فض العروض المالية:

1. الشهادات
2. إشعار تأكيد موقع من العارض (Confirmation Letters) متضمن إلتزامه بالمتطلبات الفنية المفصلة في البنود رقم ١، ٢، ٣ و ٥ من الجدول أدناه.
3. يستحصل العارض على علامة صفر لأي من البنود المذكورة في حال عدم مطابقة مؤهلات العارض المذكورة في الجدول أدناه.
4. إن الإستحصال على علامة دون ١٠٠/٧٠ ستؤدي إلى إعتبار العارض مرفوض تقنياً وغير مؤهل للمرحلة الثانية، بحيث يستثنى من فض العروض المالية.

#	Description	Grade	Confirmation (Yes / No)	Provide Information / Documents	Provide Certification
1	Confirmation of availability of spare parts in stock (item by item as listed in the schedule attached to the BOQ) and ability to supply BDL within 24 Hours. (In case of partial availability, grading will be computed on pro rata basis as detailed in spare part list attached below).	20	<input type="checkbox"/> Yes <input type="checkbox"/> No		
2	Confirmation of number of preventive maintenance visits as set in BOQ, and intervention duration for corrective maintenance visits within 24 hours.( As detailed in the scope of works)	25	<input type="checkbox"/> Yes <input type="checkbox"/> No		
3	Warranty Duration. The highest warranty duration of replaced spare parts will get the whole grade and the remaining bidders will receive lower grades on a pro rata basis.	15		_____/year	
4	Certification from manufacturer that the bidder is certified as a dealer and qualified to provide maintenance services based on the type of equipment specified in the spare part list. (Except for Portable fire extinguishers)	20		_____	
5	Company profile and references of its projects showing the brands of the maintained equipment as per clause 21 article 4 from TOR (Grading will be computed on pro rata basis according to number of presented projects and their scale).	20			

## **A- Scope of Works**

1. Yearly maintenance contract for fire suppression systems.
2. Preventive visits number for all systems is set to once per month (12 visits per year).
3. Preventive visits number for fire extinguishers is set to once per year.
4. Unlimited corrective visits should be conducted by Bidders based on call from BDL within 24 hours.

### **Fire Extinguishers:**

1. Check pressure valve and replace if needed
2. Check hose and replace if needed
3. Replace rubber seal
4. Refill extinguisher with proper Gas
5. Check physical condition of Fire Extinguisher and report if needed to be replaced
6. List of Extinguishers is listed in Annex 1 attached to this BOQ

### **High Pressure CO2 System:**

1. Survey the hazard to make certain it has not changed from what the system was designed.
2. Check all nozzles to make certain they are in place. That the orifice plates are in place and with the proper orifice.
3. Check the condition of the piping.
4. Check all warning nameplates.
5. Check all cylinders bracketing.
6. Check condition of all cylinder discharge hoses.

### **FM200 System / Novec System / Dry Chemical System**

1. Survey the hazard to make certain it has not changed from what the system was designed.
2. Check all nozzles to make certain they are in place. That the orifice plates are in place and with the proper orifice.
3. Check the condition of the piping.
4. Check all warning nameplates.
5. Check all cylinders bracketing.
6. Check condition of all cylinder discharge hoses.
7. Check proper programming & test.

### **Special Terms**

1. Bidders should ensure that all special equipment, tools and logistics are included within the price.
2. All material needed for conducting the preventive maintenance routine should be included within the price.
3. BDL has the right to award the BOQ to several bidders.

### Spare Part Lists

- Check on the available item to be delivered once needed,
- The below should be added to Envelope number (1) since it is requested for the technical grading,

Item	Part #	Item	Estimated Qty	Confirmation on Availability	Warranty
<b>Hamra Block C - Generator Room</b>					
B1		Flexible Discharge Bend	44		
B2		CV98 Electric Actuator	4		
B3		CV98 Lever Release Actuator	4		
B4		Odorizer 1"	1		
B5		Header vent plug	2		
B6		Pressure switch DPST	1		
B7		Pressure trip with Manual pull	1		
B8		4" Multi-Discharge nozzle, 8.0 orifice	2		
B9		4" Multi-Discharge nozzle, 8.5 orifice	4		
B10		4" Multi-Discharge nozzle, 9.0 orifice	4		
B11		4" Multi-Discharge nozzle, 9.5 orifice	5		
B12		4" Multi-Discharge nozzle, 10.0 orifice	3		
B13		4" Multi-Discharge nozzle, 10.5 orifice	2		
B14		Weigh rail support - Double row	6		
B15		Connector	4		
B16		26" bolt with nut	14		
B17		3 cylinder clamp	6		
B18		2 cylinder clamp	2		
B19		Bracket foot right - Double row	2		
B20		Bracket foot left - Double row	2		
B21		Centre foot	2		
B22		Soale	1		
B23		Lifting Yoke	1		
B24		Nameplate - Maintenance	1		
B25		Warning plate - Inside	1		
B26		Warning plate - Outside	1		
B27		Nameplate - Main	1		
B28		Nameplate - Reserve	1		
B29		2 1/2" check valve	2		
B30		Abort switch	1		
B31		Auto-pulse 442R control panel	1		
B32		Battery Pack	1		
B33		4xZM Zone relay module	1		

B34		Heat detectors c/w bases	12		
B35		Nameplate "Pull to activate fire suppression System"	1		
B36		Strobe	2		
B37		6" Alarm Bell	2		
B38		Selector Switch	1		
B39		Connecting Link	2		
<b>CO2 System Generator Room</b>					
B40	426613	100 # co2 cylinder, red enamel,.W/CV98 valve	12		
B41	73327	Actuator electric HF	1		
B42	428949	Booster actuator	1		
B43	427082	Flexible discharge bend for CV 98 valve	12		
B44	426120	Baffle nozzle, 1/2"	6		
B45	79642	Cylinder back frame 6 cylinder	2		
B46	73255	Bolt & Nut,26 " double row,100lb cylinder	4		
B47	73092	Cylinder clamp-3 cylinder	2		
B48	425310	Warning sign - Do not enter	1		
B49	71682	Weigh rail support - double Row	2		
B50	73270	Weigh rail 6 cylinders	2		
B51	426592	Upright	2		
B52	73556	Bracket foot - Right side double row	1		
B53	73555	Bracket foot - left side	1		
B54	74241	Weigh Scale	1		
B55	69877	Weigh lifting yoke	1		
B56	430525	Autopulse Z-10 Control System, Red 240V AC	1		
B57		Battery 12 v 7 Ah	2		
B58	431196	Abort Supervision Module	1		
B59	430687	Coil Supervision Module ( Release Circuit )	1		
B60	430529	4-PT Auxiliary Relay Module	2		
B61		Mimic panel with LED's and driver	1		
B62	13970	Detector Heat Rate Compensated, 190deg F,W base	6		
B63	417805	Alarm bell 24 VDC 6 in	1		
B64	76494	Abort Switch , Surface mount	1		
B65	433356	Horn / Strobe Multi candella, Fire red	1		
B66	551166	Pull station dual action ,SPST	1		
B67	428660	Back Box Single Gang Surface mount	1		
<b>FM200 System Electrical room</b>					
B68	570007	FM-200,tank 106 L,fill with (217 lbs)	2		
B69	N/A	Factory Fill (per lb)	434		
B70	570092	Container Bracket	4		
B71	570209	Removable Electric Solenoid,24 Volt	4		

B72	570142	2in Discharge hose and adaptor	2		
B73	570121	Check valve Flanged 2	2		
B74	570144	Manifold Inlet Flanged for 3/4 Manifold 2 Check valve	2		
B75	570162	Discharge nozzle 2 in, brass 7ports	2		
B76	570059	Switch low pressure	2		
B77	570192	Entrance Warning Sign	1		
B78	570190	Manual Release Sign	1		
B79	430525	Autopulse Z-10 Control system Red,240 VAC	1		
B80		Battery 12 v, 7 Ah	2		
B81	431196	Abort Supervision Module	1		
B82	430687	Coil supersion Module( release circuit )	1		
B83	430529	4-pt Auxiliary Relay Module	2		
B84	435356	LED Driver, with mimic panel	1		
B85	430559	Detector smoke photoelectric 2.8% ULI	4		
B86	430567	2 wire base with LED driver ULI	4		
B87	417805	Alarm bell 24 VDC 6 in	1		
B88	76494	Abort Switch , Surface mount	1		
B89	433356	Horn / Strobe Multi candella, Fire red	1		
B90	551166	Pull station dual action ,SPST	1		
B91	428660	Back Box Single Gang Surface mount	1		
B92	76496	switch, Main/ Reserve, Surface mount	1		
<b>UPS Room &amp; Batteries - SITI Block A</b>					
B93	430952	Cylinder, Inergen, std 572 cuft with CV98 valve	3		
B94	427082	Flexible discharge bend 200 Bar	3		
B95	73327	Actuator electric HF	1		
B96	428949	Booster actuator	1		
B97	79638	Back Frame 2 cylinder	1		
B98	418502	Bolt and nut 13 in single Row	1		
B99	73091	Cylinder, clamp-2 cylinder	1		
B100	416679	1 in orifice union	1		
B101	416266	Warning plate outside room without alarm	1		
B102	416265	Warning plate outside room with alarm	1		
B103	426142	1" NPT 180 degree Nozzle Inergen side wall	1		
B104	430539	Autopulse Z-28 Control system, 240 VAC	1		
B105	417694	Battery Pack, 18 AH, 24 VDC( 2- 12VDC Batteries)	1		
B106	431193	Sup Release Peripheral & Enclosure	1		
B107	430687	Coil Supervision Module( Release circuit)	1		

B108	430660	Supervised IAM	2		
B109	930663	IAM Mounting Bracket	2		
B110	430664	Relay IAM	4		
B111	430631	Photo Sensor ULI Smoke detector	2		
B112	430636	Standard Sensor Base ULI	2		
B113	76498	Maintenance Switch, surface mount	1		
B114	76494	Abort Switch surface mount	1		
B115	430671	Dual action Push/ Pull addressable	1		
B116	430597	Surface back box red	1		
B117	430594	Namplate, pull station	1		
B118	430599	Replacement Break- Rod	5		
B119	433356	Alarm, Horn/ strobe multi candela, Fire red	1		
B120	417805	Alarm, Bell 24 VDC,6 in	1		
B121	430631	Photo Sensor ULI Smoke detector	4		
B122	430636	Standard Sensor Base ULI	4		
B123	426142	1" NPT 180 degree Nozzle Inergen side wall	1		
B124	427092	Replacement Valve, CV98	1		
<b>Data Server Room ( Main cylinders ) – System2</b>					
B125	430952	Cylinder, Inergen, std 572 cuft with CV98 valve	11		
B126	427082	Flexible discharge bend 200 Bar	11		
B127	73327	Actuator electric HF	1		
B128	428949	Booster actuator	1		
B129	79641	Back Frame 5 cylinder	1		
B130	79642	Back Frame 6 cylinder	1		
B131	418503	Bolt and nut 27 in double row	7		
B132	73092	Cylinder, clamp-3 cylinder	3		
B133	73091	Cylinder, clamp-2 cylinder	1		
B134	879413	connector	1		
B135	32336	actuation Hose, swivel stainless Braided 24"	1		
B136	32334	Male elbow	2		
B137	73236	pilot valve actuation adaptor	2		
B138	416682	2 in orifice union	1		
B139	41942	Nameplate , Main	1		
B140	416266	Warning plate outside room without alarm	1		
B141	416265	Warning plate outside room with alarm	1		
B142	417365	11/4" NPT 180 degree Nozzle Inergen side wall	2		
B143	417362	1/2" NPT 180 degree Nozzle Inergen side wall	2		
B144	430620	Suppression Power supply Kit, 240 V	1		
B145		Battery 12 V,7 Ah	2		
B146	430617	Battery Meter module	1		

B147	431193	Sup Release Peripheral & Enclosure	1		
B148	430687	Coil Supervision Module ( Release circuit)	1		
B149	430660	Supervised IAM	2		
B150	930663	IAM Mounting Bracket	2		
B151	430664	Relay IAM	6		
B152	430628	LCD Annunciator	1		
B153	430629	LCD Annunciator Box , Surface	1		
B154	430631	Photo Sensor ULI Smoke detector	22		
B155	430636	Standard Sensor Base ULI	22		
B156	76498	Maintenance Switch, surface mount	1		
B157	76494	Abort Switch surface mount	1		
B158	430671	Dual action Push/ Pull addressable	1		
B159	430597	Surface back box red	1		
B160	430594	Namplate, pull station	1		
B161	430599	Replacement Break- Rod	5		
B162	433356	Alarm, Horn/ strobe multi candela, Fire red	1		
B163	417805	Alarm, Bell 24 VDC,6 in	1		
B164	430631	Photo Sensor ULI Smoke detector	5		
B165	430636	Standard Sensor Base ULI	5		
B166	417365	11/4" NPT 180 degree Nozzle Inergen side wall	1		
B167	417362	1/2" NPT 180 degree Nozzle Inergen side wall	1		
B168	427092	Replacement Valve, CV98	1		
<b>Data Server Room Future expansion – System 3</b>					
B169					
B170					
B171	73327	Actuator electric HF	3		
B172	428949	Booster actuator	3		
B173	416682	2 in orifice union	1		
B174	427150	2" Selector valve	2		
B175	416266	Warning plate outside room without alarm	1		
B176	416265	Warning plate outside room with alarm	1		
B177	417365	11/4" NPT 180 degree Nozzle Inergen side wall	2		
B178	417362	1/2" NPT 180 degree Nozzle Inergen side wall	2		
B179	430675	Autopulse Ext. Panel , 240 VAC Red	1		
B180	430676	4 pt NAC Expansion Card	1		
B181		Battery 12 V,7 Ah	2		
B182	431193	Sup Release Peripheral & Enclosure	1		
B183	430687	Coil Supervision Module ( Release circuit)	1		
B184	430660	Supervised IAM	2		



B185	930663	IAM Mounting Bracket	2		
B186	430664	Relay IAM	6		
B187	430631	Photo Sensor ULI Smoke detector	20		
B188	430636	Standard Sensor Base ULI	20		
B189	76498	Maintenance Switch, surface mount	1		
B190	76494	Abort Switch surface mount	1		
B191	430671	Dual action Push/ Pull addressable	1		
B192	430597	Surface back box red	1		
B193	430594	Namplate, pull station	1		
B194	430599	Replacement Break- Rod	5		
B195	433356	Alarm, Horn/ strobe multi candela, Fire red	1		
B196	417805	Alarm, Bell 24 VDC,6 in	1		
B197	430631	Photo Sensor ULI Smoke detector	4		
B198	430636	Standard Sensor Base ULI	4		
B199	417365	11/4" NPT 180 degree Nozzle Inergen side wall	1		
B200	417362	1/2" NPT 180 degree Nozzle Inergen side wall	1		
<b>Inergen systems, Vault 1- Zone 1,( Main )</b>					
B201	73327	Actuator electric HF	2		
B202	428949	Booster actuator	2		
B203	32336	actuation Hose, swivel stainless Braided 24"	1		
B204	32334	Male elbow	2		
B205	73236	pilot valve actuation adaptor	2		
B206	416682	2 in orifice union	1		
B207	427150	2" Selector valve	1		
B208	40656	Valve check threaded 2 1/2"	1		
B209	40309	Header vent plug	1		
B210	70846	Actuator Lever for HF Actuator	2		
B211	416266	Warning plate outside room without alarm	1		
B212	426157	1 1/2" NPT 180 degree Nozzle Inergen side wall	4		
B213	433608	Autopulse 542R Agent Releasing Control 240VAC	1		
B214		Battery 12 V,7 Ah	2		
B215	435356	LED Driver, APN-ANN-I/O	1		
B216	435358	Relay module 10 programmable Contacts	1		
B217		Mimic Panel with LED'S	1		
B218	430023	Photo detector low profile 2151	6		
B219	417996	Detector base, B401	6		
B220	76498	Maintenance Switch, surface mount	1		
B221	76494	Abort Switch surface mount	1		
B222	428655	pull station, Dual action, SPST	1		
B223	428660	Surface back box	1		

B224	35816	Namplate, pull station	1		
B225	433356	Alarm, Horn/ strobe multi candela, Fire red	2		
B226	417805	Alarm, Bell 24 VDC,6 in	2		
B227	430023	Photo detector low profile 2151	2		
B228	417996	Detector base, B401	2		
B229	426157	11/2" NPT 180 degree Nozzle Inergen side wall	1		
<b>Inergen systems, Vault 2- Zone 2,( Main )</b>					
B230	73327	Actuator electric HF	2		
B231	428949	Booster actuator	2		
B232	32336	actuation Hose, swivel stainless Braided 24"	2		
B233	32334	Male elbow	2		
B234	73236	pilot valve actuation adaptor	4		
B235	418359	Flared tee	2		
B236	416682	2 in orifice union	1		
B237	427150	2" Selector valve	1		
B238	40656	Valve check threaded 21/2"	1		
B239	40309	Header vent plug	1		
B240	70846	Actuator Lever for HF Actuator	2		
B241	416266	Warning plate outside room without alarm	1		
B242	426157	11/2" NPT 180 degree Nozzle Inergen side wall	4		
B243	433608	Autopulse 542R Agent Releasing Control 240VAC	1		
B244		Battery 12 V,7 Ah	2		
B245	435356	LED Driver, APN-ANN-I/O	1		
B246	435358	Relay module 10 programmable Contacts	1		
B247		Mimic Panel with LED'S	1		
B248	430023	Photo detector low profile 2151	8		
B249	417996	Detector base, B401	8		
B250	76498	Maintenance Switch, surface mount	1		
B251	76494	Abort Switch surface mount	1		
B252	428655	pull station, Dual action, SPST	1		
B253	428660	Surface back box	1		
B254	35816	Namplate, pull station	1		
B255	433356	Alarm, Horn/ strobe multi candela, Fire red	2		
B256	417805	Alarm, Bell 24 VDC,6 in	2		
B257	41942	Name plate Main	1		
B258	417805	Name plate Reserve	1		
B259	430023	Photo detector low profile 2151	2		
B260	417996	Detector base, B401	2		
B261	426157	11/2" NPT 180 degree Nozzle Inergen side wall	1		

Inergen systems, Vault 3- Zone 3,( Main & Reserve )					
B262	430952	Cylinder, Inergen, std 572 cuft with CV98 valve	58		
B263	427082	Flexible discharge bend 200 Bar	58		
B264	73327	Actuator electric HF	6		
B265	428949	Booster actuator	6		
B266	79641	Back Frame 5 cylinder	10		
B267	79640	Back Frame 4 cylinder	2		
B268	418503	Bolt and nut 27 in double row	17		
B269	73092	Cylinder, clamp-3 cylinder	5		
B270	73091	Cylinder, clamp-2 cylinder	7		
B271	879413	connector	10		
B272	70846	Actuator Lever for HF Actuator	4		
B273	32336	actuation Hose, swivel stainless Braided 24"	5		
B274	418359	Flared tee	5		
B275	32334	Male elbow	6		
B276	73236	pilot valve actuation adaptor	8		
B277	427886	3 in orifice Flanged , weld Neck	1		
B278	427150	2" Selector valve	2		
B279	40665	3 in Check valve Threaded Flange ,3 in	2		
B280	40656	Valve check threaded 2 1/2"	2		
B281	40309	Header vent plug	2		
B282	416266	Warning plate outside room without alarm	3		
B283	417366	1 1/2" NPT 360 degree Nozzle Inergen	6		
B284	433608	Autopulse 542R Agent Releasing Control 240VAC	1		
B285		Battery 12 V,7 Ah	2		
B286	435356	LED Driver, APN-ANN-I/O	1		
B287	435358	Relay module 10 programmable Contacts	1		
B288		Mimic Panel with LED'S	1		
B289	430023	Photo detector low profile 2151	20		
B290	417996	Detector base, B401	20		
B291	76498	Maintenance Switch, surface mount	1		
B292	76494	Abort Switch surface mount	1		
B293	428655	pull station, Dual action, SPST	1		
B294	428660	Surface back box	1		
B295	35816	Namplate, pull station	1		
B296	76496	Main / Reserve /switch Surface mount	1		
B297	433356	Alarm, Horn/ strobe multi candela, Fire red	2		
B298	417805	Alarm, Bell 24 VDC,6 in	2		
B299					

B300	430023	Photo detector low profile 2151	4		
B301	417996	Detector base, B401	4		
B302	427092	Replacement valve CV 98 for inergen cylinder	6		
B303	417366	11/2" NPT 360 degree Nozzle Inergen	2		
<b>Block E FM-200 system -UPS Room (System1)</b>					
B304	570006	FM-200,tank 52 L,fill with 84 lbs)	1		
B305	N/A	Factory Fill (per lb)	84		
B306	570092	Container Bracket	2		
B307	570209	Removable Electric Solenoid,24 Volt	1		
B308	570142	2in Discharge hose and adaptor	1		
B309	570162	Discharge nozzle 2 in, brass	1		
B310	570059	Supervisory Pressure switch	1		
B311	570192	Entrance Warning Sign	1		
B312	430525	Autopulse Z-10 Control system Red 1230/240VAC	1		
B313		Battery 12 v 7 Ah	2		
B314	430687	Coil Supervision Module ( Release circuit)	1		
B315	430559	Photoelectric Smoke detector 2.8% ULI	2		
B316	430567	2-wire base w/LED Driver ULI	2		
B317	417805	Alarm bell 24 VDC 6 in	1		
B318	76494	Abort Switch , Surface mount	1		
B319	433356	Horn / Strobe Multi candella, Fire red	1		
B320	551167	Pull station dual action ,DPST	1		
B321	428660	Back Box Single Gang Surface mount	1		
<b>Block E FM-200 system -Electrical room (System2)</b>					
B322	570006	FM-200,tank 52 L,fill with 88 lbs)	1		
B323	N/A	Factory Fill (per lb)	88		
B324	570092	Container Bracket	2		
B325	570209	Removable Electric Solenoid,24 Volt	1		
B326	570142	2in Discharge hose and adaptor	1		
B327	570162	Discharge nozzle 2 in, brass	1		
B328	570059	Supervisory Pressure switch	1		
B329	570192	Entrance Warning Sign	1		
B330	430525	Autopulse Z-10 Control system Red 1230/240VAC	1		
B331		Battery 12 v 7 Ah	2		
B332	430687	Coil Supervision Module ( Release circuit)	1		
B333	430559	Photoelectric Smoke detector 2.8% ULI	2		
B334	430567	2-wire base w/LED Driver ULI	2		
B335	417805	Alarm bell 24 VDC 6 in	1		
B336	76494	Abort Switch , Surface mount	1		
B337	433356	Horn / Strobe Multi candella, Fire red	1		

B338	551167	Pull station dual action ,DPST	1		
B339	428660	Back Box Single Gang Surface mount	1		
<b>Block B System1 UPS Room</b>					
B340	570006	FM-200,tank 52 L,fill with 84 lbs)	1		
B341	N/A	Factory Fill (per lb)	84		
B342	570092	Container Bracket	2		
B343	570209	Removable Electric Solenoid,24 Volt	1		
B344	570142	2in Discharge hose and adaptor	1		
B345	570162	Discharge nozzle 2 in, brass 7 ports	1		
B346	570192	Entrance Warning Sign	1		
B347	570190	Manual Release Sign	1		
B348	570229	PCR-100 control system, red 240VAC	1		
B349		Battery 12 v 7 Ah	2		
B350	430023	Photoelectric Smoke detector	2		
B351	430025	Base Model,B110LP , 6 in Dia	2		
B352	417805	Alarm bell 24 VDC 6 in	1		
B353	76494	Abort Switch , Surface mount	1		
B354	433357	Horn / Strobe Multi candella, Agent red	1		
B355	551167	Pull station dual action ,DPST	1		
B356	428660	Back Box Single Gang Surface mount	1		
<b>Block B System 2,Batteries room</b>					
B357	570005	FM-200,tank 32 L,fill with 58 lbs)	1		
B358	N/A	Factory Fill (per lb)	58		
B359	570085	Container Bracket	2		
B360	570209	Removable Electric Solenoid,24 Volt	1		
B361	570141	1in Discharge hose and adaptor	1		
B362	570159	Discharge nozzle 1 in, brass 7 ports	1		
B363	570192	Entrance Warning Sign	1		
B364	570190	Manual Release Sign	1		
B365	570229	PCR-100 control system, red 240VAC	1		
B366		Battery 12 v 7 Ah	2		
B367	430023	Photoelectric Smoke detector	2		
B368	430025	Base Model,B110LP , 6 in Dia	2		
B369	417805	Alarm bell 24 VDC 6 in	1		
B370	76494	Abort Switch , Surface mount	1		
B371	433357	Horn / Strobe Multi candella, Agent red	1		
B372	551167	Pull station dual action ,DPST	1		
B373	428660	Back Box Single Gang Surface mount	1		
<b>Block B System 3,CCTV&amp; Control room</b>					
B374	570004	FM-200,tank 16 L,fill with 25 lbs)	1		
B375	N/A	Factory Fill (per lb)	25		
B376	570085	Container Bracket	2		
B377	570209	Removable Electric Solenoid,24 Volt	1		
B378	570141	1in Discharge hose and adaptor	1		

B379	570159	Discharge nozzle 1 in, brass 7 ports	1		
B380	570192	Entrance Warning Sign	1		
B381	570190	Manual Release Sign	1		
B382	570229	PCR-100 control system, red 240VAC	1		
B383		Battery 12 v 7 Ah	2		
B384	430023	Photoelectric Smoke detector	2		
B385	430025	Base Model,B110LP , 6 in Dia	2		
B386	417805	Alarm bell 24 VDC 6 in	1		
B387	76494	Abort Switch , Surface mount	1		
B388	433357	Horn / Strobe Multi candella, Agent red	1		
B389	551167	Pull station dual action ,DPST	1		
B390	428660	Back Box Single Gang Surface mount	1		
<b>Block A 4th UPS Room Inergen System 1</b>					
B391	430952	Cylinder, Inergen, std 572 cuft with CV98 valve	1		
B392	427082	Flexible discharge bend 200 Bar	1		
B393	73327	Actuator electric HF	1		
B394	428949	Booster actuator	1		
B395	427705	channel includes bolts nuts saddle padding	1		
B396	416677	1/2 in orifice union	1		
B397	416266	Warning plate outside room without alarm	1		
B398	426140	1/2" NPT 180 degree Nozzle Inergen side wall	1		
B399	430525	Autopulse Z-10 Control system Red 240V AC	1		
B400		Battery 12 V,7 Ah	2		
B401	430529	4-PT Auxiliary relay Module	1		
B402	430559	Photo Detector 2.8% ULI	4		
B403	430567	2-Wire Base W/LED driver	4		
B404	433356	Horn/ strobe Multi candela, Fire red	1		
B405	417805	Alarm, Bell 24 VDC,6 in	1		
B406	428655	Manual pull station Dual action, SPST	1		
B407	428660	Back Box, Surface Mount	1		
B408	76494	Abort Switch, Surface mount	1		
<b>Block A 4th Archive room Inergen</b>					
B409	430952	Cylinder, Inergen, std 572 cuft with CV98 valve	3		
B410	427082	Flexible discharge bend 200 Bar	3		
B411	73327	Actuator electric HF	1		
B412	428949	Booster actuator	1		
B413	79639	Back Frame 3 cylinder	1		
B414	418502	Bolt and nut 13 in single row	2		
B415	873092	Cylinder, clamp-3 cylinder	1		
B416	416680	11/4 in orifice union	1		

B417	416266	Warning plate outside room without alarm	1		
B418	426142	1" NPT 180 degree Nozzle Inergen side wall	2		
B419	430525	Autopulse Z-10 Control system Red`240V AC	1		
B420		Battery 12 V,7 Ah	2		
B421	430529	4-PT Auxiliary relay Module	1		
B422	430559	Photo Detector 2.8% ULI	4		
B423	430567	2-Wire Base W/LED driver	4		
B424	433356	Horn/ strobe Multi candela, Fire red	1		
B425	417805	Alarm, Bell 24 VDC,6 in	1		
B426	428655	Manual pull station Dual action, SPST	1		
B427	428660	Back Box, Surface Mount	1		
B428	76494	Abort Switch, Surface mount	1		
<b>Primary Data Center - Inergen Fire System</b>					
B429	432874	200-Bar Inergen Cylinder Assembly	38		
B430	426620	150-Bar Inergen Cylinder Assembly	4		
B431	4007-9101	4007ES Hybrid Fire Control Panel	1		
B432	4009-9301	IDNet NAC Extender	3		
B433	4090-9006	Fire Releasing Device	12		
B434	857433	2-1/2" Selector Valve	1		
B435	427150	2" Selector Valve	2		
B436	427185	1" Selector Valve	4		
B437	73327	HF Electric Actuator	15		
B438	428949	Booster Actuator	15		
B439	4090-9007	Signal IAM	16		
B440	4098-9714	Smoke Detector	60		
B441	4098-9733	Heat Detector	1		
B442	4098-9792	Detector Base	61		
B443	4099-9006	Double-Action Surface Mounted Pull Station	8		
B444	417362	1/2" 360° Inergen Discharge Nozzle	1		
B445	426141	3/4" 180° Inergen Discharge Nozzle	4		
B446	417365	1-1/4" 360° Inergen Discharge Nozzle	1		
B447	445710	1-1/2" Inergen Acoustic Discharge Nozzle	10		
B448	27511	Inergen Acoustic Nozzle Orifice Pipe Assembly	10		
B449	40852	3/4" Check Valve	2		
B450	40649	2" Check Valve	2		
B451	40656	2-1/2" Check Valve	4		

B452	4090-9002	Relay IAM	21		
B453	4090-9001	Monitored IAM	21		
B454	4906-9127	Horn with Multi Candela Strobe	16		
B455	2080-9057	Surface Mounted Abort Switch	7		
B456	76496	Surface Mounted Main / Reserve Switch	4		
B457	76498	Maintenance Disconnect Switch	4		
B458	427082	Flexible Discharge Bend	42		
B459	416680	1-1/4" Orifice Union	1		
B460	416682	2" Orifice Union	2		
B461	427886	2-1/2" Flanged Pressure Reducer	1		
B462	431700	Manifold Relief Valve	8		
B463	40309	Header Vent Plug	7		
B464	4007-9810	Modular Network Interface Card	1		
B465	4007-9813	Wired Network Media Card	2		
B466	4606-9202	LCD Annunciator with Red Trim	1		
B467	N / A	Cylinder Bracketing	1		
<b>Block B - Fuel Tank Room - Carbon Dioxide Fire Suppression System</b>					
B468		100lbs. CO2 Cylinders & Valve Assembly with Discharge	4		
B469		Hose 3/4" Outlet	1		
B470		Aegis Release Panel	1		
B471		Batteries 12V-7AH	2		
B472		Electric Control Heads 24 VDC Head,	2		
B473		Nameplate, Warning "Vacate At Once	2		
B474		Kidde Aegis Single Hazard Agent Releasing Panel "	1		
B475		Multi Jet Type S Nozzle 1/2' NPT	4		
B476		Heat Detector Model, Vertical Mount	4		
B477		Multi-tone Signal Strobe 24 VDC 15/75 cd	2		
B478		Indoor /Outdoor Surface Back Box	2		
B479		Sounder Strobe Back Box	2		
B480		Kidde 3300 Conventional Dual Action Pull Station	1		
B481		Kidde 3300 SGB-32s Indoor Surface Back Box	1		
B482		Manual Station Back Box	1		



B483		Cylinder Strap	2		
<b>Server Room- Block B - FM-200 Fire Suppression System</b>					
<b>in</b>					
B484		70lbs Capacity FM-200 Cylinder and Valve assembly c/w Bracket and	1		
B485		Adapter	1		
B486		FM-200 Nozzle	2		
B487		Back box	1		
B488		Aegis Panel c/w Back-up Battery Valve	1		
B489		24 VDC Electric Control Head	1		
B490		Nameplate "Warning "	2		
B491		Ionization Smoke Detector c/w Base	2		
B492		Photoelectric Smoke Detector c/w Base	2		
B493		Multi-tone Signal Strobe	2		
B494		Sounder Strobe Back Box	2		
B495		Manual Station Back Box	1		
B496		Indoor/outdoor Surface Back Box	2		
B497		Suppression Abort Station	1		
B498		Kidde Conventional Dual Action Pull Station	1		
<b>Shredding Room FM-200 Fire Suppression System</b>					
B499		600lbs FM-200 Cylinder Assembly (762Lbs Filled) with Cylinder	2		
B500		Nozzle	1		
B501		Aegis Release Panel	1		
B502		Batteries 12V-7AH	2		
B503		Electric Control Heads 24 VDC	2		
B504		Nameplate, Warning "FM-200	1		
B505		Suppression Abort Station	1		
B506		Back Box-Switch 4x4	1		
B507		Kidde AEGIS Single Hazard Agent Releasing Panel	1		
B508		Multi Jet Type S Nozzle ½' NPT	4		
B509		Smoke Detector	2		
B510		PSD-7157 Advanced Photoelectric Smoke Detector	2		
B511		2WB 2 wire standard Base	2		
B512		Multi-Tone Strobe 24 VDC 15/75 cd	2		
B513		Indoor/Outdoor Surface Back Box	1		
B514		Main to Reserve Switch	1		
B515		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
B516		Sounder Strobe Back Box	2		

B517		Kidde 3300 Conventional Dual Action Pull Station	1		
B518		Name plate 'Main'	1		
B519		Name plate 'Reserve'	1		
B520		3 Swings Check FM-200	2		
B521		Container Pressure Switch	2		
B522		Back Box-Switch 4x4 r	1		
B523		Switch – Maintenance Kidde	1		
<b>Shredding Room1LVM FM-200 Fire Suppression System</b>					
B524		200Lbs FM-200 (288Lbs Filled) Cylinder Assembly 2" Valve with Strap Suppression System	2		
B525		Flex Hose 2 Discharge	2		
B526		Nozzle	1		
B527		Aegis Release Panel	1		
B528		Batteries 12V-7AH	2		
B529		Electric Control Heads 24 VDC	2		
B530		Nozzle FM-200 180 37987	1		
B531		Nameplate, Warning "FM-200	1		
B532		Suppression abort station	1		
B533		Back Box-Switch 4x4	1		
B534		Kidde AEGIS Single Hazard Agent Releasing Panel	1		
B535		Smoke Detector	2		
B536		PSD-7157 Advanced Photoelectric Smoke Detector	1		
B537		2WB 2 Wire Standard Base	2		
B538		Multi-Tone Strobe 24 VDC 15/75 cd	1		
B539		Indoor/Outdoor Surface Back Box	1		
B540		Main to Reserve Switch	1		
B541		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
B542		Kidde 3300 Conventional Dual Action Pull Station	1		
B543		Name plate "Main"	1		
B544		Name plate 'Reserve'	1		
B545		Manifold EI Check	2		
B546		Back Box-Switch 4x4	1		
B547		Supervisory Pressure Switch	2		
B548		Switch – Maintenance Kidde	1		
<b>UPS Room FM-200 Fire Suppression System</b>					
B550		200Lbs Cylinder Assembly (150Lbs Filled) with Cylinder Strap with Strap	2		
B551		Nozzle	1		
B552		Aegis Release Panel	1		
B553		Batteries 12V-7AH	2		

B554		Electric Control Heads 24 VDC	2		
B555		Nozzle FM-200 180 37987	1		
B556		Nameplate, Warning "FM-200	1		
B557		Suppression Abort Station	1		
B558		Back Box-Switch 4x4	1		
B559		Kidde AEGIS Single Hazard Agent Releasing Panel	1		
B560		Smoke Detector	1		
B561		PSD-7157 Advanced Photoelectric Smoke Detector	1		
B562		2WB 2 Wire Standard Base	2		
B563		Multi-Tone Strobe 24 VDC 15/75 cd	1		
B564		Indoor/outdoor Surface Back Box	1		
B565		Main to Reserve Switch	1		
B566		Kidde 3300 SGB-32S Indoor Surface Back box	1		
B567		Kidde 3300 Conventional Dual Action Pull Station	1		
B568		Name plate 'Main'	1		
B569		Name plate 'Reserve'	1		
B570		Manifold EI Check	2		
B571		Back Box-Switch 4x4	1		
B572		Supervisory Pressure Switch	2		
B573		Switch – Maintenance Kidde	1		
<b>DVR Room FM-200 Fire Suppression System</b>					
B574		200Lbs FM-200 Cylinder Assembly (184Lbs Filled) with Cylinder Strap and	2		
B575		Discharge	1		
B576		Nozzle	1		
B577		Aegis Release Panel	1		
B578		Batteries 12V-7AH Flex	2		
B579		Electric Control Heads 24 VDC	2		
B580		Nozzle	1		
B581		Nameplate, Warning 'FM-200'	1		
B582		Suppression Abort Station	1		
B583		Back Box-Switch 4x4	1		
B584		Kidde AEGIS Single Hazard Agent Releasing Panel	1		
B585		Smoke Detector	1		
B586		PSD-7157 Advanced Photoelectric Smoke Detector	1		
B587		2WB 2 Wire Standard Base	2		
B588		Multi-Tone- Strobe 24 VDC 15/75 cd	1		
B589		Indoor/Outdoor Surface Back Box	1		
B590		Main to Reserve Switch	1		

B591		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
B592		Kidde 3300 Conventional Dual Action Pull Station	1		
B593		Name plate 'Main'	1		
B594		Name plate 'Reserve'	1		
B595		Manifold EL Check	2		
B596		Back Box-Switch 4x4	1		
B597		Supervisory Pressure Switch	2		
B598		Switch – Maintenance Kidde	1		
<b>Archive Room - Argonite Fire Suppression System</b>					
B599		Cylinder & Valve Assembly /valve-Argonite 80-.0L	14		
B600		KIT-Prime Complete Argonite	2		
B601		Valve-Manifold Check	14		
B602		Argonite 5MM Nozzle INPT	1		
B603		Argonite 16.0MM nozzle INPT	1		
B604		Argonite KF nozzle 1/2NPT	2		
B605		Argonite 1-1/2NPT Raster-FE/FE	1		
B606		Nameplate, Warning 'FM-200'	1		
B607		Suppression abort station	1		
B608		Back Box-Switch 4x4	1		
B609		Kidde AEGIS Single Hazard Agent Releasing Panel	1		
B610		Batteries 12v-7AH	2		
B611		Smoke Detector	1		
B612		PSD-7157 Advanced Photoelectric Smoke Detector	1		
B613		2WB 2 Wire Standard Base	2		
B614		Multi-tone Strobe 24 VDC 15/75 cd	1		
B615		Indoor/Outdoor Surface Back box	1		
B616		Main to Reserve Switch	1		
B617		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
B618		Kidde 3300 Conventional Dual Action Pull Station	1		
B619		Name Plate 'Main'	1		
B620		Name Plate 'Reserve'	1		
B621		Back Box-Switch 4x4	1		
B622		Switch – Maintenance Kidde	1		
<b>Electrical Room FM-200 Fire Suppression System</b>					
B623		200Lbs FM-200 Cylinder Assembly 2" Valve (338Lbs Filled) with Cylinder	2		
B624		Nozzle FM-200	1		
B625		Aegis Release Panel	1		
B626		Batteries 12V-7AH	2		

B627		Electric Control Heads 24 Strap	2		
B628		Nameplate, Warning 'FM-200' VDC	1		
B629		Suppression Abort Station	1		
B630		Back Box-Switch 4x4	1		
B631		Kidde AEGIS Single Hazard Agent	1		
B632		Smoke Detector Releasing Panel	1		
B633		PSD-7157 Advanced Photoelectric Smoke Detector	1		
B634		2WB 2 Wire Standard	2		
B635		Multi-Tone- Strobe 24 VDC Base	1		
B636		Indoor/Outdoor Surface Back Box 15/75 cd	1		
B637		Main to Reserve Switch	1		
B638		Kidde 3300 SGB-32S Indoor	1		
B639		Kidde 3300 Conventional Dual Surface Back box	1		
B640		Name Plate 'Main' Action Pull Station	1		
B641		Name Plate 'Reserve'	1		
B642		Manifold EI Check	2		
B643		Back Box-Switch 4x4	1		
B644		Supervisory Pressure Switch	2		
B645		Switch – Maintenance Kidde	1		
<b>Zahle - Dry Chemical System in Boiler Room</b>					
B646		Ind-45 ABC Cylinder & Valve Assembly with mounting Bracket, Discharge kit, XV Control System, High Pressure Hose and Electric Actuator Kit 24 VDC	1		
B647		Total Flooding Nozzles	4		
B648		Kidde Aegis Single Hazard Agent Releasing Panel	1		
B649		Batteries 12V-7AH	2		
B650		Heat Detector Model 27121-0, 225 F Vertical Mount Kit,	2		
B651		Multi Tone Strobe 24 VDC 15/75cd	1		
B652		Indoor/Outdoor Surface Back Box	1		
B653		Kidde 3300 Conventional Dual Action Pull Station	1		
B654		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
B655		Back Box Switch 4x4	1		
B656		Suppression Abort Station	1		
B657		Nameplate	2		
<b>Novex 1230 Fire Suppression System in Block A , Archive Room 5th floor</b>					

B658		600Lb Novec Cylinder and Valve Assembly with Cylinder Strap	1		
B659		Electric Control Head, 24 VDC	1		
B660		Nozzle Novec	6		
B661		Nameplate, "Warning", Novec 1230	6		
B662		Pressure Switch, 3 Pole Double Throw	1		
B663		Suppression Abort Station	4		
B664		Back Box Switch 4x4	4		
B665		Kidde Aegis Single Hazard Agent Releasing Panel	1		
B666		Batteries 12V-7AH	2		
B667		CPD-7054D Ion Smoke Detector	6		
B668		PSD-7157 Advanced Photoelectric Smoke Detector	6		
B669		2WB-Two Wire Standard Base	12		
<b>Novec 1230 Fire Suppression System in Bloc E VGF&amp; CCTV Room</b>					
B670		40Lb Novec Cylinder and Valve Assembly with Outlet Adapter 1	1		
B671		Novec Nozzle	2		
B672		Nameplate, "Warning", Novec 1230	2		
B673		Pressure Switch 3" Pole Double Throw	1		
B674		Suppression Abort Station ½",	1		
B675		Back Box Switch 4x4	1		
B676		Kidde Aegis Single Hazard Agent Releasing Panel	1		
B677		Battery 12 V DC, 7 AH	2		
B678		CPD-7054D Ion Smoke Detector	2		
B679		PSD-7157 Advanced Photoelectric Smoke detector	2		
B680		2WB 2 Wire Standard Base	4		
B681		Multi Tone Strobe, 24 V 15/75 cd	2		
B682		Indoor/Outdoor Surface Back Box	2		
B683		Kidde 3300 Conventional Dual Action Pull Station	1		
B684		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
<b>Novec 1230 Fire Suppression System in Block B-B1 UPS Security Room</b>					
B685		125Lbs Cylinder Assembly, 1-1/2" Valve with Outlet Adapter, Cylinder Strap and Electric Control Head, 24 VDC	1		
B686		Discharge Nozzle	3		
B687		Nameplate, "Warning", Novec	2		

B688		Pressure Switch, 3 Pole Double Throw	1		
B689		Kidde 878752 Suppression Abort Station	1		
B690		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B691		Aegis Fire Releasing Panel	1		
B692		Lead Acid Battery, 12 VDC, 7 AH	2		
B693		Ionization Smoke Detector	3		
B694		Photoelectric Smoke Detector Box	3		
B695		2WB-Two Wire Standard Base	6		
B696		Multi Tone Alarm & 30cd Strobe, 24 V	2		
B697		Multi Tone Alarm Back Box, IOB-R	2		
B698		SPST Manual Release Station, 3300 Series	1		
B699		Manual Station Back Box, SGB-32S	1		
<b>NoveB 1230 Fire Suppression System in BloB A Fuel Room B3</b>					
B700		600Lbs Cylinder Assembly 3" Valve, with Cylinder Strap and Electric	1		
B701		Discharge Nozzle, Brass	4		
B702		Nameplate, "Warning", Novec	2		
B703		Pressure Switch 3" Pole Double Throw	1		
B704		Kidde 878752 Suppression Abort Station Control	1		
B705		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B706		Aegis Fire Releasing Panel	1		
B707		Lead Acid Battery, 12 V DC, 7 AH	2		
B708		Heat Detector Model 27121-0, 225 F Vertical Mount	4		
B709		Multi Alarm & 30 d Strobe, 24 V Box	2		
B710		Multi Tone Alarm Back IOB-R	2		
B711		SPST Manual Release Station, 3300 Series	1		
B712		Manual Station Back Box, SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Bloc B Electrical B1</b>					
B713		200Lbs Cylinder Assembly 2" Valve Outlet Adapter 2" and Electric	1		
B714		Discharge Nozzle, Brass	2		
B715		Nameplate, "Warning", Novec	2		
B716		Pressure Switch, 3 Pole Double Throw	1		

B717		Kidde 878752 Suppression Abort Station Control	1		
B718		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B719		Aegis Fire Releasing Panel	1		
B720		Ionization Smoke Detector	2		
B721		Photoelectric Smoke Detector	2		
B722		2WB Two Wire Standard Base Box	4		
B723		Multi Tone Alarm & 30 cd Strobe, 24 V	2		
B724		Multi Tone Alarm Back Box IOB-R	2		
B725		SPST Manual Release Station, 3300 Series	1		
B726		Manual Station Back Box, SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Bloc A UPS B2</b>					
B727		125Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Cylinder Strap Electric Control Head 24 VDC and Discharge Nozzle	1		
B728		Nameplate, "Warning," Novec	2		
B729		Pressure Switch 3 Pole Double Throw	1		
B730		Kidde 878752 Suppression Abort Station	1		
B731		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B732		Aegis Fire Releasing Panel	1		
B733		Lead Acid Battery 12 VDC 7 AH	2		
B734		Ionization Smoke Detector	1		
B735		Photoelectric Smoke Detector Box	1		
B736		2WB Two Wire Standard Base	2		
B737		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B738		Multi Tone Alarm Back Box IOB-R	2		
B739		SPST Manual Release Station 3300 Series	1		
B741		Manual Station Back Box, SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Bloc D UPS Room B1</b>					
B742		70Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Cylinder Strap Electric Control Head 24 VDC	1		
B743		Discharge Nozzle	2		
B744		Nameplate, "Warning", Novec	2		



B745		Pressure Switch 3 Pole Double Throw	1		
B746		Kidde 878752 Suppression Abort Station	1		
B747		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B748		Aegis Fire Releasing Panel	1		
B749		Lead Acid Battery 12 VDC, 7 AH	2		
B750		Ionization Smoke Detector	2		
B751		Photoelectric Smoke Detector Box	2		
B753		2WB Two Wire Standard Base	4		
B754		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B755		Multi Tone Alarm Back Box IOB-R	2		
B756		SPST Manual Release Station 3300 Series	1		
B757		Manual Station Back Box SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Bloc A-B2 UMDB</b>					
B760		40Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Wall Bracket, Electric Control Head 24 VDC and Discharge Nozzle	1		
B761		Nameplate "Warning", Novac	2		
B762		Pressure Switch 3 Pole Double Throw	1		
B763		Kidde 878752 Suppression Abort Station	1		
B764		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B765		Aegis Fire Releasing Panel	1		
B766		Lead Acid Battery 12 VDC 7 AH	2		
B767		Ionization Smoke Detector	1		
B768		Photoelectric Smoke Detector Box	1		
B769		2 WB Two Wire Standard Base	2		
B770		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B771		Multi Tone Alarm Back Box IOB-R	2		
B772		SPST Manual Release Station 3300 Series	1		
B773		Manual Station Back Box SGB-32S	1		
<b>Novac 1230 Fire Suppression System in Bloc A Bat Room B2</b>					

B774		125Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Cylinder Strap Electric Control Head and Discharge Nozzle	1		
B775		Nameplate "Warning", Novec	2		
B776		Pressure Switch 3 Pole Double Throw	1		
B777		Kidde 878752 Suppression Abort Station	1		
B778		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B779		Aegis Fire Releasing Panel	1		
B780		Lead Acid Battery 12 VDC 7 AH	2		
B781		Ionization Smoke Detector	1		
B782		Photoelectric Smoke Detector Box	1		
B783		2WB Two Wire Standard Base	2		
B784		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B785		Multi Tone Alarm Back Box IOB-R	2		
B786		SPST Manual Release Station 3300 Series	1		
B787		Manual Station Back Box SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Bloc D CCTV Room B1</b>					
B789		40Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Wall Bracket, Electric Control Head 24 VDC and Discharge Nozzle	1		
B790		Nameplate "Warning", Novec	2		
B791		Pressure Switch 3 Pole Double Throw	1		
B792		Kidde 878752 Suppression Abort Station	1		
B793		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B794		Aegis Fire Releasing Panel	1		
B795		Lead Acid Battery 12 VDC 7AH	2		
B796		Ionization Smoke Detector	1		
B797		Photoelectric Smoke Detector Box	1		
B798		2WB Two Wire Standard Base	2		
B799		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B800		Multi Tone Alarm Back Box IOB-R	2		
B801		SPT Manual Release Station 3300 Series	1		

B802		Manual Station Back Box SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Block A Bat Room 8th Floor</b>					
B803		40Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Wall Bracket, Electric Control Head 24 VDC and Discharge Nozzle	1		
B804		Nameplate "Warning", Novec	2		
B805		Pressure Switch 3 Pole Double Throw	1		
B806		Kidde 878752 Suppression Abort Station	1		
B807		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B808		Aegis Fire Releasing Panel	1		
B809		Lead Acid Battery 12 VDC 7 AH	2		
B810		Ionization Smoke Detector	1		
B811		Photoelectric Smoke Detector Box	1		
B812		2WB Wire Standard Base	2		
B813		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B814		Multi Tone Alarm Back Box IOB-R	2		
B815		SPST Manual Release Station 3300 Series	1		
B816		Manual Station Back Box SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Bloc A CCTV Room B1:</b>					
B817		40Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Wall Bracket, Electric Control Head 24 VDC and Discharge Nozzle	1		
B818		Nameplate "Warning", Novec	2		
B819		Pressure Switch 3 Pole Double Throw	1		
B820		Kidde 878752 Suppression Abort Station	1		
B821		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B822		Aegis Fire Releasing Panel	1		
B823		Lead Acid Battery 12 VDC 7 AH	2		
B824		Ionization Smoke Detector	1		
B825		Photoelectric Smoke Detector Box	1		
B826		2WB Wire Standard Base	2		
B827		Multi Tone Alarm & 30 cd Strobe 24 V	2		

B828		Multi Tone Alarm Back Box IOB-R	2		
B829		SPST Manual Release Station 3300 Series	1		
B830		Manual Station Back Box SGB-32S	1		
<b>Novec 1230 Fire Suppression System in UPS Room Block A B1</b>					
B831		200Lbs Cylinder Assembly 2" Valve Outlet Adapter 2" and Electric Control Head 24 VDC	1		
B832		Discharge Nozzle, Brass	2		
B833		Nameplate, "Warning", Novec	2		
B834		Pressure Switch, 3 Pole Double Throw	1		
B835		Kidde 878752 Suppression Abort Station Control	1		
B836		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B837		Aegis Fire Releasing Panel	1		
B838		Ionization Smoke Detector	1		
B839		Photoelectric Smoke Detector	1		
B840		2WB Two Wire Standard Base Box	2		
B841		Multi Tone Alarm & 30 cd Strobe, 24 V	2		
B842		Multi Tone Alarm Back Box IOB-R	2		
B843		SPST Manual Release Station, 3300 Series	1		
B844		Manual Station Back Box, SGB-32S	1		
B845		Lead Acid Battery 12 VDC 7 AH	2		
<b>Novec 1230 Fire Suppression System in Electrical Room Block A</b>					
B846		200Lbs Cylinder Assembly 2" Valve Outlet Adapter 2" and Electric Control Head 24 VDC	1		
B847		Discharge Nozzle, Brass	2		
B848		Nameplate, "Warning", Novec	2		
B849		Pressure Switch, 3 Pole Double Throw	1		
B850		Kidde 878752 Suppression Abort Station Control	1		
B851		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B852		Aegis Fire Releasing Panel	1		
B853		Ionization Smoke Detector	2		
B854		Photoelectric Smoke Detector	2		
B855		2WB Two Wire Standard Base Box	4		
B856		Multi Tone Alarm & 30 cd Strobe, 24 V	2		

B857		Multi Tone Alarm Back Box IOB-R	2		
B858		SPST Manual Release Station, 3300 Series	1		
B859		Manual Station Back Box, SGB-32S	1		
B860		Lead Acid Battery 12 VDC 7 AH	2		
<b>Novec 1230 Fire Suppression System in Fuel Tank Room B1 Block B</b>					
B861		200Lbs Cylinder Assembly 2" Valve Outlet Adapter 2" and Electric Control Head 24 VDC	1		
B862		Discharge Nozzle, Brass	2		
B863		Nameplate, "Warning", Novac	2		
B864		Pressure Switch, 3 Pole Double Throw	1		
B865		Kidde 878752 Suppression Abort Station Control	1		
B866		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B867		Aegis Fire Releasing Panel	1		
B868		Ionization Smoke Detector	1		
B869		Photoelectric Smoke Detector	1		
B870		2WB Two Wire Standard Base Box	2		
B871		Multi Tone Alarm & 30 cd Strobe, 24 V	2		
B872		Multi Tone Alarm Back Box IOB-R	2		
B873		SPST Manual Release Station, 3300 Series	1		
B874		Manual Station Back Box, SGB-32S	1		
B875		Lead Acid Battery 12 VDC 7 AH	2		
<b>Block A - 2nd Floor - Server Room - Automatic fire suppression system with Ziton double knock control</b>					
B876		cylinder	1		
B877		pressure operated switch	1		
B878		detectors	2		
B879		extinguishing release button	1		
B880		control board	1		

Item	Part#	Manufacturer	Description	Estimated Qty	Confirmation on Availability	Warranty
<b>Aley Boiler Room - INDX Fire Suppression</b>						
C1	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C2	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C3	553461	ANSUL	Control head Replacement Tabs	1		

C4	435017	ANSUL	ECH-24 Control Head Electrical al,24V DC W/L/a ct	1		
C5	550853	ANSUL	MB-P2 mounting bracket control head	1		
C6	435264	ANSUL	Solenoid monitor 24VDC	1		
C7	551678	ANSUL	NF-ABC Nozzle with cap, Total floodline	2		
C8	551166	ANSUL	RPS-E2 Remote pull station Electrical	1		
C9	428661	ANSUL	Break road Package	1		
C10	550299	ANSUL	glass rods for RPS-E2	1		
C11	550527	ANSUL	RPS-M pull station back box	1		
C12	551157	ANSUL	Ms-4 PDT four switch	1		
C13	551059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C14	550077	ANSUL	Alarm initiations switch	1		
C15	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C16	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C17	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C18	13970	ANSUL	HEAT DET VERT N/O 302- EPM-194	2		
C19	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C20	INT-GB6- 24	Simplex	BELL 6 INCH 24VDC	1		
C21	4903-9427	Simplex	A/V 110CD RED STD NON-ADDRESSA	1		
<b>Aley Generator Room - INERGEN Fire Suppression System</b>						
C22	441026	ANSUL	Cylinder, Inergen, std 572 cuft with CV98 valve	3		
C23	427082	ANSUL	Flexible discharge bend 200 Bar	3		
C24	73327	ANSUL	Actuator electric HF	1		
C25	428949	ANSUL	Booster actuator	1		
C26	79639	ANSUL	back frame 3 cylinder	1		
C27	418502	ANSUL	Bolt and nut 13 in single row	2		
C28	73092	ANSUL	Cylinder, clamp-3 cylinder	1		
C29	416679	ANSUL	1 in orifice union Drill nb.2U64 Drill Dia 0.328"	1		

C30	417364	ANSUL	Nozzle inergen 1" ceiling type Drill nb. 2L/54 Drill Dia 0.328"	1		
C31	417364	ANSUL	Nozzle inergen 1" ceiling type Drill nb.27164 Drill Dia 0.348"	1		
C32	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C33	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C34	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C35	13970	ANSUL	VERTICAL RATE COMPENSATED THERMAL DETECTOR 190 Des F	4		
C36	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		
C37	2975-9178	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C38	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C39	INT-GB6.24	Simplex	BELL 5 INCH 24VDC	1		
C40	4903-9427	Simplex	A/V 110CD RED STD NON-ADDRESSA	1		
<b>Baalbeck - Boiler Room - INDX Fire Suppression</b>						
C41	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C42	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C43	553461	ANSUL	Control head Replacement Tabs	1		
C44	435017	ANSUL	ECH-24 Control head, Electrical,24VDC W/L/act	1		
C45	550853	ANSUL	MB-P2 mounting bracket control head	1		
C46	435264	ANSUL	Solenoid monitor 24 VDC	1		
C47	551678	ANSUL	NF-ABC Nozzle with cap, Total flooding	2		
C48	551166	ANSUL	RPS-E2 Remote pull station Electrical	1		
C49	428661	ANSUL	Break road Package	1		
C50	550299	ANSUL	glass rods for RPS-E2	1		
C51	550527	ANSUL	RPS-M pull station back box	1		
C52	551157	ANSUL	Ms-4 PDT four switch	1		

C53	551059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C54	550077	ANSUL	Alarm initiating switch	1		
C55	4004-9302	SIMPLEX	4004R RELEASE PNL RED	1		
C56	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		
C57	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		
C58	2080-9057	SIMPLEX	ABORT SWITCH, SURFACE	1		
C59	INT-GB6-24	SIMPLEX	BELL 6 INCH 24 VDC	1		
C60	4903-9427	SIMPLEX	A/V IIOCD RED STD NON-ADDRESSA	1		
C61	13970	ANSUL	VERTICAL RATE COMPENSATED THERMAL DETECTOR 190 Deg F	4		
<b>Bekfaya - Fuel Tank Room - INDX Fire Suppression</b>						
C62	435032		A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C63	550054		MB-15 Cylinder mounting Bracket	1		
C64	553461		Control head Replacement Tabs	1		
C65	435077		ECH-24 Control head Electrical	1		
C66	550853		MB-P2 mounting bracket control head 24VD C W I L act	1		
C67	435264		Solenoid monitor 24 VDC	1		
C68	551678		NF-ABC Nozzle with cap Total floodline	2		
C69	551166		RPS-E2 Remote pull station Electrical	1		
C70	428661		Break road Package	1		
C71	550299		glass rods for RPS-E2	1		
C72	551157		Ms-4 PDT four switch	1		
C73	551059		16 gramm carbon dioxide actuation cartridge	1		
C74	550077		Alarm initiations switch	1		
C75	4004-9302		4004R RELEASE PNL RED	1		
C76	2081-9045		2 AMP COIL SUPERVISORY MODULE	1		



C77	4004-9860		4PT AUXILIARY RELAY MODULE	1		
C78	4098-9601		Smoke Detector	2		
C79	4098-9788		Base	2		
C80	2080-9057		Abort Switch Surface	1		
C81	INT-GB5-24		BELL 5 INCH 24 VDC	1		
C82	4098-9501		Smoke Detector	2		
C83	4098-9788		Base	2		
C84	4903-9427		A/V 110CD RED STD NON-ADDRESSA	1		
<b>Bekfaya - Generators Room # 1 - INERGEN Fire Suppression System</b>						
C85	441026	Ansul	Cylinder Inergen, std 572 cuft with CV98 valve	2		
C86	427082	Ansul	Flexible discharge bend 200 Bar	2		
C87	73327	Ansul	Actuator electric HF	1		
C88	428949	Ansul	Booster actuator	1		
C89	79642	Ansul	Back frame cylinder	1		
C90	418502	Ansul	Bolt and nut 13 in single row	4		
C91	73091	Ansul	Cylinder clamp-2 cylinder	3		
C92	416580	Ansul	1"1/4 orifice union Drill Number 23164 - Drill Diameter 0.359"	3		
C93	4L7365	Ansul	L"1/4in Nozzle - Drill Number LI2-Drill Diameter 0.500"	1		
C94	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C95	BTT	Local	Batteries-12VDC-7AH	2		
C96	2081-9045	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C97	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C98	2099-9t49	Simplex	DBL ACT PP STN W/O LOGO	1		
C99	2975-9778	Simplex	BOX/ADDRESSABLE PU LL STATION	1		
C100	2080-9057	Simplex	ABORT SWITCH	1		
C101	INT-GB5-24	Simplex	BELL 6 INCH 24 VDC	1		

C102	2098-9489	Simplex	HEAT DET VERT N/O 3O2.EPM-194	2		
C103	4903-9427	Simplex	A/V 11OCD RED STD NON.ADDRESSA	1		
<b>Bekfaya - Generators Room # 2 - INERGEN Fire Suppression System</b>						
C104	441026	Ansul	Cylinder Inergen, std 572 cuft with CV98 valve	2		
C105	427082	Ansul	Flexible discharge bend 200 Bar	2		
C106	73327	Ansul	Actuator electric HF	1		
C107	428949	Ansul	Booster actuator	1		
C108	79642	Ansul	Back frame cylinder	1		
C109	418502	Ansul	Bolt and nut 13 in single row	4		
C110	73091	Ansul	Cylinder clamp-2 cylinder	3		
C111	416580	Ansul	1"1/4 orifice union Drill Number 23164 - Drill Diameter 0.359"	3		
C112	4L7365	Ansul	1"1/4in Nozzle - Drill Number LI2-Drill Diameter 0.500"	1		
C113	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C114	BTT	Local	Batteries-12VDC-7AH	2		
C115	2081-9045	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C116	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C117	2099-9t49	Simplex	DBL ACT PP STN W/O LOGO	1		
C118	2975-9778	Simplex	BOX/ADDRESSABLE PU LL STATION	1		
C119	2080-9057	Simplex	ABORT SWITCH	1		
C120	INT-GB5- 24	Simplex	BELL 6 INCH 24 VDC	1		
C121	2098-9489	Simplex	HEAT DET VERT N/O 3O2.EPM-194	2		
C122	4903-9427	Simplex	A/V 11OCD RED STD NON.ADDRESSA	1		
<b>Bekfaya - Electrical Room # 1 - INERGEN Fire Suppression System</b>						
C123	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	1		
C124	427082	Ansul	Flexible discharge bend 200 Bar	1		
C125	73327	Ansul	Actuator electric HF	1		
C126	428949	Ansul	Booster actuator	1		

C127	79642	Ansul	back frame 6 cylinder	1		
C128	418502	Ansul	Bolt and nut 13 in single row	4		
C129	73097	Ansul	Cylinder, clamp-2 cylinder	3		
C130	476678	Ansul	3/4" orifice union Drill Number L - Drill Diameter 0.228"	3		
C131	4L7363	Ansul	3/4" orifice union - Drill Number 1 - Drill Diameter 0.228"	1		
C132	4t7363	Ansul	3/4" orifice union - Drill Number 1- Drill Diameter 0.228"	1		
C133	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C134	2081-9045	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C135	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C136	4098-9601	Simplex	SSD PHOTO DETECTOR	2		
C137	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C138	2099-9L49	Simplex	DBL ACT PP STN WO LOGO	7		
C139	2975-9L78	Simplex	BOX/ADDRESSABLE PULL STATTON	1		
C140	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C141	INT-GB6-24	Simplex	BELL 6 INCH 24 VDC	1		
C142	4903-9427	Simplex	A/V 110CD RED STD NON-ADDRESSA	1		
<b>Bekfaya - Electrical Room # 2 - INERGEN Fire Suppression System</b>						
C143	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	1		
C144	427082	Ansul	Flexible discharge bend 200 Bar	1		
C145	73327	Ansul	Actuator electric HF	1		
C146	428949	Ansul	Booster actuator	1		
C147	79642	Ansul	back frame 6 cylinder	1		
C148	418502	Ansul	Bolt and nut 13 in single row	4		
C149	73097	Ansul	Cylinder, clamp-2 cylinder	3		

C150	476678	Ansul	3/4" orifice union Drill Number L - Drill Diameter 0.228"	3		
C151	4L7363	Ansul	3/4" orifice union - Drill Number 1 - Drill Diameter 0.228"	1		
C152	4t7363	Ansul	3/4" orifice union - Drill Number 1- Drill Diameter 0.228"	1		
C153	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C154	2081-9045	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C155	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C156	4098-9601	Simplex	SSD PHOTO DETECTOR	2		
C157	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C158	2099-9L49	Simplex	DBL ACT PP STN WO LOGO	7		
C159	2975-9L78	Simplex	BOX/ADDRESSABLE PULL STATTON	1		
C160	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C161	INT-GB6-24	Simplex	BELL 6 INCH 24 VDC	1		
C162	4903-9427	Simplex	A/V 110CD RED STD NON-ADDRESSA	1		
<b>Jounieh System1 Server Room</b>						
C163	570005		FM-200,tank 32 L,fill with 49 lbs)	1		
C164	N/A		Factory Fill (per lb)	49		
C165	570085		Container Bracket	2		
C166	570209		Removable Electric Solenoid,24 Volt	1		
C167	570141		1in Discharge hose and adaptor	1		
C168	570159		Discharge nozzle 1 in, brass 7 ports	1		
C169	57057		Discharge nozzle 1/2 in, brass 7 ports	2		
C170	570192		Entrance Warning Sign	1		
C171	570190		Manual Release Sign	1		
C172	570229		PCR-100 control system, red 240VAC	1		
C173			Battery 12 v 7 Ah	2		

C174	78996		Detector smoke ionization	6		
C175	417996		Base Model, B401 B	6		
C176	417805		Alarm bell 24 VDC 6 in	1		
C177	76494		Abort Switch , Surface mount	1		
C178	433357		Horn / Strobe Multi candella, Agent red	1		
C179	551167		Pull station dual action ,DPST	1		
C180	428660		Back Box Single Gang Surface mount	1		
<b>Jounieh System 2 UPS room</b>						
C181	570005		FM-200,tank 32 L,fill with 54 lbs)	1		
C182	N/A		Factory Fill (per lb)	54		
C183	570085		Container Bracket	2		
C184	570209		Removable Electric Solenoid,24 Volt	1		
C185	570141		1in Discharge hose and adaptor	1		
C186	570159		Discharge nozzle 1 in, brass 7 ports	1		
C187	57057		Discharge nozzle 1/2 in, brass 7 ports	2		
C188	570192		Entrance Warning Sign	1		
C189	570190		Manual Release Sign	1		
C190	570229		PCR-100 control system, red 240VAC	1		
C191			Battery 12 v 7 Ah	2		
C192	78996		Detector smoke ionization	6		
C193	417996		Base Model, B401 B	6		
C194	417805		Alarm bell 24 VDC 6 in	1		
C195	76494		Abort Switch , Surface mount	1		
C196	433357		Horn / Strobe Multi candella, Agent red	1		
C197	551167		Pull station dual action ,DPST	1		
C198	428660		Back Box Single Gang Surface mount	1		
<b>Jounieh - Electrical Room - INERGEN Fire Suppression System</b>						
C199	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	2		

C200	427082	Ansul	Flexible discharge bend 200 Bar	2		
C201	73327	Ansul	Actuator electric HF	1		
C202	428949	Ansul	Booster actuator	1		
C203	79639	Ansul	back frame 2 cylinder	1		
C204	418502	Ansul	Bolt and nut 13 in single row	1		
C205	73097	Ansul	Cylinder, clamp-2 cylinder	1		
C206	476679	Ansul	1in orifice union Drill nb. S Drill Dia.0.348"	1		
C207	417364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 37/64 Drill Dia 0.484"	1		
C208	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C209	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C210	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C211	4098-9601	Simplex	SSD PHOTO DETECTOR	2		
C212	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C213	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		
C214	2975-9778	Simplex	BOX/ADDRESSABLE PU LL STATION	1		
C215	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C216	INT-GB6- 24	Simplex	BELL 5 INCH 24 VDC	1		
C217	4903-9427	Simplex	w 110CD RED STD NON- ADDRESSA	1		
<b>Nabatieh - Fuel Tank Room - IND X Fire Suppression System</b>						
C218	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C219	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C220	553451	ANSUL	Control head Replacement Tabs	1		
C221	4350L7	ANSUL	ECH-24 control head electrical 24DC W/L/Act	1		
C222	550853	ANSUL	MB-P2 mounting bracket control head	1		
C223	435264	ANSUL	Solenoid monitor 24VDC	1		

C224	551678	ANSUL	NF-ABC Nozzle with cap, Total flooding	2		
C225	551166	ANSUL	RPS-E2 Remote pull station Electrical	1		
C226	42866t	ANSUL	Break road Package	1		
C227	550299	ANSUL	glass rods for RPS-E2	1		
C228	550527	ANSUL	RPS-M pull station back box	1		
C229	551157	ANSUL	Ms-4 PDT four switch	1		
C230	551059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C231	550077	ANSUL	Alarm initiations switch	1		
C232	4004-9302	SIMPLEX	4OO4R RELEASE PNL RED	1		
C233	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		
C234	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		
C235	2080-9057	SIMPLEX	ABORT SWITCH, SURFACE	1		
C236	INT-GB6- 24	SIMPLEX	BELL 6 INCH 24VDC	1		
C237	4903-9427	SIMPLEX	A/V 11OCD RED STD NON-ADDRESSA	1		
C238	4098-9601	SIMPLEX	Smoke Detector	2		
C239	4098-9788	SIMPLEX	Base Detector	2		
<b>Nabatieh - Generators Room - INERGEN Fire Suppression System</b>						
C240	441026	Ansul	Cylinder, inergen, std 572 cuft with CV98 valve	3		
C241	427082	Ansul	Flexible discharge bend 200 Bar	3		
C242	73327	Ansul	Actuator electric HF	1		
C243	428949	Ansul	Booster actuator	1		
C244	79639	Ansul	back frame cylinder	1		
C245	4L8502	Ansul	Bolt and nut 13 in single row	2		
C246	73092	Ansul	Cylinder, clamp-3 cylinder	1		
C247	416679	Ansul	1 in orifice union Drill nb.29/64 Drill Dia 0.453"	1		
C248	417364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 7 /16 Drill Dia	1		
C249	417364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 7 /16 Drill Dia	1		
C250	4004-9302	Simplex	4OO4R RELEASE PNL RED	1		

C251	2081-9045	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C252	4004-9850	Simplex	4PT AUXILIARY RELAY MODULE	1		
C253	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		
C254	2975-9t78	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C255	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C256	INT-GB6- 24	Simplex	BELL 6 INCH 24 VDC	1		
C257	4903-9427	Simplex	A/V 11OCD RED STD NON-ADDRESSA	1		
C258	73970	Ansul	VERTICAL RATE COMPENSATED THERMAL DETECTOR 190 Deg F	2		
<b>Saida - Boiler Room - IND X Fire Suppression System</b>						
C259	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C260	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C261	553461	ANSUL	Control head Replacement Tabs	1		
C262	4350L7	ANSUL	ECH-24 control head, El Electrical I, 24VDC W I	1		
C263	550853	ANSUL	MB-P2 mounting bracket control head	1		
C264	435264	ANSUL	Solenoid monitor 24 VDC	1		
C265	551678	ANSUL	NF-ABC Nozzle with cap, Total flooding	2		
C266	551166	ANSUL	RPS-E2 Remote pull station Electrical L/	1		
C267	428661	ANSUL	Break road Package	1		
C268	550299	ANSUL	glass rods for RPS-E2	1		
C269	550527	ANSUL	RPS-M pull station back box	1		
C270	551157	ANSUL	Ms-4 PDT four switch	1		
C271	5s1059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C272	ssoo77	ANSUL	Alarm initiating switch	1		
C273	4004-9302	SIMPLEX	4004R RELEASE PNL RED	1		
C274	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		



C275	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		
C276	2099-9149	SIMPLEX	DBL ACT PP STN WO LOGO	1		
C277	2975-9178	SIMPLEX	BOX/ADDRESSABLE PULL STATION	1		
C278	2080-90s7	SIMPLEX	ABORT SWITCH, SURFACE	1		
C279	INT-G86.24	SIMPLEX	BELL 6 INCH 24 VDC	1		
C280	4903-9427	SIMPLEX	A/V 11OCD RED STD NON-ADDRESSA	1		
C281	13970	Ansul	VERTICAL RATE COMPENSATED THERMAL DETECTOR 190 Des F	2		
<b>Saida - Fuel Tank Room - IND X Fire Suppression System</b>						
C282	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C283	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C284	553461	ANSUL	Control head Replacement Tabs	1		
C285	435017	ANSUL	ECH-24 Control head, Electrical,24VDC W / L/ act	1		
C286	550853	ANSUL	MB-P2 mounting bracket control head	1		
C287	435264	ANSUL	Solenoid monitor 24VDC	1		
C288	551678	ANSUL	NF-ABC Nozzle with cap, Total floodline	2		
C289	551166	ANSUL	RPS-E2 Remote pull station Electrical L/	1		
C290	428661	ANSUL	Break road Package	1		
C291	550299	ANSUL	glass rods for RPS-E2	1		
C292	550s27	ANSUL	RPS-M pull station back box	1		
C293	551157	ANSUL	Ms-4 PDT four switch	1		
C294	551059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C295	550077	ANSUL	Alarm initiating switch	1		
C296	4004-9302	SIMPLEX	4004R RELEASE PNL RED	1		
C297	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		
C298	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		

C299	2099-9L49	SIMPLEX	DBL ACT PP STN WO LOGO	1		
C300	2975-9178	SIMPLEX	BOX/ADDRESSABLE PULL STATION	1		
C301	2080-9057	SIMPLEX	ABORT SWITCH, SURFACE	1		
C302	INT-GB6-24	SIMPLEX	BELL 6 INCH 24VDC	1		
C303	4903-9427	SIMPLEX	A/V 11OCD RED STD NON-ADDRESSA	1		
C304	4098-9601	SIMPLEX	Smoke Detector	2		
C305	4098-9788	SIMPLEX	Base Detector	2		
<b>Sour Branch - Generators Room INERGEN Fire Suppression System</b>						
C306	447026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	3		
C307	427082	Ansul	Flexible discharge bend 200 Bar	3		
C308	73327	Ansul	Actuator electric HF	1		
C309	428949	Ansul	Booster actuator	1		
C310	79640	Ansul	back frame 4 cylinder	1		
C311	4L8502	Ansul	Bolt and nut 13 in single row	2		
C312	73091	Ansul	Cylinder, clamp-2 cylinder	2		
C313	416680	Ansul	1"7/4 orifice union Drill nb.37/64 Drill Dia 0.484"	1		
C314	4L7364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 75/32 Drill Dia	1		
C315	4L7364	Ansul	Nozzle inergen 1" ceiling type Drill nb. t5/32Drill Dia O	1		
C316	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C317	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C318	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE 0.468"l	1		
C319	2099-9149	Simplex	DBL ACT PP STN WO LOGO 46RrI	1		
C320	2975-9178	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C321	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C322	INT.GB5.24	Simplex	BELL 5 INCH 24VDC	1		
C323	4903-9427	Simplex	A/V 11OCD RED STD NON.ADDRESSA	1		

C324	13970	Ansul	VERTICAL RATE COMPENSATED THERMAL	4		
<b>Sour Branch - Electrical Room - INERGEN Fire Suppression System</b>						
C325	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	1		
C326	427082	Ansul	Flexible discharge bend 200 Bar	1		
C327	73327	Ansul	Actuator electric HF	1		
C328	428949	Ansul	Booster actuator	1		
C329	79640	Ansul	back frame 4 cylinder	1		
C330	418502	Ansul	Bolt and nut 13 in single row	2		
C331	73091	Ansul	Cylinder, clamp-2 cylinder	2		
C332	476679	Ansul	1" orifice union Drill nb. 1 Drill Dia 0.272"	1		
C333	477364	Ansul	Nozzle inergen L" ceiling type Drill nb. 44993 Drill Dia	1		
C334	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C335	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C336	4004-9850	Simplex	4PT AUXILIARY RELAY MODULE	1		
C337	4098-9601	Simplex	SSD PHOTO DETECTOR	2		
C338	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C339	2099-9L49	Simplex	DBL ACT PP STN WO LOGO	1		
C340	2975-9L78	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C341	2080-90s7	Simplex	ABORT SWITCH, SURFACE	1		
C342	INT-GB5-24	Simplex	BELL 6 INCH 24VDC	1		
C343	4903-9427	Simplex	A/V 110CD RED STD NON-ADDRESSA	1		
<b>Sour - Fuel Tank Room - IND X Fire Suppression</b>						
C344	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C345	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C346	553461	ANSUL	Control head Replacement Tabs	1		

C347	435017	ANSUL	ECH-24 control head electrical, 24VDC W	1		
C348	550853	ANSUL	MB-P2 mounting bracket control head	1		
C349	435264	ANSUL	Solenoid monitor 24VOC	1		
C350	551678	ANSUL	NF-ABC Nozzle with cap, Total flooding	2		
C351	551166	ANSUL	RPS-E2 Remote pull station Electrical /	1		
C352	428661	ANSUL	Break road Package	1		
C353	550299	ANSUL	glass rods for RPS-E2	1		
C354	550527	ANSUL	RPS-M pull station back box	1		
C355	551157	ANSUL	Ms-4 PDT four switch	1		
C356	551059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C357	550077	ANSUL	Alarm initiations switch	1		
C358	4004-9302	SIMPLEX	4OO4R RELEASE PNL RED	1		
C359	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		
C360	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		
C361	2080-9057	SIMPLEX	ABORT SWITCH, SURFACE	1		
C362	INT-GB6-24	SIMPLEX	BELL 6 INCH 24VDC	1		
C363	4903-9427	SIMPLEX	A/V 11OCD RED STD NON-ADDRESSA	1		
C364	4098-9601	SIMPLEX	Smoke Detector	2		
C365	4098-9788	SIMPLEX	Base Detector	2		
<b>Tripoli - Fuel Tank Room - IND X Fire Suppression</b>						
C366	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C367	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C368	553461	ANSUL	Control head Replacement Tabs	1		
C369	435017	ANSUL	ECH-24 Control head Electrical, 24VDC W	1		
C370	550853	ANSUL	MB-P2 mounting bracket control head	1		
C371	435264	ANSUL	Solenoid monitor 24VOC	1		
C372	551678	ANSUL	NF-ABC Nozzle with cap, Total flooding	2		

C373	551166	ANSUL	RPS-E2 Remote pull station Electrical /	1		
C374	428661	ANSUL	Break road Package	1		
C375	550299	ANSUL	glass rods for RPS-E2	1		
C376	550527	ANSUL	RPS-M pull station back box	1		
C377	551157	ANSUL	Ms-4 PDT four switch	1		
C378	551059	ANSUL	16 gram carbon dioxide actuation cartridge	1		
C379	550077	ANSUL	Alarm initiations switch	1		
C380	4004-9302	SIMPLEX	4OO4R RELEASE PNL RED	1		
C381	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		
C382	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		
C383	2080-9057	SIMPLEX	ABORT SWITCH, SURFACE	1		
C384	INT-GB6-24	SIMPLEX	BELL 6 INCH 24VDC	1		
C385	4903-9427	SIMPLEX	A/V 11OCD RED STD NON-ADDRESSA	1		
C386	4098-9601	SIMPLEX	Smoke Detector	2		
C387	4098-9788	SIMPLEX	Base Detector	2		
<b>Tripoli Branch - Electrical Room - INERGEN Fire Suppression System</b>						
C388	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	1		
C389	427082	Ansul	Flexible discharge bend 200 Bar	1		
C390	73327	Ansul	Actuator electric HF	1		
C391	428949	Ansul	Booster actuator	1		
C392	79639	Ansul	back frame 2 cylinder	1		
C393	418502	Ansul	Bolt and nut 13 in single row	2		
C394	73091	Ansul	Cylinder, clamp-2 cylinder	2		
C395	416680	Ansul	1 1/4 in orifice union Drill nb. S Drill Dia 0.348"	1		
C396	417355	Ansul	Nozzle inergen 1"1/4 ceiling type Drill nb.37/64 Drill Dia 0.348"	1		
C397	4004-9302	Simplex	4OO4R RELEASE PNL RED	1		
C398	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C399	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C400	4098-9601	Simplex	SSD PHOTO DETECTOR	2		

C401	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C402	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		
C403	2975-9178	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C404	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C405	INT-GB5-24	Simplex	BELL 6 INCH 24VDC	1		
C406	4903-9427	Simplex	A/V 11OCD RED STD NON-ADDRESSA	1		
<b>Zahle Branch - Generators Room - INERGEN Fire Suppression System</b>						
C407	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	3		
C408	427082	Ansul	Flexible discharge bend 200 Bar	3		
C409	73327	Ansul	Actuator electric HF	1		
C410	428949	Ansul	Booster actuator	1		
C411	79640	Ansul	back frame 4 cylinder	1		
C412	418502	Ansul	Bolt and nut 13 in single row	2		
C413	73091	Ansul	Cylinder, clamp-2 cylinder	2		
C414	416679	Ansul	1 in orifice union Drill nb.29/64 Drill Dia 0.453"	1		
C415	417364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 7 /16 Drill Dia	1		
C416	417364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 7 /16 Drill Dia	1		
C417	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C418	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C419	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C420	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		
C421	2975-9178	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C422	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C423	INT-GB6-24	Simplex	BELL 6 INCH 24 VDC	1		
C424	4903-9427	Simplex	A/V 11OCD RED STD NON-ADDRESSA	1		

C425	13970	Ansul	VERTICAL RATE COMPENSATED THERMAL DETECTOR 190 Deg F	2		
<b>Zahle Branch - Electrical Room INERGEN Fire Suppression System</b>						
C426	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	2		
C427	427082	Ansul	Flexible discharge bend 200 Bar	2		
C428	73327	Ansul	Actuator electric HF	1		
C429	428949	Ansul	Booster actuator	1		
C430	79640	Ansul	back frame 4 cylinder	1		
C431	418502	Ansul	Bolt and nut 13 in single row	1		
C432	73091	Ansul	Cylinder, clamp-2 cylinder	1		
C433	476678	Ansul	3/4in orifice union Drill nb. S Drill Dia.0.321"	1		
C434	417363	Ansul	Nozzle inergen 1" ceiling type Drill nb. 2 Drill Dia 0.316"	1		
C435	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C436	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C437	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C438	4098-9601	Simplex	SSD PHOTO DETECTOR	2		
C439	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C440	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		
C441	2975-9178	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C442	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C443	INT-GB6-24	Simplex	BELL 5 INCH 24 VDC	1		
C444	4903-9427	Simplex	w 110CD RED STD NON-ADDRESSA	1		
<b>Aley Server Room - FM200 System Components</b>						
C445			Control Panel	1		
C446			Smoke detector	6		
C447			Bell	1		
C448			Siren	1		
C449			Manual Release button	1		

C450		Abort button	1		
C451		Actuator	1		
C452		27L Cylinder Fill with 26KG Agent	1		
<b>Aley UPS Room - FM200 System Components</b>					
C453		Control Panel	1		
C454		Smoke detector	2		
C455		Bell	1		
C456		Siren	1		
C457		Manual Release button	1		
C458		Abort button	1		
C459		Actuator	1		
C460		27L Cylinder Fill with 24KG Agent	1		
<b>Baalbeck Server Room - FM200 System Components</b>					
C461		Control Panel	1		
C462		Smoke detector	6		
C463		Bell	1		
C464		Siren	1		
C465		Manual Release button	1		
C466		Abort button	1		
C467		Actuator	1		
C468		44L Cylinder Fill with 37.5KG Agent	1		
<b>Baalbeck UPS Room - FM200 System Components</b>					
C469		Control Panel	1		
C470		Smoke detector	4		
C471		Bell	1		
C472		Siren	1		
C473		Manual Release button	1		
C474		Abort button	1		
C475		Actuator	1		
C476		44L Cylinder Fill with 36.5KG Agent	1		
<b>Bekfaya Server Room - FM200 System Components</b>					
C477		Control Panel	1		
C478		Smoke detector	6		
C479		Bell	1		
C480		Siren	1		
C481		Manual Release button	1		
C482		Abort button	1		
C483		Actuator	1		
C484		27L Cylinder Fill with 25.5KG Agent	1		



Bekfaya UPS Room - FM200 System Components					
C485			Control Panel	1	
C486			Smoke detector	2	
C487			Bell	1	
C488			Siren	1	
C489			Manual Release button	1	
C490			Abort button	1	
C491			Actuator	1	
C492			27L Cylinder Fill with 24KG Agent	1	
Nabatieh Server Room - FM200 System Components					
C493			Control Panel	1	
C494			Smoke detector	6	
C495			Bell	1	
C496			Siren	1	
C497			Manual Release button	1	
C498			Abort button	1	
C499			Actuator	1	
C500			38L Cylinder Fill with 34KG Agent	1	
Nabatieh UPS Room - FM200 System Components					
C501			Control Panel	1	
C502			Smoke detector	2	
C503			Bell	1	
C504			Siren	1	
C505			Manual Release button	1	
C506			Abort button	1	
C507			Actuator	1	
C508			15L Cylinder Fill with 10KG Agent	1	
Saida Server Room - FM200 System Components					
C509			Control Panel	1	
C510			Smoke detector	6	
C511			Bell	1	
C512			Siren	1	
C513			Manual Release button	1	
C514			Abort button	1	
C515			Actuator	1	
C516			27L Cylinder Fill with 21KG Agent	1	
Saida UPS Room - FM200 System Components					
C517			Control Panel	1	
C518			Smoke detector	2	
C519			Bell	1	

C520		Siren	1		
C521		Manual Release button	1		
C522		Abort button	1		
C523		Actuator	1		
C524		27L Cylinder Fill with 21KG Agent	1		
<b>Tripoli Server Room - FM200 System Components</b>					
C525		Control Panel	1		
C526		Smoke detector	6		
C527		Bell	1		
C528		Siren	1		
C529		Manual Release button	1		
C530		Abort button	1		
C531		Actuator	1		
C532		27L Cylinder Fill with 29KG Agent	1		
<b>Tripoli UPS Room - FM200 System Components</b>					
C533		Control Panel	1		
C534		Smoke detector	2		
C535		Bell	1		
C536		Siren	1		
C537		Manual Release button	1		
C538		Abort button	1		
C539		Actuator	1		
C540		15L Cylinder Fill with 15KG Agent	1		
<b>Tyr Server Room - FM200 System Components</b>					
C541		Control Panel	1		
C542		Smoke detector	6		
C543		Bell	1		
C544		Siren	1		
C545		Manual Release button	1		
C546		Abort button	1		
C547		Actuator	1		
C548		44L Cylinder Fill with 35KG Agent	1		
<b>Tyr UPS Room - FM200 System Components</b>					
C549		Control Panel	1		
C550		Smoke detector	2		
C551		Bell	1		
C552		Siren	1		
C553		Manual Release button	1		
C554		Abort button	1		
C555		Actuator	1		

C556			27L Cylinder Fill with 19KG Agent	1		
<b>Zahle Server Room - FM200 System Components</b>						
C557			Control Panel	1		
C558			Smoke detector	6		
C559			Bell	1		
C560			Siren	1		
C561			Manual Release button	1		
C562			Abort button	1		
C563			Actuator	1		
C564			44L Cylinder Fill with 49KG Agent	1		
<b>Zahle UPS Room - FM200 System Components</b>						
C565			Control Panel	1		
C566			Smoke detector	4		
C567			Bell	1		
C568			Siren	1		
C569			Manual Release button	1		
C570			Abort button	1		
C571			Actuator	1		
C572			44L Cylinder Fill with 28KG Agent	1		

Item	Part #	Item	Estimated Qty	Confirmation on Availability	Warranty
<b>Firefighting Equipment in Bloc B&amp;E</b>					
D1	Fire Hose Rack Cabinet C/W:	Steel fire cabinet, Recessed type, Single compartment.	36		
D2		Fire Hose Rack			
D3		2.5" Pressure Restricting angle Valve			
D4		2.5" x 1.5" Brass Adapter			
D5		1.5" Brass Coupling			
D6		1.5" x 100 ft Synthetic Fire Hose			
D7		1.5" Brass nozzle.			
D8	4" Zone control valve c/w	4" Fire - indicated butterfly valve with tamper switch	30		
D9		4" Water flow detector			
D10		2" Test and drain module			
D11		Pressure gauge			
D12	4" double interlock preaction	4" Butterfly valve with tamper switch	1		
D13		4" Deluge valve			

D14	valve station c/w	Variable trim with solenoid valve 24 vdc and low pressure valve			
D15		Water alarm pressure switch			
D16		Low pressure switch			
D17		Smoke detector			
D18		Air compressor			
D19		Sprinklers			
D20	6" Alarm check valve station c/w	6" Alarm check valve	1		
D21		Retarding chamber			
D22		Variable trim			
D23		Water motor alarm gong			
D24		Alarm pressure switch			
D25	misc	Sprinkler System in 15 floors in Block E and 15 floors in Block B	1		
D26		6" x 2 1/2' x 2 1/2" Siamese connection	2		
D27		Electrical Pump 500 GPM / 12 bar	2		
D28		Jockey Pump	1		

## المُلحق رقم (٢)

### كتاب التعهد

#### FORM OF TENDER

..... الموضوع: مشروع  
..... ("الإلتزام")

..... أنا الموقع أدناه  
..... مقيم في  
.....

أصّرّح :

1. عن رغبتني في الإشتراك بإستدراج العروض المتعلقة بالإلتزام، وأصّرّح كذلك بأنني أطلعت على الشّروط والمواصفات الموضوعية للإلتزام لا سيما دفتر الشروط الخاص ولائحة الشروط الفنية ودفتر الشروط العام.
2. أنني قُمت بالدرّس المُفصّل لجميع ظروف العمل ولحظت ذلك في وضع لائحة الأسعار المقدّمة مني لتنفيذ الإلتزام.

وأتعهدّ في حال إرساء الإلتزام عليّ:

1. أن أقوم بتنفيذ الموجبات موضوع الإلتزام المذكور بالمدة المحدّدة وفقاً للشّروط المفروضة وللمواصفات المطلوبة من قبل مصرف لبنان بالاسعار الافرادية المحدّدة من قبلي في العرض بدون أيّ تعديل لأية جهة كانت ولأيّ سبب كان بإستثناء ما قد ينص عليه العقد الذي سأوقعه مع مصرف لبنان.

٢. أن أنجز بصدق واستقامة وعلى كامل مسؤوليتي لحساب مصرف لبنان الإلتزام المطلوب.

وأقرّ بأنّي ألتزم دون أيّ قيد أو تحفّظ بالشّروط العامّة والخاصّة العائدة للإلتزام وبالمواصفات وبالاسعار المقدّمة من قبلي وبمستندات الإلتزام ولا يحقّ لي الإدعاء بالجهل.

التاريخ

ختم وتوقيع العارض

طابع مالي

٥٠,٠٠٠ ل.ل.

المُلحق رقم (٣)  
تصريح النزاهة

عنوان التلزم: \_\_\_\_\_  
الجهة المتعاقدة: \_\_\_\_\_  
اسم العارض / المفوض بالتوقيع عن الشركة: \_\_\_\_\_  
إسم الشركة: \_\_\_\_\_

نحن الموقعون أدناه نؤكد ما يلي:

1. ليس لنا، أو لموظفينا، أو شركائنا، أو وكلائنا، أو المساهمين، أو المستشارين، أو أقاربهم، أي علاقات قد تؤدي إلى تضارب في المصالح بموضوع هذا التلزم.
2. سنقوم بإبلاغ هيئة الشراء العام والجهة المتعاقدة في حال حصول أو اكتشاف تضارب في المصالح.
3. لم ولن نقوم، ولا أي من موظفينا، أو شركائنا، أو وكلائنا، أو المساهمين، أو المستشارين، أو أقاربهم، بممارسات احتيالية أو فاسدة، أو قسرية أو مُعرقلة في ما يخص عرضنا أو اقتراحنا.
4. لم نقدم، ولا أي من شركائنا، أو وكلائنا، أو المساهمين، أو المستشارين، أو أقاربهم، على دفع أي مبالغ للعاملين، أو الشركاء، أو للموظفين المشاركين بعملية الشراء بالنيابة عن الجهة المتعاقدة، أو لأي كان.
5. في حال مخالفتنا لهذا التصريح والتعهد، لن نكون مؤهلين للمشاركة في أي تلزم عمومي أياً كان موضوعه ونقبل سلفاً بأي تدبير إقصاء يُؤخذ بحقنا ونتعهد بملء إرادتنا بعدم المنازعة بشأنه.  
إن أي معلومات كاذبة تُعرضنا للملاحقة القضائية من قبل المراجع المختصة.

التاريخ: \_\_\_\_\_

الختم والتوقيع

## المُلحق رقم (٤)

### نموذج كتاب ضمان

### جانب مصرف لبنان

الموضوع: كتاب ضمان لصالحكم بناء للأمر السيد .....

جدية اشتراك الأمر  
يضمن حسن قيام الأمر بتعهداته  
ضمان تسديد الأمر للسلفة

في العقد المتعلق بمشروع ..... مركزه .....، الممثل بالسيد ..... الموقع عنه أدناه وذلك بصفته  
إن مصرف ..... وبناء للأمر السيد ..... (أو السادة ..... أو  
الشركة .....)، يتعهد بصورة نهائية غير قابلة للنقض  
أو للرجوع عنها بأن يدفع نقداً وفوراً بالدولار الأميركي تبعاً لكيفية التسديد المفصلة في العقد دون أي قيد أو شرط أي مبلغ تطالبونه  
به حتى حدود ..... وذلك عند أول طلب منكم بموجب كتاب صادر وموقع منكم دون أي موجب لبيان  
أسباب هذه المطالبة.

وعليه يقر مصرفنا صراحة بأن كتاب الضمان هذا قائم بذاته ومستقل كلياً عن أي إرتباط أو عقد بينكم  
وبين الأمر السيد ..... (أو السادة ..... أو الشركة .....) وبأنه  
لا يحق لمصرفنا في أي حال من الأحوال ولا في أي وقت كان ان يتذرع بأي سبب مهما كان نوعه  
أو شأنه أو أن يدلي بأية دفوع من أجل الإمتناع أو تأجيل تأدية أي مبلغ قد تطالبوننا به بالاستناد إلى كتاب الضمان هذا. كما يتنازل  
مصرفنا مسبقاً عن أي حق في المناقشة أو في الاعتراض على طلب الدفع  
الذي يصدر عنكم أو عن أي مسؤول لديكم، أو حتى ان يقبل أي اعتراض قد يصدر عن السيد ..... (أو  
السادة ..... أو الشركة .....) عن غيره  
(أو غيرهم أو غيرها) بشأن دفع المبلغ إليكم بناء لطلبكم.  
يبقى كتاب الضمان هذا معمولاً به لغاية ..... وبنهاية هذه المهلة يتجدد مفعوله تلقائياً  
إلى أن تعيدوه إلينا أو إلى أن تبلغونا خطياً إعفاءنا منه.

إن كل قيمة تدفع من مصرفنا بالإستناد إلى كتاب الضمان هذا بناء لطلبكم، يخفض المبلغ الأقصى المحدد فيه بذات المقدار.  
يخضع كتاب الضمان هذا للقوانين اللبنانية ولصلاحيات المحاكم المختصة في لبنان. وتنفيذاً منا  
لهذا الموجب نتخذ لنا محل إقامة في مركز مؤسستنا في .....

المكان والتاريخ  
الصفة  
الإسم  
التوقيع  
ختم المصرف

المُلحق رقم (٥)

لوائح الأسعار والكشف بالكميات

Fire Suppression Maintenance at BDL					
Item	Description	Unit	Qty	Unit Price	Total Price In USD
	<p>* Yearly maintenance contract for fire suppression systems.            * Preventive visits number for all systems is set to once per month (12 visits per year).            * Preventive visits number for fire extinguishers is set to once per year.            * Unlimited corrective visits should be conducted by Bidders based on call from BDL within 24 hours.</p> <p><b>Fire Extinguishers:</b>            1 Check pressure valve and replace if needed            2 Check hose and replace if needed            3 Replace rubber seal            4 Refill extinguisher with proper Gas            5 Check physical condition of Fire Extinguisher and report if needed to be replaced            6 List of Extinguishers is listed in Annex 1 attached to this BOQ</p> <p><b>High Pressure CO2 System:</b>            1 Survey the hazard to make certain it has not changed from what the system was designed.            2 Check all nozzles to make certain they are in place. That the orifice plates are in place and with the proper orifice.            3 Check the condition of the piping.            4 Check all warning nameplates.            5 Check all cylinders bracketing.            6 Check condition of all cylinder discharge hoses.</p> <p><b>FM200 System</b>            1 Survey the hazard to make certain it has not changed from what the system was designed.            2 Check all nozzles to make certain they are in place. That the orifice plates are in place and with the proper orifice.            3 Check the condition of the piping.            4 Check all warning nameplates.            5 Check all cylinders bracketing.            6 Check condition of all cylinder discharge hoses.            7 Check proper programming &amp; test.</p>				



<p><b><u>Inergen System</u></b>1 Survey the hazard to make certain it has not changed from what the system was designed.2 Check all nozzles to make certain they are in place. That the orifice plates are in place and with the proper orifice.3 Check the condition of the piping.4 Check all warning nameplates.5 Check all cylinders bracketing.6 Check condition of all cylinder discharge hoses.7 Check proper programming &amp; test.</p>				
<p><b><u>Novec System</u></b> 1 Survey the hazard to make certain it has not changed from what the system was designed. 2 Check all nozzles to make certain they are in place. That the orifice plates are in place and with the proper orifice. 3 Check the condition of the piping. 4 Check all warning nameplates. 5 Check all cylinders bracketing. 6 Check condition of all cylinder discharge hoses. 7 Check proper programming &amp; test.</p>				
<p><b><u>Dry Chemical System</u></b> 1 Survey the hazard to make certain it has not changed from what the system was designed. 2 Check all nozzles to make certain they are in place. That the orifice plates are in place and with the proper orifice. 3 Check the condition of the piping. 4 Check all warning nameplates. 5 Check all cylinders bracketing. 6 Check condition of all cylinder discharge hoses. 7 Check proper programming &amp; test.</p>				
<p>* For Spare parts and equipment refer to the attached Assets lists. * Bidders are required to price unit rates for spare parts as per the attached lists to the BOQ. * Bidders are required to submit a Service Report for each maintenance visit (Preventive &amp; Corrective). * Bidders should provide BDL with an updated schedule of equipment during their last preventive visit of the year. * Bidders should provide BDL with a maintenance check-list routine for each type of equipment at each preventive visit. * Bidders foreign employees and staff should have a valid residency &amp; Work permits.</p>				
<p><b><u>Special Terms</u></b>1- Bidders should ensure that all special equipment, tools and logistics are included within the price.2- All material needed for conducting the preventive maintenance routine should be included within the price.3- BDL has the right to award the BOQ to several bidders.</p>				

A	Portable Fire Extinguishers	LS	1		
B	Fire Suppression Hamra (Pricing of Maintenance Service to cover systems listed in Batch 1 based on routine stated above)	LS	1		
C	Fire Suppression per Branch (Pricing of Maintenance Service to cover systems listed in Batch 2 based on routine stated above)				
C1	Aley Branch	LS	1		
C2	Baalbeck Branch	LS	1		
C3	Bekfaya Branch	LS	1		
C4	Jounieh Branch	LS	1		
C5	Nabatiye Branch	LS	1		
C6	Saida Branch	LS	1		
C7	Sour Branch	LS	1		
C8	Tripoli Branch	LS	1		
C9	Zahle Branch	LS	1		
D	Fire Fighting Systems Pricing of Maintenance Service to cover systems listed in Batch 3 based on routine stated above)	LS	1		
	Sub-Total				
	VAT				
	<b>Total TTC</b>				
	<b>Total over 2 years</b>				
	<b>Total Amount in wordings</b>				
	<b>BDL Payment Terms</b>	<p><b>BDL will settle the amount of Cash USD in Cash LBP banknotes based on Sayrafa rate in addition to a margin calculated by BDL (in percent %), on the date of each payment, if needed. The determination of the margin will be based on the fluctuation of the exchange rates of the Lebanese pound versus the US dollar if existent.</b></p> <p>يسدد مصرف لبنان المستحقات المسعرة بالدولار الأميركي نقداً بالليرة اللبنانية على أساس سعر منصة صيرفة مضافاً إليها، إن وجب ذلك، تراعى فيه، في حينه، الفروقات المتعددة (%هامشاً هامشاً نسبي لتسعير الليرة اللبنانية مقابل الدولار الأميركي في حال توفرها. يتم تحديد الهامش من قبل مصرف لبنان بتاريخ تسديد كل دفعة لإحتساب قيمتها النهائية.</p>			

**Annex 1 to BOQ  
Fire Extinguishers Pricing**

Item	Location	Item	Weight (KG)	Qty	Unit Price In USD	Total Price In USD
A1	Hamra	Powder Portable Fire Extinguisher	6	104		
A2	Hamra	Fire Extinguisher	6	72		
A3	Hamra	Powder Portable Fire Extinguisher	50	1		
A4	Hamra	Powder Portable Fire Extinguisher	30	2		
A5	Aley	Powder Portable Fire Extinguisher	6	10		
A6	Aley	Powder Fire Extinguisher	12	6		
A7	Aley	CO2 Portable Fire Extinguisher	5	2		
A8	Baalbeck	Powder Portable Fire Extinguisher	6	8		
A9	Baalbeck	Fire Extinguisher	6	15		
A10	Zahle	Powder Portable Fire Extinguisher	6	13		
A11	Zahle	Powder Portable Fire Extinguisher	12	1		
A12	Zahle	Fire Extinguisher	12	8		
A13	Zahle	CO2 Portable Fire Extinguisher	5	3		
A14	Nabatiye	Powder Portable Fire Extinguisher	6	17		
A15	Sour	Powder Portable Fire Extinguisher	6	23		
A16	Sour	CO2 Portable Fire Extinguisher	5	5		
A17	Saida	Powder Portable Fire Extinguisher	6	5		
A18	Saida	CO2 Portable Fire Extinguisher	5	4		
A19	Saida	Fire Extinguisher	6	13		
A20	Saida	Fire Extinguisher	12	22		
A21	Saida	Powder Portable Fire Extinguisher	12	28		
A22	Saida	Powder Portable Fire Extinguisher	50	2		
A23	Bekfaya	Powder Portable Fire Extinguisher	6	10		
A24	Bekfaya	Fire Extinguisher	12	8		
A25	Jounieh	Fire Extinguisher	12	3		
A26	Jounieh	Powder Portable Fire Extinguisher	12	2		
A27	Jounieh	Powder Portable Fire Extinguisher	9	10		
A28	Jounieh	Powder Portable Fire Extinguisher	6	6		
A29	Jounieh	CO2 Portable Fire Extinguisher	5	2		
A30	Tripoli	Powder Portable Fire Extinguisher	6	10		
A31	Tripoli	Powder Portable Fire Extinguisher	8	4		
A32	Tripoli	CO2 Portable Fire Extinguisher	3	5		

**Spare Parts Pricing per System**

**Batch 1**

Item	Part #	Item	Expected Qty	Unit price in USD	Total Price in USD
<b>Hamra Block C - Generator Room</b>					
B1		Flexible Discharge Bend	44		
B2		CV98 Electric Actuator	4		
B3		CV98 Lever Release Actuator	4		
B4		Odorizer 1"	1		
B5		Header vent plug	2		
B6		Pressure switch DPST	1		
B7		Pressure trip with Manual pull	1		
B8		4" Multi-Discharge nozzle, 8.0 orifice	2		
B9		4" Multi-Discharge nozzle, 8.5 orifice	4		
B10		4" Multi-Discharge nozzle, 9.0 orifice	4		
B11		4" Multi-Discharge nozzle, 9.5 orifice	5		
B12		4" Multi-Discharge nozzle, 10.0 orifice	3		
B13		4" Multi-Discharge nozzle, 10.5 orifice	2		
B14		Weigh rail support - Double row	6		
B15		Connector	4		
B16		26" bolt with nut	14		
B17		3 cylinder clamp	6		
B18		2 cylinder clamp	2		
B19		Bracket foot right - Double row	2		
B20		Bracket foot left - Double row	2		
B21		Centre foot	2		
B22		Soale	1		
B23		Lifting Yoke	1		
B24		Nameplate - Maintenance	1		
B25		Warning plate - Inside	1		
B26		Warning plate - Outside	1		
B27		Nameplate - Main	1		
B28		Nameplate - Reserve	1		
B29		2 1/2" check valve	2		
B30		Abort switch	1		
B31		Auto-pulse 442R control panel	1		
B32		Battery Pack	1		
B33		4xZM Zone relay module	1		
B34		Heat detectors c/w bases	12		
B35		Nameplate "Pull to activate fire suppression System"	1		
B36		Strobe	2		

B37		6" Alarm Bell	2		
B38		Selector Switch	1		
B39		Connecting Link	2		
<b>CO2 System Generator Room</b>					
B40	426613	100 # co2 cylinder, red enamel,.W/CV98 valve	12		
B41	73327	Actuator electric HF	1		
B42	428949	Booster actuator	1		
B43	427082	Flexible discharge bend for CV 98 valve	12		
B44	426120	Baffle nozzle, 1/2"	6		
B45	79642	Cylinder back frame 6 cylinder	2		
B46	73255	Bolt & Nut,26 " double row,100lb cylinder	4		
B47	73092	Cylinder clamp-3 cylinder	2		
B48	425310	Warning sign - Do not enter	1		
B49	71682	Weigh rail support - double Row	2		
B50	73270	Weigh rail 6 cylinders	2		
B51	426592	Upright	2		
B52	73556	Bracket foot - Right side double row	1		
B53	73555	Bracket foot - left side	1		
B54	74241	Weigh Scale	1		
B55	69877	Weigh lifting yoke	1		
B56	430525	Autopulse Z-10 Control System, Red 240V AC	1		
B57		Battery 12 v 7 Ah	2		
B58	431196	Abort Supervision Module	1		
B59	430687	Coil Supervision Module ( Release Circuit )	1		
B60	430529	4-PT Auxiliary Relay Module	2		
B61		Mimic panel with LED's and driver	1		
B62	13970	Detector Heat Rate Compensated, 190deg F,W base	6		
B63	417805	Alarm bell 24 VDC 6 in	1		
B64	76494	Abort Switch , Surface mount	1		
B65	433356	Horn / Strobe Multi candella, Fire red	1		
B66	551166	Pull station dual action ,SPST	1		
B67	428660	Back Box Single Gang Surface mount	1		
<b>FM200 System Electrical room</b>					
B68	570007	FM-200,tank 106 L,fill with (217 lbs)	2		
B69	N/A	Factory Fill (per lb)	434		
B70	570092	Container Bracket	4		
B71	570209	Removable Electric Solenoid,24 Volt	4		
B72	570142	2in Discharge hose and adaptor	2		
B73	570121	Check valve Flanged 2	2		
B74	570144	Manifold Inlet Flanged for 3/4 Manifold 2 Check valve	2		
B75	570162	Discharge nozzle 2 in, brass 7ports	2		

B76	570059	Switch low pressure	2		
B77	570192	Entrance Warning Sign	1		
B78	570190	Manual Release Sign	1		
B79	430525	Autopulse Z-10 Control system Red,240 VAC	1		
B80		Battery 12 v, 7 Ah	2		
B81	431196	Abort Supervision Module	1		
B82	430687	Coil supersion Module( release circuit )	1		
B83	430529	4-pt Auxiliary Relay Module	2		
B84	435356	LED Driver, with mimic panel	1		
B85	430559	Detector smoke photoelectric 2.8% ULI	4		
B86	430567	2 wire base with LED driver ULI	4		
B87	417805	Alarm bell 24 VDC 6 in	1		
B88	76494	Abort Switch , Surface mount	1		
B89	433356	Horn / Strobe Multi candella, Fire red	1		
B90	551166	Pull station dual action ,SPST	1		
B91	428660	Back Box Single Gang Surface mount	1		
B92	76496	switch, Main/ Reserve, Surface mount	1		
<b>UPS Room &amp; Batteries - SITI Block A</b>					
B93	430952	Cylinder, Inergen, std 572 cuft with CV98 valve	3		
B94	427082	Flexible discharge bend 200 Bar	3		
B95	73327	Actuator electric HF	1		
B96	428949	Booster actuator	1		
B97	79638	Back Frame 2 cylinder	1		
B98	418502	Bolt and nut 13 in single Row	1		
B99	73091	Cylinder, clamp-2 cylinder	1		
B100	416679	1 in orifice union	1		
B101	416266	Warning plate outside room without alarm	1		
B102	416265	Warning plate outside room with alarm	1		
B103	426142	1" NPT 180 degree Nozzle Inergen side wall	1		
B104	430539	Autopulse Z-28 Control system, 240 VAC	1		
B105	417694	Battery Pack, 18 AH, 24 VDC( 2-12VDC Batteries)	1		
B106	431193	Sup Release Peripheral & Enclosure	1		
B107	430687	Coil Supervision Module( Release circuit)	1		
B108	430660	Supervised IAM	2		
B109	930663	IAM Mounting Bracket	2		
B110	430664	Relay IAM	4		
B111	430631	Photo Sensor ULI Smoke detector	2		
B112	430636	Standard Sensor Base ULI	2		
B113	76498	Maintenance Switch, surface mount	1		
B114	76494	Abort Switch surface mount	1		
B115	430671	Dual action Push/ Pull addressable	1		
B116	430597	Surface back box red	1		

B117	430594	Namplate, pull station	1		
B118	430599	Replacement Break- Rod	5		
B119	433356	Alarm, Horn/ strobe multi candela, Fire red	1		
B120	417805	Alarm, Bell 24 VDC,6 in	1		
B121	430631	Photo Sensor ULI Smoke detector	4		
B122	430636	Standard Sensor Base ULI	4		
B123	426142	1" NPT 180 degree Nozzle Inergen side wall	1		
B124	427092	Replacement Valve, CV98	1		
<b>Data Server Room ( Main cylinders ) – System2</b>					
B125	430952	Cylinder, Inergen, std 572 cuft with CV98 valve	11		
B126	427082	Flexible discharge bend 200 Bar	11		
B127	73327	Actuator electric HF	1		
B128	428949	Booster actuator	1		
B129	79641	Back Frame 5 cylinder	1		
B130	79642	Back Frame 6 cylinder	1		
B131	418503	Bolt and nut 27 in double row	7		
B132	73092	Cylinder, clamp-3 cylinder	3		
B133	73091	Cylinder, clamp-2 cylinder	1		
B134	879413	connector	1		
B135	32336	actuation Hose, swivel stainless Braided 24"	1		
B136	32334	Male elbow	2		
B137	73236	pilot valve actuation adaptor	2		
B138	416682	2 in orifice union	1		
B139	41942	Nameplate , Main	1		
B140	416266	Warning plate outside room without alarm	1		
B141	416265	Warning plate outside room with alarm	1		
B142	417365	11/4" NPT 180 degree Nozzle Inergen side wall	2		
B143	417362	1/2" NPT 180 degree Nozzle Inergen side wall	2		
B144	430620	Suppression Power supply Kit, 240 V	1		
B145		Battery 12 V,7 Ah	2		
B146	430617	Battery Meter module	1		
B147	431193	Sup Release Peripheral & Enclosure	1		
B148	430687	Coil Supervision Module ( Release circuit)	1		
B149	430660	Supervised IAM	2		
B150	930663	IAM Mounting Bracket	2		
B151	430664	Relay IAM	6		
B152	430628	LCD Annunciator	1		
B153	430629	LCD Annunciator Box , Surface	1		
B154	430631	Photo Sensor ULI Smoke detector	22		
B155	430636	Standard Sensor Base ULI	22		

B156	76498	Maintenance Switch, surface mount	1		
B157	76494	Abort Switch surface mount	1		
B158	430671	Dual action Push/ Pull addressable	1		
B159	430597	Surface back box red	1		
B160	430594	Namplate, pull station	1		
B161	430599	Replacement Break- Rod	5		
B162	433356	Alarm, Horn/ strobe multi candela, Fire red	1		
B163	417805	Alarm, Bell 24 VDC,6 in	1		
B164	430631	Photo Sensor ULI Smoke detector	5		
B165	430636	Standard Sensor Base ULI	5		
B166	417365	11/4" NPT 180 degree Nozzle Inergen side wall	1		
B167	417362	1/2" NPT 180 degree Nozzle Inergen side wall	1		
B168	427092	Replacement Valve, CV98	1		
<b>Data Server Room Future expansion – System 3</b>					
B169					
B170					
B171	73327	Actuator electric HF	3		
B172	428949	Booster actuator	3		
B173	416682	2 in orifice union	1		
B174	427150	2" Selector valve	2		
B175	416266	Warning plate outside room without alarm	1		
B176	416265	Warning plate outside room with alarm	1		
B177	417365	11/4" NPT 180 degree Nozzle Inergen side wall	2		
B178	417362	1/2" NPT 180 degree Nozzle Inergen side wall	2		
B179	430675	Autopulse Ext. Panel , 240 VAC Red	1		
B180	430676	4 pt NAC Expansion Card	1		
B181		Battery 12 V,7 Ah	2		
B182	431193	Sup Release Peripheral & Enclosure	1		
B183	430687	Coil Supervision Module ( Release circuit)	1		
B184	430660	Supervised IAM	2		
B185	930663	IAM Mounting Bracket	2		
B186	430664	Relay IAM	6		
B187	430631	Photo Sensor ULI Smoke detector	20		
B188	430636	Standard Sensor Base ULI	20		
B189	76498	Maintenance Switch, surface mount	1		
B190	76494	Abort Switch surface mount	1		
B191	430671	Dual action Push/ Pull addressable	1		
B192	430597	Surface back box red	1		
B193	430594	Namplate, pull station	1		
B194	430599	Replacement Break- Rod	5		



B195	433356	Alarm, Horn/ strobe multi candela, Fire red	1		
B196	417805	Alarm, Bell 24 VDC,6 in	1		
B197	430631	Photo Sensor ULI Smoke detector	4		
B198	430636	Standard Sensor Base ULI	4		
B199	417365	11/4" NPT 180 degree Nozzle Inergen side wall	1		
B200	417362	1/2" NPT 180 degree Nozzle Inergen side wall	1		
<b>Inergen systems, Vault 1- Zone 1,( Main )</b>					
B201	73327	Actuator electric HF	2		
B202	428949	Booster actuator	2		
B203	32336	actuation Hose, swivel stainless Braided 24"	1		
B204	32334	Male elbow	2		
B205	73236	pilot valve actuation adaptor	2		
B206	416682	2 in orifice union	1		
B207	427150	2" Selector valve	1		
B208	40656	Valve check threaded 21/2"	1		
B209	40309	Header vent plug	1		
B210	70846	Actuator Lever for HF Actuator	2		
B211	416266	Warning plate outside room without alarm	1		
B212	426157	11/2" NPT 180 degree Nozzle Inergen side wall	4		
B213	433608	Autopulse 542R Agent Releasing Control 240VAC	1		
B214		Battery 12 V,7 Ah	2		
B215	435356	LED Driver, APN-ANN-I/O	1		
B216	435358	Relay module 10 programmable Contacts	1		
B217		Mimic Panel with LED'S	1		
B218	430023	Photo detector low profile 2151	6		
B219	417996	Detector base, B401	6		
B220	76498	Maintenance Switch, surface mount	1		
B221	76494	Abort Switch surface mount	1		
B222	428655	pull station, Dual action, SPST	1		
B223	428660	Surface back box	1		
B224	35816	Namplate, pull station	1		
B225	433356	Alarm, Horn/ strobe multi candela, Fire red	2		
B226	417805	Alarm, Bell 24 VDC,6 in	2		
B227	430023	Photo detector low profile 2151	2		
B228	417996	Detector base, B401	2		
B229	426157	11/2" NPT 180 degree Nozzle Inergen side wall	1		
<b>Inergen systems, Vault 2- Zone 2,( Main )</b>					
B230	73327	Actuator electric HF	2		

B231	428949	Booster actuator	2		
B232	32336	actuation Hose, swivel stainless Braided 24"	2		
B233	32334	Male elbow	2		
B234	73236	pilot valve actuation adaptor	4		
B235	418359	Flared tee	2		
B236	416682	2 in orifice union	1		
B237	427150	2" Selector valve	1		
B238	40656	Valve check threaded 21/2"	1		
B239	40309	Header vent plug	1		
B240	70846	Actuator Lever for HF Actuator	2		
B241	416266	Warning plate outside room without alarm	1		
B242	426157	11/2" NPT 180 degree Nozzle Inergen side wall	4		
B243	433608	Autopulse 542R Agent Releasing Control 240VAC	1		
B244		Battery 12 V,7 Ah	2		
B245	435356	LED Driver, APN-ANN-I/O	1		
B246	435358	Relay module 10 programmable Contacts	1		
B247		Mimic Panel with LED'S	1		
B248	430023	Photo detector low profile 2151	8		
B249	417996	Detector base, B401	8		
B250	76498	Maintenance Switch, surface mount	1		
B251	76494	Abort Switch surface mount	1		
B252	428655	pull station, Dual action, SPST	1		
B253	428660	Surface back box	1		
B254	35816	Namplate, pull station	1		
B255	433356	Alarm, Horn/ strobe multi candela, Fire red	2		
B256	417805	Alarm, Bell 24 VDC,6 in	2		
B257	41942	Name plate Main	1		
B258	417805	Name plate Reserve	1		
B259	430023	Photo detector low profile 2151	2		
B260	417996	Detector base, B401	2		
B261	426157	11/2" NPT 180 degree Nozzle Inergen side wall	1		
<b>Inergen systems, Vault 3- Zone 3,( Main &amp; Reserve )</b>					
B262	430952	Cylinder, Inergen, std 572 cuft with CV98 valve	58		
B263	427082	Flexible discharge bend 200 Bar	58		
B264	73327	Actuator electric HF	6		
B265	428949	Booster actuator	6		
B266	79641	Back Frame 5 cylinder	10		
B267	79640	Back Frame 4 cylinder	2		
B268	418503	Bolt and nut 27 in double row	17		
B269	73092	Cylinder, clamp-3 cylinder	5		

B270	73091	Cylinder, clamp-2 cylinder	7		
B271	879413	connector	10		
B272	70846	Actuator Lever for HF Actuator	4		
B273	32336	actuation Hose, swivel stainless Braided 24"	5		
B274	418359	Flared tee	5		
B275	32334	Male elbow	6		
B276	73236	pilot valve actuation adaptor	8		
B277	427886	3 in orifice Flanged , weld Neck	1		
B278	427150	2" Selector valve	2		
B279	40665	3 in Check valve Threaded Flange ,3 in	2		
B280	40656	Valve check threaded 2 1/2"	2		
B281	40309	Header vent plug	2		
B282	416266	Warning plate outside room without alarm	3		
B283	417366	1 1/2" NPT 360 degree Nozzle Inergen	6		
B284	433608	Autopulse 542R Agent Releasing Control 240VAC	1		
B285		Battery 12 V,7 Ah	2		
B286	435356	LED Driver, APN-ANN-I/O	1		
B287	435358	Relay module 10 programmable Contacts	1		
B288		Mimic Panel with LED'S	1		
B289	430023	Photo detector low profile 2151	20		
B290	417996	Detector base, B401	20		
B291	76498	Maintenance Switch, surface mount	1		
B292	76494	Abort Switch surface mount	1		
B293	428655	pull station, Dual action, SPST	1		
B294	428660	Surface back box	1		
B295	35816	Namplate, pull station	1		
B296	76496	Main / Reserve /switch Surface mount	1		
B297	433356	Alarm, Horn/ strobe multi candela, Fire red	2		
B298	417805	Alarm, Bell 24 VDC,6 in	2		
B299					
B300	430023	Photo detector low profile 2151	4		
B301	417996	Detector base, B401	4		
B302	427092	Replacement valve CV 98 for inergen cylinder	6		
B303	417366	1 1/2" NPT 360 degree Nozzle Inergen	2		
<b>Block E FM-200 system -UPS Room (System1)</b>					
B304	570006	FM-200,tank 52 L,fill with 84 lbs)	1		
B305	N/A	Factory Fill (per lb)	84		
B306	570092	Container Bracket	2		
B307	570209	Removable Electric Solenoid,24 Volt	1		
B308	570142	2in Discharge hose and adaptor	1		
B309	570162	Discharge nozzle 2 in, brass	1		

B310	570059	Supervisory Pressure switch	1		
B311	570192	Entrance Warning Sign	1		
B312	430525	Autopulse Z-10 Control system Red 1230/240VAC	1		
B313		Battery 12 v 7 Ah	2		
B314	430687	Coil Supervision Module ( Release circuit)	1		
B315	430559	Photoelectric Smoke detector 2.8% ULI	2		
B316	430567	2-wire base w/LED Driver ULI	2		
B317	417805	Alarm bell 24 VDC 6 in	1		
B318	76494	Abort Switch , Surface mount	1		
B319	433356	Horn / Strobe Multi candella, Fire red	1		
B320	551167	Pull station dual action ,DPST	1		
B321	428660	Back Box Single Gang Surface mount	1		
<b>Block E FM-200 system -Electrical room (System2)</b>					
B322	570006	FM-200,tank 52 L,fill with 88 lbs)	1		
B323	N/A	Factory Fill (per lb)	88		
B324	570092	Container Bracket	2		
B325	570209	Removable Electric Solenoid,24 Volt	1		
B326	570142	2in Discharge hose and adaptor	1		
B327	570162	Discharge nozzle 2 in, brass	1		
B328	570059	Supervisory Pressure switch	1		
B329	570192	Entrance Warning Sign	1		
B330	430525	Autopulse Z-10 Control system Red 1230/240VAC	1		
B331		Battery 12 v 7 Ah	2		
B332	430687	Coil Supervision Module ( Release circuit)	1		
B333	430559	Photoelectric Smoke detector 2.8% ULI	2		
B334	430567	2-wire base w/LED Driver ULI	2		
B335	417805	Alarm bell 24 VDC 6 in	1		
B336	76494	Abort Switch , Surface mount	1		
B337	433356	Horn / Strobe Multi candella, Fire red	1		
B338	551167	Pull station dual action ,DPST	1		
B339	428660	Back Box Single Gang Surface mount	1		
<b>Block B System1 UPS Room</b>					
B340	570006	FM-200,tank 52 L,fill with 84 lbs)	1		
B341	N/A	Factory Fill (per lb)	84		
B342	570092	Container Bracket	2		
B343	570209	Removable Electric Solenoid,24 Volt	1		
B344	570142	2in Discharge hose and adaptor	1		
B345	570162	Discharge nozzle 2 in, brass 7 ports	1		
B346	570192	Entrance Warning Sign	1		
B347	570190	Manual Release Sign	1		
B348	570229	PCR-100 control system, red 240VAC	1		
B349		Battery 12 v 7 Ah	2		
B350	430023	Photoelectric Smoke detector	2		

B351	430025	Base Model,B110LP , 6 in Dia	2		
B352	417805	Alarm bell 24 VDC 6 in	1		
B353	76494	Abort Switch , Surface mount	1		
B354	433357	Horn / Strobe Multi candella, Agent red	1		
B355	551167	Pull station dual action ,DPST	1		
B356	428660	Back Box Single Gang Surface mount	1		
<b>Block B System 2,Batteries room</b>					
B357	570005	FM-200,tank 32 L,fill with 58 lbs)	1		
B358	N/A	Factory Fill (per lb)	58		
B359	570085	Container Bracket	2		
B360	570209	Removable Electric Solenoid,24 Volt	1		
B361	570141	1in Discharge hose and adaptor	1		
B362	570159	Discharge nozzle 1 in, brass 7 ports	1		
B363	570192	Entrance Warning Sign	1		
B364	570190	Manual Release Sign	1		
B365	570229	PCR-100 control system, red 240VAC	1		
B366		Battery 12 v 7 Ah	2		
B367	430023	Photoelectric Smoke detector	2		
B368	430025	Base Model,B110LP , 6 in Dia	2		
B369	417805	Alarm bell 24 VDC 6 in	1		
B370	76494	Abort Switch , Surface mount	1		
B371	433357	Horn / Strobe Multi candella, Agent red	1		
B372	551167	Pull station dual action ,DPST	1		
B373	428660	Back Box Single Gang Surface mount	1		
<b>Block B System 3,CCTV&amp; Control room</b>					
B374	570004	FM-200,tank 16 L,fill with 25 lbs)	1		
B375	N/A	Factory Fill (per lb)	25		
B376	570085	Container Bracket	2		
B377	570209	Removable Electric Solenoid,24 Volt	1		
B378	570141	1in Discharge hose and adaptor	1		
B379	570159	Discharge nozzle 1 in, brass 7 ports	1		
B380	570192	Entrance Warning Sign	1		
B381	570190	Manual Release Sign	1		
B382	570229	PCR-100 control system, red 240VAC	1		
B383		Battery 12 v 7 Ah	2		
B384	430023	Photoelectric Smoke detector	2		
B385	430025	Base Model,B110LP , 6 in Dia	2		
B386	417805	Alarm bell 24 VDC 6 in	1		
B387	76494	Abort Switch , Surface mount	1		
B388	433357	Horn / Strobe Multi candella, Agent red	1		
B389	551167	Pull station dual action ,DPST	1		
B390	428660	Back Box Single Gang Surface mount	1		
<b>Block A 4th UPS Room Inergen System 1</b>					
B391	430952	Cylinder, Inergen, std 572 cuft with CV98 valve	1		
B392	427082	Flexible discharge bend 200 Bar	1		

B393	73327	Actuator electric HF	1		
B394	428949	Booster actuator	1		
B395	427705	channel includes bolts nuts saddle padding	1		
B396	416677	1/2 in orifice union	1		
B397	416266	Warning plate outside room without alarm	1		
B398	426140	1/2" NPT 180 degree Nozzle Inergen side wall	1		
B399	430525	Autopulse Z-10 Control system Red 240V AC	1		
B400		Battery 12 V,7 Ah	2		
B401	430529	4-PT Auxiliary relay Module	1		
B402	430559	Photo Detector 2.8% ULI	4		
B403	430567	2-Wire Base W/LED driver	4		
B404	433356	Horn/ strobe Multi candela, Fire red	1		
B405	417805	Alarm, Bell 24 VDC,6 in	1		
B406	428655	Manual pull station Dual action, SPST	1		
B407	428660	Back Box, Surface Mount	1		
B408	76494	Abort Switch, Surface mount	1		
<b>Block A 4th Archive room Inergen</b>					
B409	430952	Cylinder, Inergen, std 572 cuft with CV98 valve	3		
B410	427082	Flexible discharge bend 200 Bar	3		
B411	73327	Actuator electric HF	1		
B412	428949	Booster actuator	1		
B413	79639	Back Frame 3 cylinder	1		
B414	418502	Bolt and nut 13 in single row	2		
B415	873092	Cylinder, clamp-3 cylinder	1		
B416	416680	11/4 in orifice union	1		
B417	416266	Warning plate outside room without alarm	1		
B418	426142	1" NPT 180 degree Nozzle Inergen side wall	2		
B419	430525	Autopulse Z-10 Control system Red`240V AC	1		
B420		Battery 12 V,7 Ah	2		
B421	430529	4-PT Auxiliary relay Module	1		
B422	430559	Photo Detector 2.8% ULI	4		
B423	430567	2-Wire Base W/LED driver	4		
B424	433356	Horn/ strobe Multi candela, Fire red	1		
B425	417805	Alarm, Bell 24 VDC,6 in	1		
B426	428655	Manual pull station Dual action, SPST	1		
B427	428660	Back Box, Surface Mount	1		
B428	76494	Abort Switch, Surface mount	1		
<b>Primary Data Center - Inergen Fire System</b>					
B429	432874	200-Bar Inergen Cylinder Assembly	38		
B430	426620	150-Bar Inergen Cylinder Assembly	4		

B431	4007-9101	4007ES Hybrid Fire Control Panel	1		
B432	4009-9301	IDNet NAC Extender	3		
B433	4090-9006	Fire Releasing Device	12		
B434	857433	2-1/2" Selector Valve	1		
B435	427150	2" Selector Valve	2		
B436	427185	1" Selector Valve	4		
B437	73327	HF Electric Actuator	15		
B438	428949	Booster Actuator	15		
B439	4090-9007	Signal IAM	16		
B440	4098-9714	Smoke Detector	60		
B441	4098-9733	Heat Detector	1		
B442	4098-9792	Detector Base	61		
B443	4099-9006	Double-Action Surface Mounted Pull Station	8		
B444	417362	1/2" 360° Inergen Discharge Nozzle	1		
B445	426141	3/4" 180° Inergen Discharge Nozzle	4		
B446	417365	1-1/4" 360° Inergen Discharge Nozzle	1		
B447	445710	1-1/2" Inergen Acoustic Discharge Nozzle	10		
B448	27511	Inergen Acoustic Nozzle Orifice Pipe Assembly	10		
B449	40852	3/4" Check Valve	2		
B450	40649	2" Check Valve	2		
B451	40656	2-1/2" Check Valve	4		
B452	4090-9002	Relay IAM	21		
B453	4090-9001	Monitored IAM	21		
B454	4906-9127	Horn with Multi Candela Strobe	16		
B455	2080-9057	Surface Mounted Abort Switch	7		
B456	76496	Surface Mounted Main / Reserve Switch	4		
B457	76498	Maintenance Disconnect Switch	4		
B458	427082	Flexible Discharge Bend	42		
B459	416680	1-1/4" Orifice Union	1		
B460	416682	2" Orifice Union	2		
B461	427886	2-1/2" Flanged Pressure Reducer	1		
B462	431700	Manifold Relief Valve	8		
B463	40309	Header Vent Plug	7		
B464	4007-9810	Modular Network Interface Card	1		

B465	4007-9813	Wired Network Media Card	2		
B466	4606-9202	LCD Annunciator with Red Trim	1		
B467	N / A	Cylinder Bracketing	1		
<b>Block B - Fuel Tank Room - Barbon Dioxide Fire Suppression System</b>					
B468		100lbs. CO2 Cylinders & Valve Assembly with Discharge	4		
B469		Hose ¾" Outlet	1		
B470		Aegis Release Panel	1		
B471		Batteries 12V-7AH	2		
B472		Electric Control Heads 24 VDC Head,	2		
B473		Nameplate, Warning "Vacate At Once	2		
B474		Kidde Aegis Single Hazard Agent Releasing Panel "	1		
B475		Multi Jet Type S Nozzle ½' NPT	4		
B476		Heat Detector Model, Vertical Mount	4		
B477		Multi-tone Signal Strobe 24 VDC 15/75 cd	2		
B478		Indoor /Outdoor Surface Back Box	2		
B479		Sounder Strobe Back Box	2		
B480		Kidde 3300 Conventional Dual Action Pull Station	1		
B481		Kidde 3300 SGB-32s Indoor Surface Back Box	1		
B482		Manual Station Back Box	1		
B483		Cylinder Strap	2		
<b>Server Room- Block B - FM-200 Fire Suppression System in</b>					
B484		70lbs Capacity FM-200 Cylinder and Valve assembly c/w Bracket and	1		
B485		Adapter	1		
B486		FM-200 Nozzle	2		
B487		Back box	1		
B488		Aegis Panel c/w Back-up Battery Valve	1		
B489		24 VDC Electric Control Head	1		
B490		Nameplate "Warning "	2		
B491		Ionization Smoke Detector c/w Base	2		
B492		Photoelectric Smoke Detector c/w Base	2		
B493		Multi-tone Signal Strobe	2		
B494		Sounder Strobe Back Box	2		
B495		Manual Station Back Box	1		
B496		Indoor/outdoor Surface Back Box	2		



B497		Suppression Abort Station	1		
B498		Kidde Conventional Dual Action Pull Station	1		
<b>Shredding Room FM-200 Fire Suppression System</b>					
B499		600Lbs FM-200 Cylinder Assembly (762Lbs Filled) with Cylinder	2		
B500		Nozzle	1		
B501		Aegis Release Panel	1		
B502		Batteries 12V-7AH	2		
B503		Electric Control Heads 24 VDC	2		
B504		Nameplate, Warning "FM-200	1		
B505		Suppression Abort Station	1		
B506		Back Box-Switch 4x4	1		
B507		Kidde AEGIS Single Hazard Agent Releasing Panel	1		
B508		Multi Jet Type S Nozzle ½' NPT	4		
B509		Smoke Detector	2		
B510		PSD-7157 Advanced Photoelectric Smoke Detector	2		
B511		2WB 2 wire standard Base	2		
B512		Multi-Tone Strobe 24 VDC 15/75 cd	2		
B513		Indoor/Outdoor Surface Back Box	1		
B514		Main to Reserve Switch	1		
B515		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
B516		Sounder Strobe Back Box	2		
B517		Kidde 3300 Conventional Dual Action Pull Station	1		
B518		Name plate 'Main'	1		
B519		Name plate 'Reserve'	1		
B520		3 Swings Check FM-200	2		
B521		Container Pressure Switch	2		
B522		Back Box-Switch 4x4 r	1		
B523		Switch – Maintenance Kidde	1		
<b>Shredding Room1LVM FM-200 Fire Suppression System</b>					
B524		200Lbs FM-200 (288Lbs Filled) Cylinder Assembly 2" Valve with Strap Suppression System	2		
B525		Flex Hose 2 Discharge	2		
B526		Nozzle	1		
B527		Aegis Release Panel	1		
B528		Batteries 12V-7AH	2		
B529		Electric Control Heads 24 VDC	2		
B530		Nozzle FM-200 180 37987	1		
B531		Nameplate, Warning "FM-200	1		
B532		Suppression abort station	1		

B533		Back Box-Switch 4x4	1		
B534		Kidde AEGIS Single Hazard Agent Releasing Panel	1		
B535		Smoke Detector	2		
B536		PSD-7157 Advanced Photoelectric Smoke Detector	1		
B537		2WB 2 Wire Standard Base	2		
B538		Multi-Tone Strobe 24 VDC 15/75 cd	1		
B539		Indoor/Outdoor Surface Back Box	1		
B540		Main to Reserve Switch	1		
B541		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
B542		Kidde 3300 Conventional Dual Action Pull Station	1		
B543		Name plate "Main"	1		
B544		Name plate 'Reserve'	1		
B545		Manifold EI Check	2		
B546		Back Box-Switch 4x4	1		
B547		Supervisory Pressure Switch	2		
B548		Switch – Maintenance Kidde	1		
<b>UPS Room FM-200 Fire Suppression System</b>					
B550		200Lbs Cylinder Assembly (150Lbs Filled) with Cylinder Strap with Strap	2		
B551		Nozzle	1		
B552		Aegis Release Panel	1		
B553		Batteries 12V-7AH	2		
B554		Electric Control Heads 24 VDC	2		
B555		Nozzle FM-200 180 37987	1		
B556		Nameplate, Warning "FM-200	1		
B557		Suppression Abort Station	1		
B558		Back Box-Switch 4x4	1		
B559		Kidde AEGIS Single Hazard Agent Releasing Panel	1		
B560		Smoke Detector	1		
B561		PSD-7157 Advanced Photoelectric Smoke Detector	1		
B562		2WB 2 Wire Standard Base	2		
B563		Multi-Tone Strobe 24 VDC 15/75 cd	1		
B564		Indoor/outdoor Surface Back Box	1		
B565		Main to Reserve Switch	1		
B566		Kidde 3300 SGB-32S Indoor Surface Back box	1		
B567		Kidde 3300 Conventional Dual Action Pull Station	1		
B568		Name plate 'Main'	1		
B569		Name plate 'Reserve'	1		

B570		Manifold EI Check	2		
B571		Back Box-Switch 4x4	1		
B572		Supervisory Pressure Switch	2		
B573		Switch – Maintenance Kidde	1		
<b>DVR Room FM-200 Fire Suppression System</b>					
B574		200Lbs FM-200 Cylinder Assembly (184Lbs Filled) with Cylinder Strap and	2		
B575		Discharge	1		
B576		Nozzle	1		
B577		Aegis Release Panel	1		
B578		Batteries 12V-7AH Flex	2		
B579		Electric Control Heads 24 VDC	2		
B580		Nozzle	1		
B581		Nameplate, Warning 'FM-200'	1		
B582		Suppression Abort Station	1		
B583		Back Box-Switch 4x4	1		
B584		Kidde AEGIS Single Hazard Agent Releasing Panel	1		
B585		Smoke Detector	1		
B586		PSD-7157 Advanced Photoelectric Smoke Detector	1		
B587		2WB 2 Wire Standard Base	2		
B588		Multi-Tone- Strobe 24 VDC 15/75 cd	1		
B589		Indoor/Outdoor Surface Back Box	1		
B590		Main to Reserve Switch	1		
B591		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
B592		Kidde 3300 Conventional Dual Action Pull Station	1		
B593		Name plate 'Main'	1		
B594		Name plate 'Reserve'	1		
B595		Manifold EL Check	2		
B596		Back Box-Switch 4x4	1		
B597		Supervisory Pressure Switch	2		
B598		Switch – Maintenance Kidde	1		
<b>Archive Room - Argonite Fire Suppression System</b>					
B599		Cylinder & Valve Assembly /valve-Argonite 80-.0L	14		
B600		KIT-Prime Complete Argonite	2		
B601		Valve-Manifold Check	14		
B602		Argonite 5MM Nozzle INPT	1		
B603		Argonite 16.0MM nozzle INPT	1		
B604		Argonite KF nozzle 1/2NPT	2		
B605		Argonite 1-1/2NPT Raster-FE/FE	1		
B606		Nameplate, Warning 'FM-200'	1		

B607		Suppression abort station	1		
B608		Back Box-Switch 4x4	1		
B609		Kidde AEGIS Single Hazard Agent Releasing Panel	1		
B610		Batteries 12v-7AH	2		
B611		Smoke Detector	1		
B612		PSD-7157 Advanced Photoelectric Smoke Detector	1		
B613		2WB 2 Wire Standard Base	2		
B614		Multi-tone Strobe 24 VDC 15/75 cd	1		
B615		Indoor/Outdoor Surface Back box	1		
B616		Main to Reserve Switch	1		
B617		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
B618		Kidde 3300 Conventional Dual Action Pull Station	1		
B619		Name Plate 'Main'	1		
B620		Name Plate 'Reserve'	1		
B621		Back Box-Switch 4x4	1		
B622		Switch – Maintenance Kidde	1		
<b>Electrical RoomFM-200 Fire Suppression System</b>					
B623		200Lbs FM-200 Cylinder Assembly 2" Valve (338Lbs Filled) with Cylinder	2		
B624		Nozzle FM-200	1		
B625		Aegis Release Panel	1		
B626		Batteries 12V-7AH	2		
B627		Electric Control Heads 24 Strap	2		
B628		Nameplate, Warning 'FM-200' VDC	1		
B629		Suppression Abort Station	1		
B630		Back Box-Switch 4x4	1		
B631		Kidde AEGIS Single Hazard Agent	1		
B632		Smoke Detector Releasing Panel	1		
B633		PSD-7157 Advanced Photoelectric Smoke Detector	1		
B634		2WB 2 Wire Standard	2		
B635		Multi-Tone- Strobe 24 VDC Base	1		
B636		Indoor/Outdoor Surface Back Box 15/75 cd	1		
B637		Main to Reserve Switch	1		
B638		Kidde 3300 SGB-32S Indoor	1		
B639		Kidde 3300 Conventional Dual Surface Back box	1		
B640		Name Plate 'Main' Action Pull Station	1		
B641		Name Plate 'Reserve'	1		
B642		Manifold EI Check	2		

B643		Back Box-Switch 4x4	1		
B644		Supervisory Pressure Switch	2		
B645		Switch – Maintenance Kidde	1		
<b>Zahle - Dry Chemical System in Boiler Room</b>					
B646		Ind-45 ABC Cylinder & Valve Assembly with mounting Bracket, Discharge kit, XV Control System, High Pressure Hose and Electric Actuator Kit 24 VDC	1		
B647		Total Flooding Nozzles	4		
B648		Kidde Aegis Single Hazard Agent Releasing Panel	1		
B649		Batteries 12V-7AH	2		
B650		Heat Detector Model 27121-0, 225 F Vertical Mount Kit,	2		
B651		Multi Tone Strobe 24 VDC 15/75cd	1		
B652		Indoor/Outdoor Surface Back Box	1		
B653		Kidde 3300 Conventional Dual Action Pull Station	1		
B654		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
B655		Back Box Switch 4x4	1		
B656		Suppression Abort Station	1		
B657		Nameplate	2		
<b>Novec 1230 Fire Suppression System in Block A , Archive Room 5th floor</b>					
B658		600Lb Novec Cylinder and Valve Assembly with Cylinder Strap	1		
B659		Electric Control Head, 24 VDC	1		
B660		Nozzle Novec	6		
B661		Nameplate, “Warning”, Novec 1230	6		
B662		Pressure Switch, 3 Pole Double Throw	1		
B663		Suppression Abort Station	4		
B664		Back Box Switch 4x4	4		
B665		Kidde Aegis Single Hazard Agent Releasing Panel	1		
B666		Batteries 12V-7AH	2		
B667		CPD-7054D Ion Smoke Detector	6		
B668		PSD-7157 Advanced Photoelectric Smoke Detector	6		
B669		2WB-Two Wire Standard Base	12		
<b>Novec 1230 Fire Suppression System in Bloc E VGF&amp; CCTV Room</b>					
B670		40Lb Novec Cylinder and Valve Assembly with Outlet Adapter 1	1		
B671		Novec Nozzle	2		
B672		Nameplate, “Warning”, Novec 1230	2		

B673		Pressure Switch 3" Pole Double Throw	1		
B674		Suppression Abort Station ½",	1		
B675		Back Box Switch 4x4	1		
B676		Kidde Aegis Single Hazard Agent Releasing Panel	1		
B677		Battery 12 V DC, 7 AH	2		
B678		CPD-7054D Ion Smoke Detector	2		
B679		PSD-7157 Advanced Photoelectric Smoke detector	2		
B680		2WB 2 Wire Standard Base	4		
B681		Multi Tone Strobe, 24 V 15/75 cd	2		
B682		Indoor/Outdoor Surface Back Box	2		
B683		Kidde 3300 Conventional Dual Action Pull Station	1		
B684		Kidde 3300 SGB-32S Indoor Surface Back Box	1		
<b>Novac 1230 Fire Suppression System in Block B-B1 UPS Security Room</b>					
B685		125Lbs Cylinder Assembly, 1-1/2" Valve with Outlet Adapter, Cylinder Strap and Electric Control Head, 24 VDC	1		
B686		Discharge Nozzle	3		
B687		Nameplate, "Warning", Novac	2		
B688		Pressure Switch, 3 Pole Double Throw	1		
B689		Kidde 878752 Suppression Abort Station	1		
B690		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B691		Aegis Fire Releasing Panel	1		
B692		Lead Acid Battery, 12 VDC, 7 AH	2		
B693		Ionization Smoke Detector	3		
B694		Photoelectric Smoke Detector Box	3		
B695		2WB-Two Wire Standard Base	6		
B696		Multi Tone Alarm & 30cd Strobe, 24 V	2		
B697		Multi Tone Alarm Back Box, IOB-R	2		
B698		SPST Manual Release Station, 3300 Series	1		
B699		Manual Station Back Box, SGB-32S	1		
<b>Novac 1230 Fire Suppression System in BloB A Fuel Room B3</b>					
B700		600Lbs Cylinder Assembly 3" Valve, with Cylinder Strap and Electric	1		

B701		Discharge Nozzle, Brass	4		
B702		Nameplate, "Warning", Novec	2		
B703		Pressure Switch 3" Pole Double Throw	1		
B704		Kidde 878752 Suppression Abort Station Control	1		
B705		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B706		Aegis Fire Releasing Panel	1		
B707		Lead Acid Battery, 12 V DC, 7 AH	2		
B708		Heat Detector Model 27121-0, 225 F Vertical Mount	4		
B709		Multi Alarm & 30 d Strobe, 24 V Box	2		
B710		Multi Tone Alarm Back IOB-R	2		
B711		SPST Manual Release Station, 3300 Series	1		
B712		Manual Station Back Box, SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Bloc B Electrical B1</b>					
B713		200Lbs Cylinder Assembly 2" Valve Outlet Adapter 2" and Electric	1		
B714		Discharge Nozzle, Brass	2		
B715		Nameplate, "Warning", Novec	2		
B716		Pressure Switch, 3 Pole Double Throw	1		
B717		Kidde 878752 Suppression Abort Station Control	1		
B718		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B719		Aegis Fire Releasing Panel	1		
B720		Ionization Smoke Detector	2		
B721		Photoelectric Smoke Detector	2		
B722		2WB Two Wire Standard Base Box	4		
B723		Multi Tone Alarm & 30 cd Strobe, 24 V	2		
B724		Multi Tone Alarm Back Box IOB-R	2		
B725		SPST Manual Release Station, 3300 Series	1		
B726		Manual Station Back Box, SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Bloc A UPS B2</b>					
B727		125Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Cylinder Strap Electric Control Head 24 VDC and Discharge Nozzle	1		
B728		Nameplate, "Warning," Novec	2		
B729		Pressure Switch 3 Pole Double Throw	1		

B730		Kidde 878752 Suppression Abort Station	1		
B731		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B732		Aegis Fire Releasing Panel	1		
B733		Lead Acid Battery 12 VDC 7 AH	2		
B734		Ionization Smoke Detector	1		
B735		Photoelectric Smoke Detector Box	1		
B736		2WB Two Wire Standard Base	2		
B737		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B738		Multi Tone Alarm Back Box IOB-R	2		
B739		SPST Manual Release Station 3300 Series	1		
B741		Manual Station Back Box, SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Bloc D UPS Room B1</b>					
B742		70Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Cylinder Strap Electric Control Head 24 VDC	1		
B743		Discharge Nozzle	2		
B744		Nameplate, "Warning", Novec	2		
B745		Pressure Switch 3 Pole Double Throw	1		
B746		Kidde 878752 Suppression Abort Station	1		
B747		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B748		Aegis Fire Releasing Panel	1		
B749		Lead Acid Battery 12 VDC, 7 AH	2		
B750		Ionization Smoke Detector	2		
B751		Photoelectric Smoke Detector Box	2		
B753		2WB Two Wire Standard Base	4		
B754		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B755		Multi Tone Alarm Back Box IOB-R	2		
B756		SPST Manual Release Station 3300 Series	1		
B757		Manual Station Back Box SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Bloc A-B2 UMDB</b>					
B760		40Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Wall Bracket, Electric Control Head 24 VDC and Discharge Nozzle	1		
B761		Nameplate "Warning", Novec	2		



B762		Pressure Switch 3 Pole Double Throw	1		
B763		Kidde 878752 Suppression Abort Station	1		
B764		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B765		Aegis Fire Releasing Panel	1		
B766		Lead Acid Battery 12 VDC 7 AH	2		
B767		Ionization Smoke Detector	1		
B768		Photoelectric Smoke Detector Box	1		
B769		2 WB Two Wire Standard Base	2		
B770		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B771		Multi Tone Alarm Back Box IOB-R	2		
B772		SPST Manual Release Station 3300 Series	1		
B773		Manual Station Back Box SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Bloc A Bat Room B2</b>					
B774		125Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Cylinder Strap Electric Control Head and Discharge Nozzle	1		
B775		Nameplate "Warning", Novac	2		
B776		Pressure Switch 3 Pole Double Throw	1		
B777		Kidde 878752 Suppression Abort Station	1		
B778		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B779		Aegis Fire Releasing Panel	1		
B780		Lead Acid Battery 12 VDC 7 AH	2		
B781		Ionization Smoke Detector	1		
B782		Photoelectric Smoke Detector Box	1		
B783		2WB Two Wire Standard Base	2		
B784		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B785		Multi Tone Alarm Back Box IOB-R	2		
B786		SPST Manual Release Station 3300 Series	1		
B787		Manual Station Back Box SGB-32S	1		
<b>Novac 1230 Fire Suppression System in Bloc D CCTV Room B1</b>					

B789		40Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Wall Bracket, Electric Control Head 24 VDC and Discharge Nozzle	1		
B790		Nameplate "Warning", Novec	2		
B791		Pressure Switch 3 Pole Double Throw	1		
B792		Kidde 878752 Suppression Abort Station	1		
B793		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B794		Aegis Fire Releasing Panel	1		
B795		Lead Acid Battery 12 VDC 7AH	2		
B796		Ionization Smoke Detector	1		
B797		Photoelectric Smoke Detector Box	1		
B798		2WB Two Wire Standard Base	2		
B799		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B800		Multi Tone Alarm Back Box IOB-R	2		
B801		SPT Manual Release Station 3300 Series	1		
B802		Manual Station Back Box SGB-32S	1		
<b>Novec 1230 Fire Suppression System in Block A Bat Room 8th Floor</b>					
B803		40Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Wall Bracket, Electric Control Head 24 VDC and Discharge Nozzle	1		
B804		Nameplate "Warning", Novec	2		
B805		Pressure Switch 3 Pole Double Throw	1		
B806		Kidde 878752 Suppression Abort Station	1		
B807		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B808		Aegis Fire Releasing Panel	1		
B809		Lead Acid Battery 12 VDC 7 AH	2		
B810		Ionization Smoke Detector	1		
B811		Photoelectric Smoke Detector Box	1		
B812		2WB Wire Standard Base	2		
B813		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B814		Multi Tone Alarm Back Box IOB-R	2		
B815		SPST Manual Release Station 3300 Series	1		

B816		Manual Station Back Box SGB-32S	1		
<b>Novac 1230 Fire Suppression System in Bloc A CCTV Room B1:</b>					
B817		40Lbs Cylinder Assembly 1-1/2" Valve with Outlet Adapter, Wall Bracket, Electric Control Head 24 VDC and Discharge Nozzle	1		
B818		Nameplate "Warning", Novac	2		
B819		Pressure Switch 3 Pole Double Throw	1		
B820		Kidde 878752 Suppression Abort Station	1		
B821		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B822		Aegis Fire Releasing Panel	1		
B823		Lead Acid Battery 12 VDC 7 AH	2		
B824		Ionization Smoke Detector	1		
B825		Photoelectric Smoke Detector Box	1		
B826		2WB Wire Standard Base	2		
B827		Multi Tone Alarm & 30 cd Strobe 24 V	2		
B828		Multi Tone Alarm Back Box IOB-R	2		
B829		SPST Manual Release Station 3300 Series	1		
B830		Manual Station Back Box SGB-32S	1		
<b>Novac 1230 Fire Suppression System in UPS Room Block A B1</b>					
B831		200Lbs Cylinder Assembly 2" Valve Outlet Adapter 2" and Electric Control Head 24 VDC	1		
B832		Discharge Nozzle, Brass	2		
B833		Nameplate, "Warning", Novac	2		
B834		Pressure Switch, 3 Pole Double Throw	1		
B835		Kidde 878752 Suppression Abort Station Control	1		
B836		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B837		Aegis Fire Releasing Panel	1		
B838		Ionization Smoke Detector	1		
B839		Photoelectric Smoke Detector	1		
B840		2WB Two Wire Standard Base Box	2		
B841		Multi Tone Alarm & 30 cd Strobe, 24 V	2		
B842		Multi Tone Alarm Back Box IOB-R	2		

B843		SPST Manual Release Station, 3300 Series	1		
B844		Manual Station Back Box, SGB-32S	1		
B845		Lead Acid Battery 12 VDC 7 AH	2		
<b>Novac 1230 Fire Suppression System in Electrical Room Block A</b>					
B846		200Lbs Cylinder Assembly 2" Valve Outlet Adapter 2" and Electric Control Head 24 VDC	1		
B847		Discharge Nozzle, Brass	2		
B848		Nameplate, "Warning", Novac	2		
B849		Pressure Switch, 3 Pole Double Throw	1		
B850		Kidde 878752 Suppression Abort Station Control	1		
B851		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B852		Aegis Fire Releasing Panel	1		
B853		Ionization Smoke Detector	2		
B854		Photoelectric Smoke Detector	2		
B855		2WB Two Wire Standard Base Box	4		
B856		Multi Tone Alarm & 30 cd Strobe, 24 V	2		
B857		Multi Tone Alarm Back Box IOB-R	2		
B858		SPST Manual Release Station, 3300 Series	1		
B859		Manual Station Back Box, SGB-32S	1		
B860		Lead Acid Battery 12 VDC 7 AH	2		
<b>Novac 1230 Fire Suppression System in Fuel Tank Room B1 Block B</b>					
B861		200Lbs Cylinder Assembly 2" Valve Outlet Adapter 2" and Electric Control Head 24 VDC	1		
B862		Discharge Nozzle, Brass	2		
B863		Nameplate, "Warning", Novac	2		
B864		Pressure Switch, 3 Pole Double Throw	1		
B865		Kidde 878752 Suppression Abort Station Control	1		
B866		Kidde Surface Mount Back Box / Key Maintenance Switch Back	1		
B867		Aegis Fire Releasing Panel	1		
B868		Ionization Smoke Detector	1		
B869		Photoelectric Smoke Detector	1		
B870		2WB Two Wire Standard Base Box	2		
B871		Multi Tone Alarm & 30 cd Strobe, 24 V	2		

B872		Multi Tone Alarm Back Box IOB-R	2		
B873		SPST Manual Release Station, 3300 Series	1		
B874		Manual Station Back Box, SGB-32S	1		
B875		Lead Acid Battery 12 VDC 7 AH	2		
<b>Block A - 2nd Floor - Server Room - Automatic fire suppression system with Ziton double knock control</b>					
B876		cylinder	1		
B877		pressure operated switch	1		
B878		detectors	2		
B879		extinguishing release button	1		
B880		control board	1		

**Spare Parts Pricing per System**

**Batch 2**

Item	Part#	Manufacturer	Description	Qty	Unit Price in USD	Total Price in USD
<b>Aley Boiler Room - INDX Fire Suppression</b>						
C1	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C2	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C3	553461	ANSUL	Control head Replacement Tabs	1		
C4	435017	ANSUL	ECH-24 Control Head Electrical al,24V DC W/L/act	1		
C5	550853	ANSUL	MB-P2 mounting bracket control head	1		
C6	435264	ANSUL	Solenoid monitor 24VDC	1		
C7	551678	ANSUL	NF-ABC Nozzle with cap, Total floodline	2		
C8	551166	ANSUL	RPS-E2 Remote pull station Electrical	1		
C9	428661	ANSUL	Break road Package	1		
C10	550299	ANSUL	glass rods for RPS-E2	1		
C11	550527	ANSUL	RPS-M pull station back box	1		
C12	551157	ANSUL	Ms-4 PDT four switch	1		
C13	551059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C14	550077	ANSUL	Alarm initiations switch	1		
C15	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C16	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C17	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C18	13970	ANSUL	HEAT DET VERT N/O 302-EPM-194	2		
C19	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C20	INT-GB6-24	Simplex	BELL 6 INCH 24VDC	1		
C21	4903-9427	Simplex	A/V 11OCD RED STD NON-ADDRESSA	1		
<b>Aley Generator Room - INERGEN Fire Suppression System</b>						

C22	441026	ANSUL	Cylinder, Inergen, std 572 cuft with CV98 valve	3		
C23	427082	ANSUL	Flexible discharge bend 200 Bar	3		
C24	73327	ANSUL	Actuator electric HF	1		
C25	428949	ANSUL	Booster actuator	1		
C26	79639	ANSUL	back frame 3 cylinder	1		
C27	418502	ANSUL	Bolt and nut 13 in single row	2		
C28	73092	ANSUL	Cylinder, clamp-3 cylinder	1		
C29	416679	ANSUL	1 in orifice union Drill nb.2U64 Drill Dia 0.328"	1		
C30	417364	ANSUL	Nozzle inergen 1" ceiling type Drill nb. 2L/54 Drill Dia 0.328"	1		
C31	417364	ANSUL	Nozzle inergen 1" ceiling type Drill nb.27164 Drill Dia 0.348"	1		
C32	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C33	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C34	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C35	13970	ANSUL	VERTICAL RATE COMPENSATED THERMAL DETECTOR 190 Des F	4		
C36	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		
C37	2975-9178	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C38	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C39	INT-GB6.24	Simplex	BELL 5 INCH 24VDC	1		
C40	4903-9427	Simplex	A/V 11OCD RED STD NON-ADDRESSA	1		
<b>Baalbeck - Boiler Room - INDX Fire Suppression</b>						
C41	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C42	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C43	553461	ANSUL	Control head Replacement Tabs	1		
C44	435017	ANSUL	ECH-24 Control head, Electrical,24VDC W/L/act	1		
C45	550853	ANSUL	MB-P2 mounting bracket control head	1		

C46	435264	ANSUL	Solenoid monitor 24 VDC	1		
C47	551678	ANSUL	NF-ABC Nozzle with cap, Total flooding	2		
C48	551166	ANSUL	RPS-E2 Remote pull station Electrical	1		
C49	428661	ANSUL	Break road Package	1		
C50	550299	ANSUL	glass rods for RPS-E2	1		
C51	550527	ANSUL	RPS-M pull station back box	1		
C52	551157	ANSUL	Ms-4 PDT four switch	1		
C53	551059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C54	550077	ANSUL	Alarm initiating switch	1		
C55	4004-9302	SIMPLEX	4004R RELEASE PNL RED	1		
C56	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		
C57	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		
C58	2080-9057	SIMPLEX	ABORT SWITCH, SURFACE	1		
C59	INT-GB6- 24	SIMPLEX	BELL 6 INCH 24 VDC	1		
C60	4903-9427	SIMPLEX	A/V IIOCD RED STD NON- ADDRESSA	1		
C61	13970	ANSUL	VERTICAL RATE COMPENSATED THERMAL DETECTOR 190 Deg F	4		
<b>Bekfaya - Fuel Tank Room - INDX Fire Suppression</b>						
C62	435032		A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C63	550054		MB-15 Cylinder mounting Bracket	1		
C64	553461		Control head Replacement Tabs	1		
C65	435077		ECH-24 Control head Electrical	1		
C66	550853		MB-P2 mounting bracket control head 24VD C W I L act	1		
C67	435264		Solenoid monitor 24 VDC	1		
C68	551678		NF-ABC Nozzle with cap Total floodline	2		
C69	551166		RPS-E2 Remote pull station Electrical	1		
C70	428661		Break road Package	1		
C71	550299		glass rods for RPS-E2	1		
C72	551157		Ms-4 PDT four switch	1		



C73	551059		16 gramm carbon dioxide actuation cartridge	1		
C74	550077		Alarm initiations switch	1		
C75	4004-9302		4004R RELEASE PNL RED	1		
C76	2081-9045		2 AMP COIL SUPERVISORY MODULE	1		
C77	4004-9860		4PT AUXILIARY RELAY MODULE	1		
C78	4098-9601		Smoke Detector	2		
C79	4098-9788		Base	2		
C80	2080-9057		Abort Switch Surface	1		
C81	INT-GB5-24		BELL 5 INCH 24 VDC	1		
C82	4098-9501		Smoke Detector	2		
C83	4098-9788		Base	2		
C84	4903-9427		A/V 110CD RED STD NON-ADDRESSA	1		
<b>Bekfaya - Generators Room # 1 - INERGEN Fire Suppression System</b>						
C85	441026	Ansul	Cylinder Inergen, std 572 cuft with CV98 valve	2		
C86	427082	Ansul	Flexible discharge bend 200 Bar	2		
C87	73327	Ansul	Actuator electric HF	1		
C88	428949	Ansul	Booster actuator	1		
C89	79642	Ansul	Back frame cylinder	1		
C90	418502	Ansul	Bolt and nut 13 in single row	4		
C91	73091	Ansul	Cylinder clamp-2 cylinder	3		
C92	416580	Ansul	1"1/4 orifice union Drill Number 23164 - Drill Diameter 0.359"	3		
C93	4L7365	Ansul	L"1/4in Nozzle - Drill Number LI2-Drill Diameter 0.500"	1		
C94	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C95	BTT	Local	Batteries-12VDC-7AH	2		
C96	2081-9045	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C97	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C98	2099-9t49	Simplex	DBL ACT PP STN W/O LOGO	1		

C99	2975-9778	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C100	2080-9057	Simplex	ABORT SWITCH	1		
C101	INT-GB5-24	Simplex	BELL 6 INCH 24 VDC	1		
C102	2098-9489	Simplex	HEAT DET VERT N/O 302.EPM-194	2		
C103	4903-9427	Simplex	A/V 11OCD RED STD NON.ADDRESSA	1		
<b>Bekfaya - Generators Room # 2 - INERGEN Fire Suppression System</b>						
C104	441026	Ansul	Cylinder Inergen, std 572 cuft with CV98 valve	2		
C105	427082	Ansul	Flexible discharge bend 200 Bar	2		
C106	73327	Ansul	Actuator electric HF	1		
C107	428949	Ansul	Booster actuator	1		
C108	79642	Ansul	Back frame cylinder	1		
C109	418502	Ansul	Bolt and nut 13 in single row	4		
C110	73091	Ansul	Cylinder clamp-2 cylinder	3		
C111	416580	Ansul	1"1/4 orifice union Drill Number 23164 - Drill Diameter 0.359"	3		
C112	4L7365	Ansul	1"1/4in Nozzle - Drill Number L12-Drill Diameter 0.500"	1		
C113	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C114	BTT	Local	Batteries-12VDC-7AH	2		
C115	2081-9045	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C116	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C117	2099-9t49	Simplex	DBL ACT PP STN W/O LOGO	1		
C118	2975-9778	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C119	2080-9057	Simplex	ABORT SWITCH	1		
C120	INT-GB5-24	Simplex	BELL 6 INCH 24 VDC	1		
C121	2098-9489	Simplex	HEAT DET VERT N/O 302.EPM-194	2		
C122	4903-9427	Simplex	A/V 11OCD RED STD NON.ADDRESSA	1		
<b>Bekfaya - Electrical Room # 1 - INERGEN Fire Suppression System</b>						
C123	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	1		

C124	427082	Ansul	Flexible discharge bend 200 Bar	1		
C125	73327	Ansul	Actuator electric HF	1		
C126	428949	Ansul	Booster actuator	1		
C127	79642	Ansul	back frame 6 cylinder	1		
C128	418502	Ansul	Bolt and nut 13 in single row	4		
C129	73097	Ansul	Cylinder, clamp-2 cylinder	3		
C130	476678	Ansul	3/4" orifice union Drill Number L - Drill Diameter 0.228"	3		
C131	4L7363	Ansul	3/4" orifice union - Drill Number 1 - Drill Diameter 0.228"	1		
C132	4t7363	Ansul	3/4" orifice union - Drill Number 1 - Drill Diameter 0.228"	1		
C133	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C134	2081-9045	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C135	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C136	4098-9601	Simplex	SSD PHOTO DETECTOR	2		
C137	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C138	2099-9L49	Simplex	DBL ACT PP STN WO LOGO	7		
C139	2975-9L78	Simplex	BOX/ADDRESSABLE PULL STATTON	1		
C140	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C141	INT-GB6-24	Simplex	BELL 6 INCH 24 VDC	1		
C142	4903-9427	Simplex	A/V 11OCD RED STD NON-ADDRESSA	1		
Bekfaya - Electrical Room # 2 - INERGEN Fire Suppression System						
C143	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	1		
C144	427082	Ansul	Flexible discharge bend 200 Bar	1		
C145	73327	Ansul	Actuator electric HF	1		
C146	428949	Ansul	Booster actuator	1		
C147	79642	Ansul	back frame 6 cylinder	1		
C148	418502	Ansul	Bolt and nut 13 in single row	4		
C149	73097	Ansul	Cylinder, clamp-2 cylinder	3		

C150	476678	Ansul	3/4" orifice union Drill Number L - Drill Diameter 0.228"	3		
C151	4L7363	Ansul	3/4" orifice union - Drill Number 1 - Drill Diameter 0.228"	1		
C152	4t7363	Ansul	3/4" orifice union - Drill Number 1- Drill Diameter 0.228"	1		
C153	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C154	2081-9045	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C155	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C156	4098-9601	Simplex	SSD PHOTO DETECTOR	2		
C157	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C158	2099-9L49	Simplex	DBL ACT PP STN WO LOGO	7		
C159	2975-9L78	Simplex	BOX/ADDRESSABLE PULL STATTON	1		
C160	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C161	INT-GB6-24	Simplex	BELL 6 INCH 24 VDC	1		
C162	4903-9427	Simplex	A/V 11OCD RED STD NON-ADDRESSA	1		
<b>Jounieh System1 Server Room</b>						
C163	570005		FM-200,tank 32 L,fill with 49 lbs)	1		
C164	N/A		Factory Fill (per lb)	49		
C165	570085		Container Bracket	2		
C166	570209		Removable Electric Solenoid,24 Volt	1		
C167	570141		1in Discharge hose and adaptor	1		
C168	570159		Discharge nozzle 1 in, brass 7 ports	1		
C169	57057		Discharge nozzle 1/2 in, brass 7 ports	2		
C170	570192		Entrance Warning Sign	1		
C171	570190		Manual Release Sign	1		
C172	570229		PCR-100 control system, red 240VAC	1		
C173			Battery 12 v 7 Ah	2		
C174	78996		Detector smoke ionization	6		

C175	417996		Base Model, B401 B	6		
C176	417805		Alarm bell 24 VDC 6 in	1		
C177	76494		Abort Switch , Surface mount	1		
C178	433357		Horn / Strobe Multi candella, Agent red	1		
C179	551167		Pull station dual action ,DPST	1		
C180	428660		Back Box Single Gang Surface mount	1		
<b>Jounieh System 2 UPS room</b>						
C181	570005		FM-200,tank 32 L,fill with 54 lbs)	1		
C182	N/A		Factory Fill (per lb)	54		
C183	570085		Container Bracket	2		
C184	570209		Removable Electric Solenoid,24 Volt	1		
C185	570141		1in Discharge hose and adaptor	1		
C186	570159		Discharge nozzle 1 in, brass 7 ports	1		
C187	57057		Discharge nozzle 1/2 in, brass 7 ports	2		
C188	570192		Entrance Warning Sign	1		
C189	570190		Manual Release Sign	1		
C190	570229		PCR-100 control system, red 240VAC	1		
C191			Battery 12 v 7 Ah	2		
C192	78996		Detector smoke ionization	6		
C193	417996		Base Model, B401 B	6		
C194	417805		Alarm bell 24 VDC 6 in	1		
C195	76494		Abort Switch , Surface mount	1		
C196	433357		Horn / Strobe Multi candella, Agent red	1		
C197	551167		Pull station dual action ,DPST	1		
C198	428660		Back Box Single Gang Surface mount	1		
<b>Jounieh - Electrical Room - INERGEN Fire Suppression System</b>						
C199	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	2		
C200	427082	Ansul	Flexible discharge bend 200 Bar	2		
C201	73327	Ansul	Actuator electric HF	1		

C202	428949	Ansul	Booster actuator	1		
C203	79639	Ansul	back frame 2 cylinder	1		
C204	418502	Ansul	Bolt and nut 13 in single row	1		
C205	73097	Ansul	Cylinder, clamp-2 cylinder	1		
C206	476679	Ansul	1in orifice union Drill nb. S Drill Dia.0.348"	1		
C207	417364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 37/64 Drill Dia 0.484"	1		
C208	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C209	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C210	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C211	4098-9601	Simplex	SSD PHOTO DETECTOR	2		
C212	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C213	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		
C214	2975-9778	Simplex	BOX/ADDRESSABLE PU LL STATION	1		
C215	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C216	INT-GB6-24	Simplex	BELL 5 INCH 24 VDC	1		
C217	4903-9427	Simplex	w 110CD RED STD NON-ADDRESSA	1		
<b>Nabatieh - Fuel Tank Room - IND X Fire Suppression System</b>						
C218	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C219	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C220	553451	ANSUL	Control head Replacement Tabs	1		
C221	4350L7	ANSUL	ECH-24 control head electrical 24DC W/L/Act	1		
C222	550853	ANSUL	MB-P2 mounting bracket control head	1		
C223	435264	ANSUL	Solenoid monitor 24VDC	1		
C224	551678	ANSUL	NF-ABC Nozzle with cap, Total flooding	2		
C225	551166	ANSUL	RPS-E2 Remote pull station Electrical	1		
C226	42866t	ANSUL	Break road Package	1		
C227	550299	ANSUL	glass rods for RPS-E2	1		
C228	550527	ANSUL	RPS-M pull station back box	1		

C229	551157	ANSUL	Ms-4 PDT four switch	1		
C230	551059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C231	550077	ANSUL	Alarm initiations switch	1		
C232	4004-9302	SIMPLEX	4OO4R RELEASE PNL RED	1		
C233	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		
C234	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		
C235	2080-9057	SIMPLEX	ABORT SWITCH, SURFACE	1		
C236	INT-GB6-24	SIMPLEX	BELL 6 INCH 24VDC	1		
C237	4903-9427	SIMPLEX	A/V 11OCD RED STD NON-ADDRESSA	1		
C238	4098-9601	SIMPLEX	Smoke Detector	2		
C239	4098-9788	SIMPLEX	Base Detector	2		
Nabatieh - Generators Room - INERGEN Fire Suppression System						
C240	441026	Ansul	Cylinder, inergen, std 572 cuft with CV98 valve	3		
C241	427082	Ansul	Flexible discharge bend 200 Bar	3		
C242	73327	Ansul	Actuator electric HF	1		
C243	428949	Ansul	Booster actuator	1		
C244	79639	Ansul	back frame cylinder	1		
C245	4L8502	Ansul	Bolt and nut 13 in single row	2		
C246	73092	Ansul	Cylinder, clamp-3 cylinder	1		
C247	416679	Ansul	1 in orifice union Drill nb.29/64 Drill Dia 0.453"	1		
C248	417364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 7 /16 Drill Dia	1		
C249	417364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 7 /16 Drill Dia	1		
C250	4004-9302	Simplex	4OO4R RELEASE PNL RED	1		
C251	2081-9045	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C252	4004-9850	Simplex	4PT AUXILIARY RELAY MODULE	1		
C253	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		
C254	2975-9t78	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C255	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C256	INT-GB6-24	Simplex	BELL 6 INCH 24 VDC	1		

C257	4903-9427	Simplex	A/V 11OCD RED STD NON-ADDRESSA	1		
C258	73970	Ansul	VERTICAL RATE COMPENSATED THERMAL DETECTOR 190 Deg F	2		
Saida - Boiler Room - IND X Fire Suppression System						
C259	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C260	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C261	553461	ANSUL	Control head Replacement Tabs	1		
C262	4350L7	ANSUL	ECH-24 control head, EI Electrical I, 24VDC W I	1		
C263	550853	ANSUL	MB-P2 mounting bracket control head	1		
C264	435264	ANSUL	Solenoid monitor 24 VDC	1		
C265	551678	ANSUL	NF-ABC Nozzle with cap, Total flooding	2		
C266	551166	ANSUL	RPS-E2 Remote pull station Electrical L/	1		
C267	428661	ANSUL	Break road Package	1		
C268	550299	ANSUL	glass rods for RPS-E2	1		
C269	550527	ANSUL	RPS-M pull station back box	1		
C270	551157	ANSUL	Ms-4 PDT four switch	1		
C271	5s1059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C272	ssoo77	ANSUL	Alarm initiating switch	1		
C273	4004-9302	SIMPLEX	4004R RELEASE PNL RED	1		
C274	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		
C275	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		
C276	2099-9149	SIMPLEX	DBL ACT PP STN WO LOGO	1		
C277	2975-9178	SIMPLEX	BOX/ADDRESSABLE PULL STATION	1		
C278	2080-90s7	SIMPLEX	ABORT SWITCH, SURFACE	1		
C279	INT-G86.24	SIMPLEX	BELL 6 INCH 24 VDC	1		
C280	4903-9427	SIMPLEX	A/V 11OCD RED STD NON-ADDRESSA	1		
C281	13970	Ansul	VERTICAL RATE COMPENSATED THERMAL DETECTOR 190 Des F	2		



Saida - Fuel Tank Room - IND X Fire Suppression System						
C282	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C283	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C284	553461	ANSUL	Control head Replacement Tabs	1		
C285	435017	ANSUL	ECH-24 Control head, Electrical,24VDC W / L/ act	1		
C286	550853	ANSUL	MB-P2 mounting bracket control head	1		
C287	435264	ANSUL	Solenoid monitor 24VDC	1		
C288	551678	ANSUL	NF-ABC Nozzle with cap, Total floodline	2		
C289	551166	ANSUL	RPS-E2 Remote pull station Electrical L/	1		
C290	428661	ANSUL	Break road Package	1		
C291	550299	ANSUL	glass rods for RPS-E2	1		
C292	550s27	ANSUL	RPS-M pull station back box	1		
C293	551157	ANSUL	Ms-4 PDT four switch	1		
C294	551059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C295	550077	ANSUL	Alarm initiating switch	1		
C296	4004-9302	SIMPLEX	4004R RELEASE PNL RED	1		
C297	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		
C298	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		
C299	2099-9L49	SIMPLEX	DBL ACT PP STN WO LOGO	1		
C300	2975-9178	SIMPLEX	BOX/ADDRESSABLE PULL STATION	1		
C301	2080-9057	SIMPLEX	ABORT SWITCH, SURFACE	1		
C302	INT-GB6-24	SIMPLEX	BELL 6 INCH 24VDC	1		
C303	4903-9427	SIMPLEX	A/V 110CD RED STD NON-ADDRESSA	1		
C304	4098-9601	SIMPLEX	Smoke Detector	2		
C305	4098-9788	SIMPLEX	Base Detector	2		
Sour Branch - Generators Room INERGEN Fire Suppression System						
C306	447026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	3		
C307	427082	Ansul	Flexible discharge bend 200 Bar	3		
C308	73327	Ansul	Actuator electric HF	1		

C309	428949	Ansul	Booster actuator	1		
C310	79640	Ansul	back frame 4 cylinder	1		
C311	4L8502	Ansul	Bolt and nut 13 in single row	2		
C312	73091	Ansul	Cylinder, clamp-2 cylinder	2		
C313	416680	Ansul	1"7/4 orifice union Drill nb.37/64 Drill Dia 0.484"	1		
C314	4L7364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 75/32 Drill Dia	1		
C315	4L7364	Ansul	Nozzle inergen 1" ceiling type Drill nb. t5/32Drill Dia O	1		
C316	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C317	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C318	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE O.468'I	1		
C319	2099-9149	Simplex	DBL ACT PP STN WO LOGO 46Rrl	1		
C320	2975-9178	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C321	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C322	INT.GB5.24	Simplex	BELL 5 INCH 24VDC	1		
C323	4903-9427	Simplex	A/V 11OCD RED STD NON.ADDRESSA	1		
C324	13970	Ansul	VERTICAL RATE COMPENSATED THERMAL	4		
Sour Branch - Electrical Room - INERGEN Fire Suppression System						
C325	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	1		
C326	427082	Ansul	Flexible discharge bend 200 Bar	1		
C327	73327	Ansul	Actuator electric HF	1		
C328	428949	Ansul	Booster actuator	1		
C329	79640	Ansul	back frame 4 cylinder	1		
C330	418502	Ansul	Bolt and nut 13 in single row	2		
C331	73091	Ansul	Cylinder, clamp-2 cylinder	2		
C332	476679	Ansul	1" orifice union Drill nb. 1 Drill Dia 0.272"	1		
C333	477364	Ansul	Nozzle inergen L" ceiling type Drill nb. 44993 Drill Dia	1		
C334	4004-9302	Simplex	4004R RELEASE PNL RED	1		

C335	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C336	4004-9850	Simplex	4PT AUXILIARY RELAY MODULE	1		
C337	4098-9601	Simplex	SSD PHOTO DETECTOR	2		
C338	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C339	2099-9L49	Simplex	DBL ACT PP STN WO LOGO	1		
C340	2975-9L78	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C341	2080-90s7	Simplex	ABORT SWITCH, SURFACE	1		
C342	INT-GB5-24	Simplex	BELL 6 INCH 24VDC	1		
C343	4903-9427	Simplex	A/V 11OCD RED STD NON-ADDRESSA	1		
<b>Sour - Fuel Tank Room - IND X Fire Suppression</b>						
C344	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C345	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C346	553461	ANSUL	Control head Replacement Tabs	1		
C347	435017	ANSUL	ECH-24 control head electrical, 24VDC W	1		
C348	550853	ANSUL	MB-P2 mounting bracket control head	1		
C349	435264	ANSUL	Solenoid monitor 24VOC	1		
C350	551678	ANSUL	NF-ABC Nozzle with cap, Total flooding	2		
C351	551166	ANSUL	RPS-E2 Remote pull station Electrical /	1		
C352	428661	ANSUL	Break road Package	1		
C353	550299	ANSUL	glass rods for RPS-E2	1		
C354	550527	ANSUL	RPS-M pull station back box	1		
C355	551157	ANSUL	Ms-4 PDT four switch	1		
C356	551059	ANSUL	16 gramm carbon dioxide actuation cartridge	1		
C357	550077	ANSUL	Alarm initiations switch	1		
C358	4004-9302	SIMPLEX	4OO4R RELEASE PNL RED	1		
C359	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		
C360	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		
C361	2080-9057	SIMPLEX	ABORT SWITCH, SURFACE	1		

C362	INT-GB6-24	SIMPLEX	BELL 6 INCH 24VDC	1		
C363	4903-9427	SIMPLEX	A/V 11OCD RED STD NON-ADDRESSA	1		
C364	4098-9601	SIMPLEX	Smoke Detector	2		
C365	4098-9788	SIMPLEX	Base Detector	2		
Tripoli - Fuel Tank Room - IND X Fire Suppression						
C366	435032	ANSUL	A-25 ABC Cylinder with valve ABC agent 25 lb	1		
C367	550054	ANSUL	MB-15 Cylinder mounting Bracket	1		
C368	553461	ANSUL	Control head Replacement Tabs	1		
C369	435017	ANSUL	ECH-24 Control head Electrical, 24VDC W	1		
C370	550853	ANSUL	MB-P2 mounting bracket control head	1		
C371	435264	ANSUL	Solenoid monitor 24VOC	1		
C372	551678	ANSUL	NF-ABC Nozzle with cap, Total flooding	2		
C373	551166	ANSUL	RPS-E2 Remote pull station Electrical /	1		
C374	428661	ANSUL	Break road Package	1		
C375	550299	ANSUL	glass rods for RPS-E2	1		
C376	550527	ANSUL	RPS-M pull station back box	1		
C377	551157	ANSUL	Ms-4 PDT four switch	1		
C378	551059	ANSUL	16 gram carbon dioxide actuation cartridge	1		
C379	550077	ANSUL	Alarm initiations switch	1		
C380	4004-9302	SIMPLEX	4OO4R RELEASE PNL RED	1		
C381	2081-9046	SIMPLEX	2 AMP COIL SUPERVISORY MODULE	1		
C382	4004-9860	SIMPLEX	4PT AUXILIARY RELAY MODULE	1		
C383	2080-9057	SIMPLEX	ABORT SWITCH, SURFACE	1		
C384	INT-GB6-24	SIMPLEX	BELL 6 INCH 24VDC	1		
C385	4903-9427	SIMPLEX	A/V 11OCD RED STD NON-ADDRESSA	1		
C386	4098-9601	SIMPLEX	Smoke Detector	2		
C387	4098-9788	SIMPLEX	Base Detector	2		
Tripoli Branch - Electrical Room - INERGEN Fire Suppression System						
C388	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	1		

C389	427082	Ansul	Flexible discharge bend 200 Bar	1		
C390	73327	Ansul	Actuator electric HF	1		
C391	428949	Ansul	Booster actuator	1		
C392	79639	Ansul	back frame 2 cylinder	1		
C393	418502	Ansul	Bolt and nut 13 in single row	2		
C394	73091	Ansul	Cylinder, clamp-2 cylinder	2		
C395	416680	Ansul	1 1/4 in orifice union Drill nb. S Drill Dia 0.348"	1		
C396	417355	Ansul	Nozzle inergen 1"1/4 ceiling type Drill nb.37/64 Drill Dia 0.348"	1		
C397	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C398	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C399	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C400	4098-9601	Simplex	SSD PHOTO DETECTOR	2		
C401	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C402	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		
C403	2975-9178	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C404	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C405	INT-GB5-24	Simplex	BELL 6 INCH 24VDC	1		
C406	4903-9427	Simplex	A/V 11OCD RED STD NON-ADDRESSA	1		
<b>Zahle Branch - Generators Room - INERGEN Fire Suppression System</b>						
C407	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	3		
C408	427082	Ansul	Flexible discharge bend 200 Bar	3		
C409	73327	Ansul	Actuator electric HF	1		
C410	428949	Ansul	Booster actuator	1		
C411	79640	Ansul	back frame 4 cylinder	1		
C412	418502	Ansul	Bolt and nut 13 in single row	2		
C413	73091	Ansul	Cylinder, clamp-2 cylinder	2		
C414	416679	Ansul	1 in orifice union Drill nb.29/64 Drill Dia 0.453"	1		
C415	417364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 7 /16 Drill Dia	1		

C416	417364	Ansul	Nozzle inergen 1" ceiling type Drill nb. 7 /16 Drill Dia	1		
C417	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C418	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C419	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C420	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		
C421	2975-9178	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C422	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C423	INT-GB6-24	Simplex	BELL 6 INCH 24 VDC	1		
C424	4903-9427	Simplex	A/V 110CD RED STD NON-ADDRESSA	1		
C425	13970	Ansul	VERTICAL RATE COMPENSATED THERMAL DETECTOR 190 Deg F	2		
Zahle Branch - Electrical Room INERGEN Fire Suppression System						
C426	441026	Ansul	Cylinder, Inergen, std 572 cuft with CV98 valve	2		
C427	427082	Ansul	Flexible discharge bend 200 Bar	2		
C428	73327	Ansul	Actuator electric HF	1		
C429	428949	Ansul	Booster actuator	1		
C430	79640	Ansul	back frame 4 cylinder	1		
C431	418502	Ansul	Bolt and nut 13 in single row	1		
C432	73091	Ansul	Cylinder, clamp-2 cylinder	1		
C433	476678	Ansul	3/4in orifice union Drill nb. S Drill Dia.0.321"	1		
C434	417363	Ansul	Nozzle inergen 1" ceiling type Drill nb. 2 Drill Dia 0.316"	1		
C435	4004-9302	Simplex	4004R RELEASE PNL RED	1		
C436	2081-9046	Simplex	2 AMP COIL SUPERVISORY MODULE	1		
C437	4004-9860	Simplex	4PT AUXILIARY RELAY MODULE	1		
C438	4098-9601	Simplex	SSD PHOTO DETECTOR	2		
C439	4098-9788	Simplex	SSD 2-WIRE DET REM LED BASE	2		
C440	2099-9149	Simplex	DBL ACT PP STN WO LOGO	1		

C441	2975-9178	Simplex	BOX/ADDRESSABLE PULL STATION	1		
C442	2080-9057	Simplex	ABORT SWITCH, SURFACE	1		
C443	INT-GB6-24	Simplex	BELL 5 INCH 24 VDC	1		
C444	4903-9427	Simplex	w 110CD RED STD NON-ADDRESSA	1		
<b>Aley Server Room - FM200 System Components</b>						
C445			Control Panel	1		
C446			Smoke detector	6		
C447			Bell	1		
C448			Siren	1		
C449			Manual Release button	1		
C450			Abort button	1		
C451			Actuator	1		
C452			27L Cylinder Fill with 26KG Agent	1		
<b>Aley UPS Room - FM200 System Components</b>						
C453			Control Panel	1		
C454			Smoke detector	2		
C455			Bell	1		
C456			Siren	1		
C457			Manual Release button	1		
C458			Abort button	1		
C459			Actuator	1		
C460			27L Cylinder Fill with 24KG Agent	1		
<b>Baalbeck Server Room - FM200 System Components</b>						
C461			Control Panel	1		
C462			Smoke detector	6		
C463			Bell	1		
C464			Siren	1		
C465			Manual Release button	1		
C466			Abort button	1		
C467			Actuator	1		
C468			44L Cylinder Fill with 37.5KG Agent	1		
<b>Baalbeck UPS Room - FM200 System Components</b>						
C469			Control Panel	1		
C470			Smoke detector	4		
C471			Bell	1		
C472			Siren	1		
C473			Manual Release button	1		
C474			Abort button	1		

C475			Actuator	1		
C476			44L Cylinder Fill with 36.5KG Agent	1		
<b>Bekfaya Server Room - FM200 System Components</b>						
C477			Control Panel	1		
C478			Smoke detector	6		
C479			Bell	1		
C480			Siren	1		
C481			Manual Release button	1		
C482			Abort button	1		
C483			Actuator	1		
C484			27L Cylinder Fill with 25.5KG Agent	1		
<b>Bekfaya UPS Room - FM200 System Components</b>						
C485			Control Panel	1		
C486			Smoke detector	2		
C487			Bell	1		
C488			Siren	1		
C489			Manual Release button	1		
C490			Abort button	1		
C491			Actuator	1		
C492			27L Cylinder Fill with 24KG Agent	1		
<b>Nabatieh Server Room - FM200 System Components</b>						
C493			Control Panel	1		
C494			Smoke detector	6		
C495			Bell	1		
C496			Siren	1		
C497			Manual Release button	1		
C498			Abort button	1		
C499			Actuator	1		
C500			38L Cylinder Fill with 34KG Agent	1		
<b>Nabatieh UPS Room - FM200 System Components</b>						
C501			Control Panel	1		
C502			Smoke detector	2		
C503			Bell	1		
C504			Siren	1		
C505			Manual Release button	1		
C506			Abort button	1		
C507			Actuator	1		
C508			15L Cylinder Fill with 10KG Agent	1		
<b>Saida Server Room - FM200 System Components</b>						



C509			Control Panel	1		
C510			Smoke detector	6		
C511			Bell	1		
C512			Siren	1		
C513			Manual Release button	1		
C514			Abort button	1		
C515			Actuator	1		
C516			27L Cylinder Fill with 21KG Agent	1		
Saida UPS Room - FM200 System Components						
C517			Control Panel	1		
C518			Smoke detector	2		
C519			Bell	1		
C520			Siren	1		
C521			Manual Release button	1		
C522			Abort button	1		
C523			Actuator	1		
C524			27L Cylinder Fill with 21KG Agent	1		
Tripoli Server Room - FM200 System Components						
C525			Control Panel	1		
C526			Smoke detector	6		
C527			Bell	1		
C528			Siren	1		
C529			Manual Release button	1		
C530			Abort button	1		
C531			Actuator	1		
C532			27L Cylinder Fill with 29KG Agent	1		
Tripoli UPS Room - FM200 System Components						
C533			Control Panel	1		
C534			Smoke detector	2		
C535			Bell	1		
C536			Siren	1		
C537			Manual Release button	1		
C538			Abort button	1		
C539			Actuator	1		
C540			15L Cylinder Fill with 15KG Agent	1		
Tyr Server Room - FM200 System Components						
C541			Control Panel	1		
C542			Smoke detector	6		
C543			Bell	1		
C544			Siren	1		

C545			Manual Release button	1		
C546			Abort button	1		
C547			Actuator	1		
C548			44L Cylinder Fill with 35KG Agent	1		
Tyr UPS Room - FM200 System Components						
C549			Control Panel	1		
C550			Smoke detector	2		
C551			Bell	1		
C552			Siren	1		
C553			Manual Release button	1		
C554			Abort button	1		
C555			Actuator	1		
C556			27L Cylinder Fill with 19KG Agent	1		
Zahle Server Room - FM200 System Components						
C557			Control Panel	1		
C558			Smoke detector	6		
C559			Bell	1		
C560			Siren	1		
C561			Manual Release button	1		
C562			Abort button	1		
C563			Actuator	1		
C564			44L Cylinder Fill with 49KG Agent	1		
Zahle UPS Room - FM200 System Components						
C565			Control Panel	1		
C566			Smoke detector	4		
C567			Bell	1		
C568			Siren	1		
C569			Manual Release button	1		
C570			Abort button	1		
C571			Actuator	1		
C572			44L Cylinder Fill with 28KG Agent	1		

**Spare Parts Pricing per System**

**Batch 3**

Item	Part #	Item	Expected Qty	Unit Price in USD	Total Price in USD
<b>Firefighting Equipment in Bloc B&amp;E</b>					
D1	Fire Hose Rack Cabinet C/W:	Steel fire cabinet, Recessed type, Single compartment.	36		
D2		Fire Hose Rack			
D3		2.5" Pressure Restricting angle Valve			
D4		2.5" x 1.5" Brass Adapter			
D5		1.5" Brass Coupling			
D6		1.5" x 100 ft Synthetic Fire Hose			
D7		1.5" Brass nozzle.			
D8	4" Zone control valve c/w	4" Fire - indicated butterfly valve with tamper switch	30		
D9		4" Water flow detector			
D10		2" Test and drain module			
D11		Pressure gauge			
D12	4" double interlock preaction valve station c/w	4" Butterfly valve with tamper switch	1		
D13		4" Deluge valve			
D14		Variable trim with solenoid valve 24 vdc and low pressure valve			
D15		Water alarm pressure switch			
D16		Low pressure switch			
D17		Smoke detector			
D18		Air compressor			
D19	Sprinklers				
D20	6" Alarm check valve station c/w	6" Alarm check valve	1		
D21		Retarding chamber			
D22		Variable trim			
D23		Water motor alarm gong			
D24		Alarm pressure switch			
D25	misc	Sprinkler System in 15 floors in Block E and 15 floors in Block B	1		
D26		6" x 2 1/2' x 2 1/2" Siamese connection	2		
D27		Electrical Pump 500 GPM / 12 bar	2		
D28		Jockey Pump	1		

## المُلحق رقم (٦)

### تحليل الأسعار

- 1- في المرحلة الأولى يتم تقييم الشروط التقنية والفنية بحسب ما نصّ عليه الملحق رقم (١) وفقاً للجدول **Technical Evaluation Grading**، إن الإستحصال على علامة دون ١٠٠/٧٠ ستؤدي إلى إعتبار العارض مرفوض تقنياً وغير مؤهل للمرحلة الثانية، بحيث يتم فض عرضه المالي.
- 2- في المرحلة الثانية، يتم وضع العلامات وفقاً لجدول **Commercial Evaluation**.
- 3- يسند التلزييم بعد تحليل الأسعار إلى العرض الأفضل نتيجة الإستحصال على أعلى علامة بموجب معادلة نسبية بين العرض التقني والأكلاف المالية المتمثلة بكلفة اليد العاملة وقطع الغيار للأعطال المستجدة على الشكل التالي:
  - **العرض التقني ٤٠%:** أي يستحصل على نسبة كاملة ٤٠% العارض المستحصل على أعلى علامة في التقييم التقني بحيث باقي العروض المقبولة تستحصل على النسبة المحتسبة من الـ ٤٠% مقارنة مع العلامة التقنية الأعلى،
  - **الأكلاف المالية ٦٠%:** أي يستحصل على نسبة كاملة ٦٠% العارض المستحصل على أعلى علامة في التقييم المالي بحيث باقي العروض المقبولة تستحصل على النسبة المحتسبة من الـ ٦٠% مقارنة مع العلامة المالية الأدنى،
- 4- يمكن للمصرف تجزئة التلزييم بحسب الأنواع المفصّلة في الملحق رقم (٥).
- 5- في حال تجزئة التلزييم: يتم إرساء التلزييم لمورد واحد أو أكثر وذلك لمجموعة واحدة أو أكثر بحسب تقسيم جدول الكميات وفقاً لما هو مفصّل في الملحق رقم (٥). يكون الملتزم مسؤول عن تنفيذ أعمال الصيانة والتوصيلحات كافة بناءً للأكلاف المقدمة من قبله خلال فترة التلزييم.

Technical Evaluation Grading		Grade
1	Confirmation of availability of spare parts in stock (item by item as listed in the schedule attached to the BOQ) and ability to supply BDL within 24 Hours. (In case of partial availability, grading will be computed on pro rata basis as detailed in spare parts list attached below).	20
2	Confirmation of number of preventive maintenance visits as set in BOQ, and intervention duration for corrective maintenance visits within 24 hours. (As detailed in the scope of works)	25
3	Warranty Duration. The highest warranty duration of replaced spare parts will get the whole grade and the remaining bidders will receive lower grades on a pro rata basis.	15
4	Certification from manufacturer that the bidder is certified as a dealer and qualified to provide maintenance services based on the type of equipment specified in the spare parts list. (Except for Portable fire extinguishers)	20
5	Company profile and references of its projects showing the brands of the maintained equipment as per clause 21 article 4 from TOR (Grading will be computed on pro rata basis according to number of presented projects and their scale).	20
N.B.	Technical aspects that comply or surpass the tender's specifications will receive a full grade, while aspects less complying will receive lower grades on a pro rata basis.	
<b>TOTAL</b>		<b>100</b>

<b>Commercial Evaluation</b>		
		<b>Grade</b>
1	The lowest commercial bid for preventive maintenance labor receives a full grade of 45%, the remaining bidders receive lower grades on a pro rata basis	45
2	The lowest commercial bid for supply of spare parts receives a full grade of 55%, the remaining bidders receive lower grades on a pro rata basis	55
	<b>TOTAL</b>	<b>100</b>

## المُلحق رقم (٧)

### وثيقة رقم ١ : كتاب تعهد بالإمتثال

أنا الموقع أدناه، .....  
أتعهد، باسمي و/أو باسم الشخص المعنوي الذي أمثله، على مسؤوليتي الشخصية، وفي معرض تعاملي مع مصرف لبنان:

١. بأن ألتزم بأعلى معايير الأخلاق وقواعد حسن لسلوك.
٢. بعدم ممارسة أي ضغوطات أو نفوذ أو أي ممارسات غير مشروعة، كعرض أو وعد بتقديم أي نوع من العمولة أو المنفعة الخاصة أو الهدايا بغض النظر عن قيمتها المادية، بشكل مباشر أو بواسطة شخص ثالث، على أي من العاملين لدى مصرف لبنان أو القيمين على إدارته.
٣. بالإفصاح لمصرف لبنان عن وجود أو احتمال وجود أي تضارب بين مصالح مصرف لبنان وبينني و/أو بين مصالح الشخص المعنوي الذي أمثله وأي من العاملين لديه أو القيمين على إدارته قبل بدء التعامل أو التعاقد مع مصرف لبنان.
٤. بالإفصاح لمصرف لبنان، فوراً، لدى اكتشاف أي تضارب بين المصالح المذكورة وذلك خلال فترة التعامل/التعاقد المنوّه عنه أعلاه.

وأقر، باسمي و/أو باسم الشخص المعنوي الذي أمثله، على مسؤوليتي الشخصية، وفي معرض تعاملي مع مصرف لبنان، بأنني أخذت علماً أن القيام و/أو محاولة القيام، بشكل مباشر أو غير مباشر، بأي من الأعمال غير المشروعة المشار إليها أعلاه أو بأية أعمال أو ممارسات مخالفة للقوانين والأنظمة المرعية قد تنتج عنها تبعات قانونية منها وقف التعامل و/أو فسخ العقد الموقع مع مصرف لبنان على مسؤوليتي الشخصية و/أو مسؤولية الشخص المعنوي الذي أمثله، مع احتفاظ مصرف لبنان بحقه في مقاضاتي ومطالبتي بالتعويضات القانونية.

كما أصرح وأقر على مسؤوليتي الشخصية:

- بأنه لا توجد أي صلة قرابة، حتى الدرجة الرابعة، تجمع بيني و/أو بين أي من العاملين لدى الشخص المعنوي الذي أمثله أو القيمين على إدارته وبين أي من العاملين لدى مصرف لبنان أو القيمين على إدارته.
- بأن صلة قرابة، حتى الدرجة الرابعة، تجمع بيني و/أو بين أي من العاملين لدى الشخص المعنوي الذي أمثله أو القيمين على إدارته وبين أي من العاملين لدى مصرف لبنان أو القيمين على إدارته، وذلك وفقاً للتفصيل التالي:  
◀ طبيعة صلة القرابة:

◀ أسماء طرفي صلة القرابة:

### التوقيع

بيروت، في ...../...../.....

المُلحق رقم (٧)

وثيقة رقم ٢ : استمارة الامتثال للعميل  
Customer Compliance Form

استمارة "KYC - 00"

	اسم العميل Customer's Full Name
	عدد الاستمارات المرفقة باستمارة الامتثال الحاضرة "KYC - 01" - "KYC" Number of "KYC-01" Forms attached to this Compliance Form
	عدد الاستمارات المرفقة باستمارة الامتثال الحاضرة "KYC - 02" - "KYC" Number of "KYC-02" Forms attached to this Compliance Form

ارشادات تعبئة الاستمارة / Instructions for Completing the Form

1. في حال كان العميل شخصا طبيعيا، يرجى تعبئة الاستمارتين "KYC - 00" و"KYC - 02" فقط.

1- If the customer is an individual, kindly complete the "KYC-00" and "KYC-02" Forms only.

2. في حال كان العميل شخصا معنويا، يرجى تعبئة كل من:

2- If the customer is an entity, kindly complete the Forms below:

- استمارة "KYC - 00" - Form "KYC - 00"

- استمارة "KYC - 01" للعميل - Customer Form "KYC - 01"

- استمارة "KYC - 02" لكل شخص طبيعي مفوض بالتوقيع عن العميل و/أو عن أي صاحب حق إقتصادي\*.  
- "KYC - 02" Form for each individual authorized to sign on behalf of the customer and/or any beneficial owner\*.

- استمارة "KYC - 02" لكل شخص طبيعي يعتبر صاحب حق إقتصادي (للعامل و/أو لصاحب حق إقتصادي).  
- "KYC - 02" Form for each individual considered as the beneficial owner (of the customer and/or a beneficial owner).

- استمارة "KYC - 01" لكل شخص معنوي يعتبر صاحب حق إقتصادي (للعامل و/أو لصاحب حق إقتصادي).  
- "KYC-01" Form for each entity considered as the beneficial owner (of the customer and/or a beneficial owner).

\* يعتبر صاحب حق اقتصادي، لغايات تعبئة هذه الاستمارة، أي شخص طبيعي أو معنوي يملك ما يوازي أو يزيد عن ٢٠% من رأسمال الشخص المعنوي.

\* For the purpose of completing this Form, a beneficial owner shall be any individual or entity holding 20% or more of the entity's capital.

3. يجب أن تكون المعلومات كافة المقدّمة إلى مصرف لبنان صحيحة وتعكس الوضع الحقيقي بالنسبة للشخص الطبيعي و/أو المعنوي وأن تكون المستندات كافة صادرة عن الجهة المخوّلة بإصدارها قانوناً أو نظاماً، على أن يتم إبلاغ مصرف لبنان، فوراً وخطياً، بأي تعديل يطرأ على المستندات المذكورة، سيما في حال لم يعد مضمون أي من هذه المستندات يعكس الوضع الحالي بالنسبة للشخص الطبيعي و/أو المعنوي.

3- All the information provided to Banque du Liban must be accurate and must reflect the real situation of the individual and/or entity. All the documents must be issued by the authority specifically empowered to do so by law and by regulations, provided Banque du Liban is promptly notified, in writing, of any amendment to these documents, in particular if their contents cease to reflect the current situation of the individual and/or entity.

← للاستفسار عن كيفية تعبئة أية استمارة، تراجع وحدة الامتثال لدى مصرف لبنان على الرقم: ٠١/٧٥٠٠٠٠ (مقسّم ٦٥٢١).

→ For further information on completing any Form, please contact the BDL Compliance Unit on: 01/750000 (extension 6521).



<input type="checkbox"/> صاحب حق اقتصادي Beneficial Owner		<input type="checkbox"/> العميل Customer		استمارة "KYC - 01" رقم: "KYC - 01" Form No:	
<b>معلومات عن الشخص المعنوي: Information about the Entity</b>					
					الاسم القانوني Legal name
			الجنسية Nationality		
					نشاط الشركة بالتفصيل Detailed activity of the company
<b>العنوان الفعلي: Effective Address</b>					
القضاء Caza		المحافظة Mouhafaza		البلد Country	
			الشارع Street	المنطقة Region	
			الطابق Floor	البنابة Building	
<b>بيانات الاتصال: Contact Information</b>					
		رقم الفاكس Fax number			رقم الهاتف Telephone number
		البريد الإلكتروني E-mail			الموقع الرسمي على شبكة الانترنت Official website
					الخدمات/السلع المقدمة إلى مصرف لبنان Services/goods provided to Banque du Liban
					الاسم الثلاثي للمفوضين بالتوقيع Full Name of Authorized Signatories

المُلحق رقم (٧)

وثيقة رقم ٣: استمارة الامتثال للأشخاص المعنويين  
Entity Compliance Form

اصحاب الحق الاقتصادي (أي شخص طبيعي او معنوي يملك ما يوازي او يزيد عن ٢٠% من رأسمال الشخص المعنوي)		
Beneficial Owners (any individual or entity holding 20% or more of the entity's capital)		
نسبة الملكية Ownership Percentage	اسم الشخص الطبيعي/المعنوي Individual/Entity's Name	الرقم Nb
		.1
		.2
		.3
		.4
		.5

\*راجع المستندات الإلزامية الواجب إرفاقها بالاستمارة الحاضرة وفقاً للـ Annex 1.

\* Refer to the mandatory documents that must be attached to this Form, as per Annex 1.

	الاسم الثلاثي للمفوض بالتوقيع Full Name of Authorized Signatory
	التاريخ Date
	التوقيع Signature

## Annex 1

<b>Entity</b> الشخص المعنوي ١.				
شركة مؤسسة وفقاً للقوانين اللبنانية Company established pursuant to the Lebanese laws	فرع لشركة مؤسسة وفقاً لقوانين أجنبية Subsidiary of a company established pursuant to foreign laws	شركة مؤسسة وفقاً لقوانين أجنبية Company established pursuant to foreign laws	جمعية مؤسسة وفقاً لقانون الجمعيات تاريخ ١٩٠٩/٨/٣ Association established pursuant to the Law on Associations of 3 August 1909	شخص معنوي غير شركة أو جمعية Entity other than company or association
شهادة تسجيل في السجل التجاري Certificate of registration in the Trade Register	إفادة تسجيل صادرة عن وزارة الاقتصاد Certificate of registration issued by the Ministry of Economy	شهادة تسجيل في السجل التجاري أو ما يوازيها Certificate of registration in the Trade Register, or any equivalent	بيان علم وخبر صادر عن وزارة الداخلية والبلديات Registration Notice issued by the Ministry of Interior and Municipalities	مستند صادر عن جهات رسمية مثبت لهوية الشخص المعنوي Document issued by official authorities, evidencing the entity's identity
صورة عن النظام الأساسي للشركة وتعديلاته Copy of the Company's bylaws and amendments thereto	صورة عن النظام الأساسي للشركة الأم وتعديلاته Copy of the Parent Company's bylaws and amendments thereto	صورة عن النظام الأساسي للشركة وتعديلاته Copy of the Company's bylaws and amendments thereto	صورة عن النظام الأساسي للجمعية وتعديلاته Copy of the Association's bylaws and amendments thereto	بالنسبة للشخص المعنوي Concerning the entity
<p>- إفادة صادرة عن وزارة المالية اللبنانية (أو الجهة المعنية بالنسبة للشخص غير المقيم) تبيّن الرقم الضريبي</p> <p>- Certificate issued by the Lebanese Ministry of Finance (or the concerned authority regarding non-resident persons) indicating the Tax Identification Number (TIN)</p>				
إذاعة تجارية لا يعود تاريخها إلى أكثر من ثلاثة أشهر تبيّن المفوض/المفوضين بالتوقيع عن الشركة Circular issued within the last three months, indicating the Company's authorized signatory(ies)	قرار تعيين ممثل لفرع الشركة الأجنبية موقع ومصادق عليه وفقاً للأصول Duly signed and approved decision regarding the appointment of a representative for the foreign company's subsidiary	إذاعة تجارية حديثة، أو ما يوازيها، تبيّن المفوض/المفوضين بالتوقيع عن الشركة Recent Circular or an equivalent, indicating the Company's authorized signatory (ies)	صورة عن هوية/جواز سفر ممثل الجمعية Copy of the ID card/passport of the association's representative	مستند يتضمّن، على الأقل، كيفية اتخاذ القرارات وصلاحيات القيمين على إدارة الشخص المعنوي و/أو نسخة/مستخرج عن قرار متخذ وفقاً للأصول بتعيين ممثل للشخص المعنوي والصلاحيات المفوضة له Document showing, at least, the decision-making process and the prerogatives of the entity's managers and/or a copy/extract of a duly taken decision regarding the appointment of the entity's representative and his/her prerogatives
صورة عن هوية/جواز سفر المفوض/المفوضين بالتوقيع عن الشركة Copy of the ID card/passport of the Company's authorized signatory (ies)	صورة عن هوية/جواز سفر ممثل فرع الشركة الأجنبية Copy of the ID card/passport of the representative of the foreign company's subsidiary	صورة عن جواز سفر المفوض/المفوضين بالتوقيع عن الشركة Copy of the passport of the Company's authorized signatory (ies)	صورة عن هوية/جواز سفر ممثل الشخص المعنوي Copy of the ID card/passport of the entity's representative	بالنسبة للقائمين على إدارة الشخص المعنوي Concerning the entity's managers

<p>صورة عن هوية/جواز سفر كل مالك صاحب الحق الإقتصادي أو البيانات المشار إليها أعلاه في حال كان أحد المالك صاحب الحق الإقتصادي شخصاً معنوياً</p> <p>Copy of the ID card/passport of each beneficial owner holding shares or the above-mentioned information if any of the beneficial owners holding shares is an entity</p>	<p>صورة عن هوية/جواز سفر كل من المؤسسين أو البيانات المشار إليها أعلاه في حال كان أحد المؤسسين شخصاً معنوياً</p> <p>Copy of the ID card/passport of each founder or the above-mentioned information if any of the founders is an entity</p>	<p>صورة عن هوية/جواز سفر كل مالك أو البيانات المشار إليها أعلاه في حال كان أحد المالكين شخصاً معنوياً</p> <p>Copy of the ID card/passport of each shareholder or the above-mentioned information if any of the shareholders is an entity</p>	<p>بالنسبة لصاحب الحق الإقتصادي المالك في رأسمال الشخص المعنوي</p> <p>Concerning the Beneficial Owner with a share in the entity's capital</p>
<p>مستند رسمي يحدد هوية ونسبة ملكية كل شخص يملك أكثر من ٢٠% في رأسمال الشخص المعنوي (بالنسبة لشركات الأموال المؤسسة وفقاً للقوانين اللبنانية، تقبل ورقة حضور آخر جمعية عمومية موقّعة من قبل المساهمين الحاضرين أو من يمثلهم).</p> <p>An official document that determines the identity and the ownership percentage of each person holding more than 20% of the entity's capital (for joint-stock companies established pursuant to Lebanese laws, the attendance sheet of the last general assembly signed by the attending shareholders or their representatives may be submitted).</p>			
<p><b>٢. الشخص الطبيعي Individual</b></p>			
<p>صورة عن هوية/جواز سفر (ما يثبت جنسية الشخص المعني)</p> <p>Copy of ID card/passport (evidencing the nationality of the concerned individual)</p>	<p>مستندات تبين المعلومات التالية:</p> <ul style="list-style-type: none"> <li>- مكان وتاريخ الولادة</li> <li>- العنوان الكامل لمكان الإقامة</li> <li>- عنوان البريد الإلكتروني</li> <li>- رقم الهاتف</li> <li>- إفادة صادرة عن وزارة المالية اللبنانية (أو الجهة المعنية بالنسبة للشخص غير المقيم) تبين الرقم الضريبي</li> </ul> <p>Documents indicating:</p> <ul style="list-style-type: none"> <li>- The date and place of birth</li> <li>- The full residential address</li> <li>- The e-mail address</li> <li>- The telephone number</li> <li>- Certificate issued by the Lebanese Ministry of Finance (or the concerned authority regarding non-resident persons) indicating the Tax Identification Number (TIN)</li> </ul>	<p>السند الخطي الذي يخول من يمثل العميل اتخاذ هذه الصفة (مثلاً، أصل أو نسخة طبق الأصل عن وكالة)، مؤرخاً وموقّعةً أمام موظف رسمي أو كاتب عدل أو ما يمثله وفقاً لقانون البلد حيث نظم السند، على أن يتم التأكد من تاريخ الصلاحية ومن الصلاحيات المعطاة للشخص الذي يمثل العميل بموجب السند المذكور.</p> <p>The written document authorizing the customer's representative to act in this capacity (i.e. an original or a duly certified copy of the proxy), dated and signed in the presence of a public officer or notary or the like, pursuant to the Law of the country where the said document was prepared, and provided the document validation date and the representative's powers are verified.</p>	<p>العميل Customer</p> <p>الشخص الذي يمثل العميل Customer's representative</p>

المُلحق رقم (٧)

وثيقة رقم ٤ : استمارة الامتثال للأشخاص الطبيعيين

Individual Compliance Form

<input type="checkbox"/> مفوض بالتوقيع Authorized Signatory		<input type="checkbox"/> صاحب حق اقتصادي Beneficial Owner		استمارة "KYC - 02" رقم: "KYC - 02" Form No:	
<b>بيانات شخصية: Personal Information</b>					
		الشهرة Family Name		الاسم Name	
		اسم الام وشهرتها Mother's Name & Family Name		اسم الاب Father's Name	
الجنس Gender		تاريخ الولادة Date of Birth		مكان الولادة Place of Birth	
		جنسيات اخرى Other Nationalities		الجنسية Nationality	
				الكنية (في حال وجودها) Surname (if any)	
<b>العنوان الفعلي: Actual Address</b>					
القضاء Caza		المحافظة Mouhafaza		البلد Country	
		الشارع Street		المنطقة Region	
		الطابق Floor		البنية Building	
<b>بيانات الاتصال: Contact Information</b>					
		البريد الالكتروني E-mail		رقم الهاتف Telephone number	
<b>بيانات التعامل: Activity Information</b>					
		الخدمات/السلع المقدمة إلى مصرف لبنان Services/goods provided to Banque du Liban			

\*راجع المستندات الإلزامية الواجب إرفاقها بالاستمارة الحاضرة وفقاً لـ Annex 2.

\* Refer to the mandatory documents that must be attached to this Form as per Annex 2.

	الاسم الثلاثي Full Name
	التاريخ Date
	التوقيع Signature

## Annex 2

<b>Entity</b> الشخص المعنوي ١.					
شركة مؤسسة وفقاً للقوانين اللبنانية Company established pursuant to the Lebanese Laws	فرع لشركة مؤسسة وفقاً لقوانين أجنبية Subsidiary of a company established pursuant to foreign laws	شركة مؤسسة وفقاً لقوانين أجنبية Company established pursuant to foreign laws	جمعية مؤسسة وفقاً لقانون الجمعيات تاريخ ١٩٠٩/٨/٣ Association established pursuant to the Law on Associations of 3 August 1909	شخص معنوي غير شركة أو جمعية Entity other than company or association	
شهادة تسجيل في السجل التجاري Certificate of registration in the Trade Register	إفادة تسجيل صادرة عن وزارة الاقتصاد Certificate of registration issued by the Ministry of Economy	شهادة تسجيل في السجل التجاري أو ما يوازيها Certificate of registration in the Trade Register or any equivalent	بيان علم وخبر صادر عن وزارة الداخلية والبلديات Registration Notice issued by the Ministry of Interior and Municipalities	مستند صادر عن جهات رسمية مثبت لهوية الشخص المعنوي Document issued by official authorities, evidencing the entity's identity	بالنسبة للشخص المعنوي Concerning the entity
صورة عن النظام الأساسي للشركة وتعديلاته Copy of the Company's bylaws and amendments thereto	صورة عن النظام الأساسي للشركة الأم وتعديلاته Copy of the Parent Company's bylaws and amendments thereto	صورة عن النظام الأساسي للشركة وتعديلاته Copy of the Company's bylaws and amendments thereto	صورة عن النظام الأساسي للجمعية وتعديلاته Copy of the Association's bylaws and amendments thereto		
- إفادة صادرة عن وزارة المالية اللبنانية (أو الجهة المعنية بالنسبة للشخص غير المقيم) تبيّن الرقم الضريبي - Certificate issued by the Lebanese Ministry of Finance (or the concerned authority regarding non-resident persons) indicating the Tax Identification Number (TIN)					
إذاعة تجارية لا يعود تاريخها إلى أكثر من ثلاثة أشهر تبيّن المفوض/المفوضين بالتوقيع عن الشركة Circular issued within the last three months, indicating the Company's authorized signatory(ies)	قرار تعيين ممثل لفرع الشركة الأجنبية موقع ومصداق عليه وفقاً للأصول Duly signed and approved decision regarding the appointment of a representative for the foreign company's subsidiary	إذاعة تجارية حديثة، أو ما تبيّن المفوض/المفوضين بالتوقيع عن الشركة Recent Circular or an equivalent, indicating the Company's authorized signatory (ies)	صورة عن هوية/جواز سفر ممثل الجمعية Copy of the ID card/passport of the association's representative	مستند يتضمّن، على الأقل، كيفية اتخاذ القرارات وصلاحيات القيمين على إدارة الشخص المعنوي وأو نسخة/مستخرج عن قرار متخذ وفقاً للأصول بتعيين ممثل للشخص المعنوي والصلاحيات المفوضة له Document showing, at least, the decision-making process and the prerogatives of the entity's managers and/or a copy/extract of a duly taken decision regarding the appointment of the entity's representative and his/her prerogatives	بالنسبة للقائمين على إدارة الشخص المعنوي Concerning the entity's managers
صورة عن هوية/جواز سفر المفوض/المفوضين بالتوقيع عن الشركة Copy of the ID card/passport of the Company's authorized signatory (ies)	صورة عن هوية/جواز سفر ممثل فرع الشركة الأجنبية Copy of the ID card/passport of the representative of the foreign company's subsidiary	صورة عن جواز سفر المفوض/المفوضين بالتوقيع عن الشركة Copy of the passport of the Company's authorized signatory (ies)		صورة عن هوية/جواز سفر ممثل الشخص المعنوي Copy of the ID card/passport of the entity's representative	
صورة عن هوية/جواز سفر كل مالك صاحب الحق الإقتصادي أو البيانات المشار إليها أعلاه في حال كان أحد المالكين شخصاً معنوياً Copy of the ID card/passport of each beneficial owner holding shares or the above-mentioned information if any of the beneficial owners holding shares is an entity			صورة عن هوية/جواز سفر كل من المؤسسين أو البيانات المشار إليها أعلاه في حال كان أحد المؤسسين شخصاً معنوياً Copy of the ID card/passport of each founder or the above-mentioned information if any of the founders is an entity	صورة عن هوية/جواز سفر كل مالك أو البيانات المشار إليها أعلاه في حال كان أحد المالكين شخصاً معنوياً Copy of the ID card/passport of each shareholder or the above-mentioned	بالنسبة لصاحب الحق الإقتصادي المالك في رأسمال الشخص المعنوي Concerning the Beneficial Owner holding shares in the entity's capital

		information if any of the shareholders is an entity	
<p>مستند رسمي يحدّد هوية ونسبة ملكية كل شخص يملك أكثر من ٢٠% في رأسمال الشخص المعنوي (بالنسبة لشركات الأموال المؤسسة وفقاً للقوانين اللبنانية، تقبل ورقة حضور آخر جمعية عمومية مؤقّعة من قبل المساهمين الحاضرين أو من يمثلهم).</p> <p>Official document that determines the identity and the ownership percentage of each person holding more than 20% of the entity's capital (for joint-stock companies established pursuant to Lebanese laws, the attendance sheet of the last general assembly signed by the attending shareholders or their representatives may be submitted).</p>			
<b>٢. الشخص الطبيعي Individual</b>			
	<p>مستندات تبين المعلومات التالية:</p> <ul style="list-style-type: none"> <li>- مكان وتاريخ الولادة</li> <li>- العنوان الكامل لمكان الإقامة</li> <li>- عنوان البريد الإلكتروني</li> <li>- رقم الهاتف</li> <li>- إفادة صادرة عن وزارة المالية اللبنانية (أو الجهة المعنية بالنسبة للشخص غير المقيم) تبين الرقم الضريبي</li> </ul>	العميل Customer	
<p>صورة عن هوية/جواز سفر (ما يثبت جنسية الشخص المعني)</p> <p>Copy of ID card/passport (evidencing the nationality of the concerned individual)</p>	<p>Documents indicating:</p> <ul style="list-style-type: none"> <li>- The date and place of birth</li> <li>- The full residential address</li> <li>- The e-mail address</li> <li>- The telephone number</li> <li>- Certificate issued by the Lebanese Ministry of Finance (or the concerned authority regarding non-resident persons) indicating the Tax Identification Number (TIN)</li> </ul>	<p>السند الخطي الذي يخول من يمثل العميل اتخاذ هذه الصفة (مثلاً، أصل أو نسخة طبق الأصل عن وكالة)، مؤرخاً وموقّعاً أمام موظف رسمي أو كاتب عدل أو ما يمثله وفقاً لقانون البلد حيث نظم السند، على أن يتم التأكد من تاريخ الصلاحية ومن الصلاحيات المعطاة للشخص الذي يمثل العميل بموجب السند المذكور.</p> <p>A written document authorizing the customer's representative to act in this capacity (i.e. an original or a duly certified copy of the proxy), dated and signed in the presence of a public officer or notary or the like, pursuant to the Law of the country where the said document was prepared, and provided the document validation date and the representative's powers are verified.</p>	<p>الشخص الذي يمثل العميل</p> <p>Customer's representative</p>

## المُلحق رقم (٧)

### وثيقة رقم ٥: تعهد بصحة المعلومات

أنا الموقع أدناه، .....

أتعهد، باسمي و/أو باسم الشخص المعنوي الذي أمثله، على مسؤوليتي الشخصية، وفي معرض تعاملي مع مصرف لبنان:

1. بأن المستندات كافة المقدمة إلى مصرف لبنان صحيحة وتعكس الوضع الحالي بالنسبة لي و/أو بالنسبة للشخص المعنوي الذي أمثله وهي صادرة عن الجهة المخولة بإصدارها.
2. بأن أبلغ مصرف لبنان، فوراً وخطياً، بأي تعديل يطرأ على المستندات المذكورة، سيما في حال لم يعد مضمون أي من هذه المستندات يعكس الوضع الحالي بالنسبة لي و/أو بالنسبة للشخص المعنوي الذي أمثله.

كما أقر، باسمي و/أو باسم الشخص المعنوي الذي أمثله، على مسؤوليتي الشخصية، بأنني أخذت علماً بأن أي مخالفة لأي من الالتزامات المحددة أعلاه، قد تنتج عنها تبعات قانونية منها وقف التعامل فوراً و/أو فسخ العقد الموقع مع مصرف لبنان على مسؤوليتي الشخصية و/أو مسؤولية الشخص المعنوي الذي أمثله، مع احتفاظ مصرف لبنان بحقه في مقاضاتي ومطالبتي بالتعويضات القانونية.

الاسم الثلاثي

التوقيع

بيروت، في ...../...../.....