

AREA OF COVERAGE OF LIGHTNING SYSTEM

Zone 2 For administration build.

S17

Distance between modules rows is 1m
South direction
Aluminum anodized Structure thickness 2mm
aluminum rails 41x41mm
ballasted type triangular low profile

PORTABLE DRY
POWDER FIRE
EXTINGUISHER 12KG

PV SOLAR CABLES 10MM2
IN CABLE TRAY
6 STRINGS OF 15MODULES EACH

PV SOLAR CABLES
10MM2 DN IN
CABLE TRAY TO
GRD LEVEL (sp. 6)

PV SOLAR MODULES 550W
(TYP. TO 90)

FREE ZONE ENTRANCE

office

S16

B106

PV SOLAR CABLES 10MM2
UNDER GROUND TO INVERTER
ROOM (EXCAVATION IS NEEDED
TO PROTECT CABLES)

NEW GENERATOR
LOCATION, OUTDOOR
AREA

PV SOLAR CABLES 10MM2
INVERTER AT UPPER STAIR
LEVEL