



مصرف لبنان
BANQUE DU LIBAN

31/07/2023 بيروت في

مديرية الخدمات
الرقم:

حضره السيد إيلي أبي صابر المحترم
مدير وحدة المشتريات

الموضوع: شراء وتركيب مولدات كهربائية لفروع مصرف لبنان (جونية - عاليه - صيدا - النبطية - بعلبك) - رقم التسجيل

SD00277-23

المرجع: أسئلة - الأجوبة التوضيحية - القسم الأول

بالإشارة إلى الموضوع والمرجع المبينين أعلاه،
بناءً على زيارة الفروع التي تمت مع ممثلين مصرف لبنان، وعطفاً على بعض الأسئلة الموجهة من قبل الشركات، يود
مصرف لبنان توضيح التالي:

بناءً على الأسئلة الواردة من الشركات بعد زيارة الموقع والمبنية أدناه، للنفضل باعتماد التعديل المفصل أدناه كملحق تعديلي
للائحة الشروط التقنية والفنية:

A- Kindly let us know if engines

- John Deere
- Deutz

Are acceptable.

We have no objection on the proposed engines brands if the submitted technical data sheets
comply with our specifications,

B- Kindly note that concerning having space inside the canopy 0.6 meter its not applicable. The canopy is already 60 kva and small in size and the maintenance employees cannot fit inside it. Also the size will be very large and expensive.

The maintenance can be easily done in our standard size canopies.

Also, in some locations it will not fit.

Jounieh: The only change in specs is BOQ Item B5 - 5) Canopy shall have 0.6m internal free space around the generator. The bidders should disregard this clause due to the confined space, the new canopy must be the same size as the existing one.

Aley & Baalbeck: The only change in specs is BOQ Item B5 - 5) Canopy shall have 0.6m internal free space around the generator. We requested the bidders to disregard this clause since the generator is located in a confined space and access to the generator must be through the doors of the canopy.

C- In Baalbek we will fit the panel to the left without increasing the cable size.

The Electrical circuit breaker of the new generator should be located inside the canopy in a way to avoid replacing the existing power cable and a Concrete foundation (not less than 30 Pascal) for the

15



مصرف لبنان
BANQUE DU LIBAN

new generator is required to make leveling with a thickness not less than 12 cm with reinforced steel bars 12 mm diameter.

D- Alley we need exhaust connection pipe + flexible + elbow.

It can be black steel or black steel + rock wool + aluminum jacketing.

The exhaust should be made of Black steel pipe to suit the generator size with rock wool insulation and aluminum jacketing same as existing.

It should be connected to the existing exhaust of the 150 KVA generator in a proper way to avoid smoke leak.

E- Moreover, we would like to confirm whether the use of the Lister Petter Engine is approved for this project

We have no objection on the proposed engines brands if the submitted technical data sheets comply with our specifications,

كما تجدون أدناه المستند الإداري KYC00 المذكور في دفتر الشروط ولكن غير مرقم

F- Could you please assist regarding the attached file.

We as a company what should we fill out (KYC00 & KYC01)

We did not find KYC00.

KYC00 refers to form attached below, refer to page 40 of the TOR for instructions.

الملحق رقم (٢)
وثيقة رقم ٢ : استماراة الامتثال للعميل
Customer Compliance Form

Customer's Full Name	اسم العميل
"KYC" - 01"	عدد الاستمارات المرفقة باستماراة الامتثال الحاضرة Number of "KYC-01" Forms attached to this Compliance Form
"KYC" - 02"	عدد الاستمارات المرفقة باستماراة الامتثال الحاضرة Number of "KYC-02" Forms attached to this Compliance Form

G- We kindly ask you if we can submit this bond from our Lollar account

No.

شاكرين تعاونكم.

مدير الخدمات
وليد حليق