

كهرباء لبنان
"مؤسسة عامة"
ELECTRICITE DU LIBAN
"Etablissement Public"

[]

شارع النهر - بيروت - تلفون : 01-442720
تلفرافيا : كهرباء لبنان
فاكس : 01583084

[]

رقم المحفوظات
رقم الصادر **٢٩٧٨**
بيروت في ١٣ / ٠٥ / ٢٠٢٦

الموضوع: المناقصة العمومية رقم م.ع. ٢٠٢٦/٠٧ - تقديم ثلاث محطات تحويل نقالة ١٥-٦٦/٢٠ ك.ف قدرة ٢٠ م.ف. لكل واحدة وتركيب اثنتين منها في الطيبة وبقسما - توضيحات دفعة 5 على دفتر الشروط - المادة ٢١ من قانون الشراء العام.

المراجع:

بالإشارة الى الموضوع أعلاه، وعطفاً على الدعوة إلى المناقصة العمومية رقم م.ع. ٢٠٢٦/٠٧ بموضوع تقديم ثلاث محطات تحويل نقالة ١٥-٦٦/٢٠ ك.ف قدرة ٢٠ م.ف. لكل واحدة وتركيب اثنتين منها في الطيبة وبقسما المُعلن عنها على موقع هيئة الشراء العام تحت الرقم ١٠٥٤٩ بتاريخ ٢٠٢٦/٠١/١٦،

تبدي مؤسسة كهرباء لبنان التوضيح التالي على سؤال وارد من عارض محتمل:

سؤال:

Regarding 66 kV current transformer, referring to section 3.1.6-2: "Current Transformers shall be insulated and suitable for outdoor use. They shall comply with the requirements of IEC61869-2. Bushing current transformers and combined voltage and current transformers are not acceptable"

Since this is a mobile Substation application, and in order to comply with dimensional limitations while maintaining a compact/economical solution, kindly confirm that 66 kV bushing-type current transformer (installed on the HV bushing of the power transformer) is acceptable."

جواب:

يرجى الالتزام قطعاً بدفتر الشروط

يؤمل أخذ العلم.

ع.ب.
ف.ع.
ج.ف.

رئيس مجلس الإدارة
المدیر العام

كمال الحايك

