Mideast Power Systems
An YTG company

Capital 5,000,000 LBP
CRB 51777
Mkalles Diab Bldg. - 01-682000
Beirut Lebanon,
Phone: 01595615
Fax: 01595616
Email: mailto:info@mps.com.lb
VAT ID : 4549-601

QUOTATION

DATE 05/10/2026
NO 00093998

SHIP TO
,

SOLD TO
MIC 2 SAL
TIN No: 291711
.
Downtown behind Azarieh bldg
, Beirut Lebanon
T: 01566111

Payment Terms
Immediately

No.	Item	LocID	Unit	VAT%	Ordered	Unit Price U$	Total Price U$
1	KIT 3 CAPACITORS 200MF	XtremeM ks	PCS	11	2	750.00	1,500.00
	Output AC Capacitors for your two Schneider Electric Galaxy5000-120kVA UPS with serial numbers 1P5K11001 and 1P5K11002						
2	INPUT AC CAP. GALAXY5000/60	XtremeM ks	PCS	11	2	1,350.00	2,700.00
	Input AC Capacitors for your two Schneider Electric Galaxy5000-120kVA UPS with serial numbers 1P5K11001 and 1P5K11002						
3	DC CAPA KIT G5K 40-60 KVA	XtremeM ks	PCS	11	2	2,900.00	5,800.00
	DC Capacitors for your two Schneider Electric Galaxy5000-120kVA UPS with serial numbers 1P5K11001 and 1P5K11002						

Joseph Abdo
Large/Others

Original

Mideast Power Systems
An YTG company

Capital 5,000,000 LBP
CRB 51777
Mkalles Diab Bldg. - 01-682000
Beirut Lebanon,
Phone: 01595615
Fax: 01595616
Email: mailto:info@mps.com.lb
VAT ID : 4549-601

QUOTATION

DATE 05/10/2026
NO 00093998

SHIP TO
,

SOLD TO
MIC 2 SAL
TIN No: 291711
.
Downtown behind Azarieh bldg
, Beirut Lebanon
T: 01566111

Payment Terms
Immediately

No.	Item	LocID	Unit	VAT%	Ordered	Unit Price U$	Total Price U$

TOTAL BEFORE VAT	**10,000.00**
VAT 11%	1,100.00
TOTAL AFTER VAT	**11,100.00**

Being ELEVEN THOUSAND ONE HUNDRED AND 0/100 U.S.DOLLARS

General Conditions:
1- Offer validity: 15 days
2- Expected delivery date: 6 up to 7 months upon approval
3- Payment terms: 100% USD Cash banknotes upon approval - To be paid by bank transfer in LBP at time of payment as per current rate.
4- UPS installation date on May-2009

Disclaimer: It is understood between the Parties that the Fees are calculated and agreed upon based on the applicable customs fees and rates in the Republic of Lebanon at the current prevailing official rate against US Dollar. In the event of any changes of the said customs fees and rates upon clearing the Goods with the customs' authority, the Purchaser shall bear any increase or change to the said customs without any objection or reserves. The mentioned due VAT has been calculated at the current BDL official rate (the "Initial Rate"). However, the due VAT should be paid by the client exactly in the same way and same amount as the Company pays it to the Lebanese authorities currently or following the latter's increase or change of the Initial Rate (the "Modified Rate").
Should the Lebanese Authorities reject, challenge, amend or modify in a way or another the above Initial Rate or the total VAT sum due on invoices related to this agreement, the Client shall additionally pay to the Company, despite its previous payment of the VAT at the Initial Rate, the difference between the Modified Rate and the Initial Rate upon the Company's first demand.

Name:

Signature:

Mideast Power Systems
An ITG Company

51877

UPS PREVENTIVE/CORRECTIVE MAINTENANCE REPORT

Preventive ☐
Corrective ☑

UPS2

Call ID	Region	Customer	System	Serial No.
	Adlia	HIC 2	G Sam. 60 kVA	1PSK1001

Engineer: JOSEPH CHEHWAN | Date: 30 Sep 26

Status Upon Arrival:
Failure Analysis:
Summary of Service: Restart in Parallel Normal operation
ET must replace the AC & DC capacitors

OPERATIONAL STATUS

		Temperature		Vng
- Mains 1 input	VAC	389	389	389
- Hz 50	Amps	11	11	11
- Mains 2 input	VAC	386	386	387
- Battery charger	VDC	462	Amps	
- UPS output	VAC	383	382	381
- Hz 50	Amps	6	12	12

BATTERY DATA

Delivered by	MPS	External ☑	Built in ☐
Date Code		Flooded ☐	Sealed ☑
Model		Quantity	34
		Rating	95 AH

CHECK CARRIED OUT	NOK	OK
UPS & battery room visual check	☐	☐
Ambient temperature	☐	☐
UPS alarms check	☐	☐
Mains 1 measurement (Vrms/Hz/A)	☐	☐
Mains 2 measurement (Vrms/Hz/A)	☐	☐
Charger voltage measurement	☐	☐
Inverter measurement (Vrms/Hz/A)	☐	☐
Fan operation	☐	☐
Battery visual check	☐	☐
Battery voltage measurements	☐	☐
UPS cleaning	☐	☐
Com. options check	☐	☐

Parts Used

Part No.	Qty	Part No.	Qty

Remarks

Normal operation

Customer Remarks:

Time In: | Time Out:

*** For Technical Support: APC/Schneider & Vertiv UPS: 71-69 66 97 or Eaton UPS: 71-63 66 37 | 76-42 16 48 ***

*** Unable to reach us? Want to file a complaint? Call ITG Hotline (24/7): 04-594 400 ***

Customer Signature: Hazem Habanjar

Field Engineer Signature:

2 000 - Ext. 415

WHITE: Customer - BLUE: Administration - GREEN: Accounting

Mideast Power Systems
An ITG Company

51876

UPS PREVENTIVE/CORRECTIVE MAINTENANCE REPORT

Preventive ☐
Corrective ☑

UPS1

Call ID	Region	Customer	System	Serial No.
	Adlia	HIC 2	G Sam. 60 kVA	1PSK1002

Engineer: JOSEPH CHEHWAN | Date: 30 Sep 26

Status Upon Arrival:
Failure Analysis:
Summary of Service: Restart of the UPS, Normal operation
ET must replace the AC & DC capacitors

OPERATIONAL STATUS

		Temperature		Vng
- Mains 1 input	VAC	389	389	389
- Hz 50	Amps	17	17	17
- Mains 2 input	VAC	386	386	386
- Battery charger	VDC	462	Amps	
- UPS output	VAC	381	380	377
- Hz 50	Amps	16	11	11

BATTERY DATA

Delivered by	MPS	External ☑	Built in ☐
Date Code		Flooded ☐	Sealed ☑
Model		Quantity	34
		Rating	95 AH

CHECK CARRIED OUT	NOK	OK
UPS & battery room visual check	☐	☑
Ambient temperature	☐	☑
UPS alarms check	☐	☑
Mains 1 measurement (Vrms/Hz/A)	☐	☑
Mains 2 measurement (Vrms/Hz/A)	☐	☑
Charger voltage measurement	☐	☑
Inverter measurement (Vrms/Hz/A)	☐	☑
Fan operation	☐	☑
Battery visual check	☐	☑
Battery voltage measurements	☐	☑
UPS cleaning	☐	☑
Com. options check	☐	☑

Parts Used

Part No.	Qty	Part No.	Qty

Remarks

Normal

Customer Remarks:

Time In: | Time Out:

*** For Technical Support: APC/Schneider & Vertiv UPS: 71-69 66 97 or Eaton UPS: 71-63 66 37 | 76-42 16 48 ***

*** Unable to reach us? Want to file a complaint? Call ITG Hotline (24/7): 04-594 400 ***

Customer Signature: Hazem Habanjar

Field Engineer Signature:

Tel: 01 682 000 - Ext. 415

WHITE: Customer - BLUE: Administration - GREEN: Accounting